

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160516-E28476  
**Report Reference** E28476-20121128  
**Issue Date** 2016-MAY-16

**Issued to:** TYCO ELECTRONICS CORP  
2901 FULLING MILL RD  
MIDDLETON PA 17057-3170.

**This is to certify that**  
representative samples of  
COMPONENT - CONNECTORS FOR USE IN DATA,  
SIGNAL, CONTROL AND POWER APPLICATIONS  
Series Power Triple Lock, PTL-MFBL.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1977 - Component Connectors for Use in Data, Signal,  
Control and Power Applications  
CAN/CSA C22.2 No. 182.3 - Special Use Attachment  
Plugs, Receptacles, and Connectors

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Recognized components are incomplete in certain constructional features or restricted in performance  
capabilities and are intended for use as components of complete equipment submitted for investigation rather  
than for direct separate installation in the field. The final acceptance of the component is dependent upon its  
installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



File E28476

Vol. 4	Sec. 97
Vol. 10	Sec. 16
Vol. 102	Sec. 16
Vol. 121	Sec. 1
Vol. 122	Sec. 2
Vol. 123	Sec. 8

Page 1

Issued: 2012-11-28  
 Revised: 2016-05-15

and Report

## DESCRIPTION

## PRODUCT COVERED:

USR, CNR Component Connector, Series Power Triple Lock, PTL-MFBL.

## GENERAL:

These devices are multi-pole connectors intended for factory assembly on copper wire sizes as indicated in Ratings table below where the acceptability of combinations is determined by UL LLC. The devices are identified as follows:

USR indicates investigation to United States Standards, UL 1977.

CNR indicates investigation to Canadian National Standards,  
 C22.2 No. 182.3.

## RATINGS:

Series	No. of Positions	Voltage, V ac/ dc	Ampere (A)									
			12 AWG	14 AWG	16 AWG	18 AWG	20 AWG	18*2 AWG	20*2 AWG	22 AWG	22*2 AWG (1)	22*2 AWG (1) (2)
Power Triple Lock	1	600	20	15	15	10	9	16	12	6.2	6	12
	2		20	15	15	10	9	16	12	6.2	6	12
	3		20	15	12	10, 8	9	16	12	6.2	6	12
	4		19	14	12	9.8	9	16	12	6.2	4.5	9
	5		18	13	12	9.8	6.8	14	12	6.2	4.5	9
	6		18	13	12	9.8, 9.4 , 7.8	6.8	14	12	6.2	4.5	9
	7		16	12	11	9	6.8	14	10	6.2	4	8
	8		16	12	11	9	6.8	14	10	6.2	4	8
	9		16	12	11	9, 8.5, 7.2	6.8	14	10	6.2	4	8
	10		15	12	8	7	6.5	12	10	5.8	4	8
	11		15	12	8	7	6.5	12	10	5.8	4	8
	12		15	12	8	7, 5.6	6.5	12	10	5.8	4	8
	13		14	10	8	6	6.5	10	8	5	3.5	7
	14		14	10	8	6	6.5	10	8	5	3.5	7
	15		14	10	8	6, 4.8	6.5	10	8	5	3.5	7
PTL - MFBL	2	600			12	8	7.2				4.8	
	3				9.6	8	7.2				4.8	

Note: (1) Limited to quick-connect terminals 1971783 (Ill. 18), 2238066-1, -2 (Ill. 35) and 1971784 (Ill. 9), 2238067-1, -2 (Ill. 36).

(2) Limited to USR only.

Disconnecting Use - see Sec Gen for required marking.

and Report

## TECHNICAL CONSIDERATIONS (NOT FOR FIELD REPRESENTATIVE'S USE):

Use - For use only in or with complete equipment where the acceptability of the combination is determined by UL LLC.

Conditions of Acceptability - The following are among the considerations to be made when evaluating the device in the end-use product.

## Interruption of Current

1. These devices are not suitable for interrupting the flow of current by connecting or disconnecting the mating connector.

## Current-Carrying Capability and Current Ratings

2. These devices have been subjected to the Temperature test with the rated currents and maximum temperature rise values tabulated below.

Table 1 Temperature rise for the Plug Connectors

Series Name	Power Triple Lock, Plug													
	Current, A							Maximum Temperature Rise, °C						
	*No. of Positions							No. of Positions						
Wire Size, AWG	2	3	4	6	9	12	15	2	3	4	6	9	12	15
12	20	20	19	18	16	15	14	23	25	25.4	-	24.1	28.97	27.21
14	15	15	14	13	12	12	10	23.3	20	19.6	22.8	21.7	24.24	25.20
16	10	10	9	9	8	8	8	14.9	-	15.2	13.4	13.5	23.21	26.53
16	15	12	12	12	11	8	8	28.9	-	-	28.2	29.6	-	-
								7			4	1		
18	8	8	8	7	7	7	6	-	14.8	-	14	14.3	20.89	19.93
18	10	10	9.8	9.8	9	7	6	-	25.0	-	28.9	26.1	-	-
									0		6	7		
18*2	<b>16</b>	<b>16</b>	<b>16</b>	<b>14</b>	<b>14</b>	<b>12</b>	<b>10</b>	-	27.7	-	25.1	22.5	26.39	21.14
20	6	6	6	6	5	6	6	-	-	14.1	-	14.2	23.13	19.19
20	9	9	9	6.8	6.8	6.5	6.5	-	-	26.6	-	27.8	-	26.84
										3		8		
20*2	<b>12</b>	<b>12</b>	<b>12</b>	<b>12</b>	<b>10</b>	<b>10</b>	<b>8</b>	-	-	28.7	-	25.7	26.11	18.90
22	4	4	4	4	3	4	4	-	-	9.2	-	8	13.36	17.00
22	6.2	6.2	6.2	6.2	6.2	5.8	5	-	-	-	-	27.7	27.83	24.03
22*2	(1)	6	(2)	4.5	(3)	4	3.5	(1)	18.1	(2)	13.9	(3)	12.7	12.7 (4)

and Report

 Temperature rise for the Cap Connectors employing Receptacle/Tab contact  
 (2238066-1 / 2238067-1)

Series Name	Power Triple Lock, Cap													
	Current, A							Maximum Temperature Rise, °C						
	No. of Positions							No. of Positions						
2	3	4	6	9	12	15	2	3	4	6	9	12		
18	-	10	-	9.4	8.5	7	6	-	28.2	-	28.7	19.3	27.9	27.9

 Temperature rise for the Plug Connectors employing Receptacle/Tab contact  
 (2238066-1 / 2238067-1)

Series Name	Power Triple Lock, Plug													
	Current, A							Maximum Temperature Rise, °C						
	No. of Positions							No. of Positions						
2	3	4	6	9	12	15	2	3	4	6	9	12		
18	-	10	-	9.4	8.5	7	6	-	29.1	-	28.9	24.9	25.4	25.4

 Temperature rise for the Cap Connectors employing Receptacle/Tab contact  
 (2238066-2 / 2238067-2)

Series Name	Power Triple Lock, Cap													
	Current, A							Maximum Temperature Rise, °C						
	No. of Positions							No. of Positions						
2	3	4	6	9	12	15	2	3	4	6	9	12		
18	-	8	-	7.8	7.2	5.6	4.8	-	18.4	-	21.5	24.3	17.5	15.1

 Temperature rise for the Plug Connectors employing Receptacle/Tab contact  
 (2238066-2 / 2238067-2)

Series Name	Power Triple Lock, Plug													
	Current, A							Maximum Temperature Rise, °C						
	No. of Positions							No. of Positions						
2	3	4	6	9	12	15	2	3	4	6	9	12		
18	-	8	-	7.8	7.2	5.6	4.8	-	19.9	-	22.0	24.6	17.3	15.7

## and Report

Table 2 Temperature rise for the Cap Connectors

Series Name	Power Triple Lock, Cap											
	Current, A							Maximum Temperature Rise, °C				
	No. of Positions							No. of Positions				
Wire Size, AWG	2	3	4	6	9	12	15	2	3	4	6	9
12	20	20	19	18	16	15	14	23	25	25.4	-	24.1
14	15	15	14	13	12	12	10	23.3	20	19.6	22.8	21.7
16	10	10	9	9	8	8	8	14.9	-	15.2	13.4	13.5
16	15	12	12	12	11	8	8	28.8	-	-	30.00	29.7
								4			8	-
18	8	8	8	7	7	7	6	-	14.8	-	14	14.3
18	10	10	9.8	9.8	9	7	6	-	24.75	-	29.47	25.8
											8	-
18*2	16	16	16	14	14	12	10	-	27.7	-	25.1	22.5
20	6	6	6	6	5	6	6	-	-	14.1	-	14.2
20	9	9	9	6.8	6.8	6.5	6.5	-	-	28.2	-	26.1
										9	0	0
20*2	12	12	12	12	10	10	8	-	-	28.7	-	25.7
22	4	4	4	4	3	4	4	-	-	9.2	-	8
22	6.2	6.2	6.2	6.2	6.2	5.8	5	-	-	-	-	28.5
										5	5	29.69
22*2	(1)	6	(2)	4.5	(3)	4	3.5	(1)	15.6	(2)	15.6	(3)
							(4)					12.2
												(4)

These devices have been subjected to the Temperature test with the rated currents and recorded temperature (adjusted to 25°C ambient) values tabulated below:

Table 1A Temperature rise for the Plug Connectors:

Series Name	Power Triple Lock, Plug											
	Current, A							Maximum Temperature, °C				
	No. of Positions							No. of Positions				
Wire Size, AWG	2	3	4	6	9	12	15	2	3	4	6	9
22*2	(1)	12	(2)	9	(3)	8	7	(1)	80.4	(2)	61.2	(3)
							(4)					63.7
												77.1
												(4)

Table 2A Temperature rise for the Cap Connectors:

Series Name	Power Triple Lock, Cap											
	Current, A							Maximum Temperature, °C				
	No. of Positions							No. of Positions				
Wire Size, AWG	2	3	4	6	9	12	15	2	3	4	6	9
22*2	(1)	12	(2)	9	(3)	8	7	(1)	81.8	(2)	60.2	(3)
							(4)					64.7
												75.9
												(4)

## Note:

(1) Represented by 3 position device inclusive of 1 position device; (2) represented by 6 position device inclusive of 5 position device; (3) Represented by 12 position device inclusive of 8, 10, 11 position devices; (4) Represents the 13 and 14 position devices.

File E28476      Vol. 4      Sec. 97      Page 3A      Issued: 2012-11-28  
                     Vol. 10      Sec. 16      Revised: 2016-08-02  
                     Vol. 102     Sec. 16  
                     Vol. 121     Sec. 1  
                     Vol. 122     Sec. 2  
                     Vol. 123     Sec. 8  
                                     and Report

(#) - Code for Insulating Body Material.

(+) - Indicates material only applicable to the following Cat. Nos.:

Cat. No.	Max No. of Positions
1-2232263-1	5
2-2232263-1	5
1-2232264-1	6
1-2232265-1	5
2-2232265-1	5
1-2232266-1	6
1-2232356-6	9
1-2232357-6	15
1-2232356-5	15
1-2232357-4	12
1-2232357-5	15
1-2232360-4	12
1-2232360-5	15

(@) - Indicates material A applicable to level 2 in Ills. 1 thru 6, 13 thru 15, with the marking HDT in products; material B applicable to level B in Ills. 22 thru 27, with the marking HWT in products; material C applicable to level 1 in Ills. 1 thru 6, 13 thru 15, with the marking PBT in products; material D applicable to level A in Ills. 22 thru 27 and 31 thru 33 with the marking GWT in products. Material E applicable to Power Triple Lock Header in Ill. 34 and 37.

- A.      Tyco Raw  
             Material P/N 705264.  
             1. Dielectric strength (kV/mm): 25  
             2. CTI: 0
- B.      Tyco Raw  
             Material P/N 1573374  
             1. Dielectric strength (kV/mm): 23  
             2. CTI: 3
- C.      Tyco Raw  
             Material P/N 1573716.  
             1. Dielectric strength (kV/mm): -  
             2. CTI: 2
- D.      Tyco  
             Raw Material P/N 2136325.  
             1. Dielectric strength (kV/mm): 11  
             2. CTI: 1

File E28476

Vol. 4            Sec. 97  
Vol. 10          Sec. 16  
Vol. 102         Sec. 16  
Vol. 121         Sec. 1  
Vol. 122         Sec. 2  
Vol. 123         Sec. 8  
                    and Report

Page 3B

Issued: 2012-11-28

Revised: 2016-08-02

E.      Tyco Raw Material P/N 2136507.  
1. Dielectric strength (kV/mm): **19**  
2. CTI: -

F.      Tyco Raw Material P/N 2136325 w/ Colorants #XXXXXXX, #XXXXXXXX.  
1. Dielectric strength (kV/mm): 11  
2. CTI: 1

and Report

Table 3 Temperature rise for the Header Connectors

Series Name	Power Triple Lock, Header								
	Current, A					Maximum Temperature Rise, °C			
No. of Contacts						No. of Contacts			
2	3	4	5	2	3	4	5		
20	20	19	18	24.9	24.9	23.6	22.0		

Table 4 Temperature rise for the Cap/Plug Connectors:

Series Name	Power Triple Lock, Plug			
	Current, A		Maximum Temperature Rise, °C	
Wire Size, AWG	No. of Positions		No. of Positions	
	2	3	2	3
16	12	9.6	24	20.6
18	8	8	17.2	21.8
20	7.2	7.2	18.2	21.0

## Insulating Materials

3. These devices employ insulating materials with properties as tabulated below at the minimum thickness employed in the connector housing, the suitability of the insulating materials based on the documented values shall be determined in the end-use application. Please note the values specified in the table when multiple materials are indicated represent the minimum values for the group of materials.

Series	Insulating Material (#)	Measured Minimum Thickness	Flame Class	HWI	HAI	RTI Elec	Max Operating Temp, °C
Power Triple Lock(®)	A for housing	0.5 mm	V-0	4	2	150	150
	B for housing(+)	0.75 mm	V-0	-	-	140	140
	C for housing	0.5	V-0	4	3	130	130
	D for housing	0.75 mm	V-0	2	0	140	140
	E for housing	0.5	V-0	3	0	140	140
	F for housing	0.8 mm	V-0	2	0	140	140

## Mating Connectors

4. These devices have only been assessed for use with specific types of connectors within their product family. They have not been assessed to operate with any other similar devices from any other manufacturer.

\*5. Crimp contacts of Power Triple Lock Series are intended for crimp termination on stranded copper conductor using the automatic crimp machine shown in Fig. 1, Fig. 2 and Fig. 3 matched with applicators indicated below respectively in table 4, and the hand tool requirements shown in table 5, see below tables for details.

\*Table 4

Contact	US/EMEA only Ocean Atlantic Application Tool P/N	US/EMEA only Ocean Pacific Application Tool P/N	AP only HDE Applicati on Tool P/N	Wire Size (AWG )	Crimp Width (mm)	Crimp Height (mm)
Tab/ Rec	2151741-1	2-2151741-1	1552992-2	12	3.05	1.87±0.05
	2151742-1	2-2151742-1	1552993-2	14	2.29	1.56±0.05
				16		1.37±0.04
	2151743-1	2-2151743-1	1552994-2	18	2.03	1.21±0.04
				20		1.08±0.04
	2151745-1	2-2151745-1	1552996-2	18*2	2.29	1.53±0.05
	2151746-1	2-2151746-1	1552511-2	20*2	2.03	1.28±0.04
	2151744-1	2-2151744-1	1552995-2	22	1.4	0.89±0.03
	2151743-1	2-2151743-1	--	22*2	2.03	1.08±0.04

\*Table 5

Contact	Hand Tool No.	Wire Size (AWG)	Crimp Width (mm)	Crimp Height (mm)
Tab/ Rec	2217268-1	12	3.05	1.87+0.05- 0.1
	2217266-1	14	2.29	1.56+0.05- 0.1
		16		1.37+0.04- 0.08
	2217208-1	18	2.03	1.21+0.04- 0.08
		20		1.08+0.04- 0.08
	2217266-1	18*2	2.29	1.53+0.05- 0.1
	2217267-1	20*2	2.03	1.28+0.04- 0.08
	2217267-1	22	1.4	0.89+0.03- 0.06