

## Feed-through terminal block - UT 4-TWIN HV - 3000608

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid  
(<http://phoenixcontact.com/download>)



Feed-through terminal block, Connection method: Screw connection, Cross section: 0.14 mm<sup>2</sup> - 6 mm<sup>2</sup>, AWG: 26 - 10, Width: 6.2 mm, Color: gray, Mounting type: NS 35/7,5, NS 35/15



### Key Commercial Data

|              |                                                                                                         |
|--------------|---------------------------------------------------------------------------------------------------------|
| Packing unit | 50 STK                                                                                                  |
| GTIN         | <br>4 046356 726184 |
| GTIN         | 4046356726184                                                                                           |

### Technical data

#### Environmental Product Compliance

|            |                                                                          |
|------------|--------------------------------------------------------------------------|
| China RoHS | Hazardous substances above threshold values                              |
|            | Environmentally Friendly Use Period = 50                                 |
|            | For details go to tab "Downloads", Category "Manufacturer's declaration" |

#### General

|                                        |                   |
|----------------------------------------|-------------------|
| Number of levels                       | 1                 |
| Number of connections                  | 3                 |
| Potentials                             | 1                 |
| Nominal cross section                  | 4 mm <sup>2</sup> |
| Color                                  | gray              |
| Insulating material                    | PA                |
| Flammability rating according to UL 94 | V0                |
| Rated surge voltage                    | 6 kV              |
| Degree of pollution                    | 3                 |
| Overvoltage category                   | III               |
| Insulating material group              | I                 |

# Feed-through terminal block - UT 4-TWIN HV - 3000608

## Technical data

### General

|                                                                                           |                                                                                                                                                                   |
|-------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Maximum load current                                                                      | 39 A (In the case of a 6 mm <sup>2</sup> conductor cross section, the maximum load current must not be exceeded by the total current of all connected conductors) |
| Nominal current I <sub>N</sub>                                                            | 32 A                                                                                                                                                              |
| Nominal voltage U <sub>N</sub>                                                            | 1000 V                                                                                                                                                            |
| Open side panel                                                                           | Yes                                                                                                                                                               |
| Shock protection test specification                                                       | DIN EN 50274 (VDE 0660-514):2002-11                                                                                                                               |
| Back of the hand protection                                                               | guaranteed                                                                                                                                                        |
| Finger protection                                                                         | guaranteed                                                                                                                                                        |
| Result of surge voltage test                                                              | Test passed                                                                                                                                                       |
| Surge voltage test setpoint                                                               | 9.8 kV                                                                                                                                                            |
| Result of power-frequency withstand voltage test                                          | Test passed                                                                                                                                                       |
| Power frequency withstand voltage setpoint                                                | 2.2 kV                                                                                                                                                            |
| Result of the test for mechanical stability of terminal points (5 x conductor connection) | Test passed                                                                                                                                                       |
| Result of bending test                                                                    | Test passed                                                                                                                                                       |
| Bending test rotation speed                                                               | 10 rpm                                                                                                                                                            |
| Bending test turns                                                                        | 135                                                                                                                                                               |
| Bending test conductor cross section/weight                                               | 0.14 mm <sup>2</sup> / 0.2 kg                                                                                                                                     |
|                                                                                           | 4 mm <sup>2</sup> / 0.9 kg                                                                                                                                        |
|                                                                                           | 6 mm <sup>2</sup> / 1.4 kg                                                                                                                                        |
| Tensile test result                                                                       | Test passed                                                                                                                                                       |
| Conductor cross section tensile test                                                      | 0.14 mm <sup>2</sup>                                                                                                                                              |
| Tractive force setpoint                                                                   | 10 N                                                                                                                                                              |
| Conductor cross section tensile test                                                      | 4 mm <sup>2</sup>                                                                                                                                                 |
| Tractive force setpoint                                                                   | 60 N                                                                                                                                                              |
| Conductor cross section tensile test                                                      | 6 mm <sup>2</sup>                                                                                                                                                 |
| Tractive force setpoint                                                                   | 80 N                                                                                                                                                              |
| Result of tight fit on support                                                            | Test passed                                                                                                                                                       |
| Tight fit on carrier                                                                      | NS 35                                                                                                                                                             |
| Setpoint                                                                                  | 1 N                                                                                                                                                               |
| Result of voltage-drop test                                                               | Test passed                                                                                                                                                       |
| Requirements, voltage drop                                                                | ≤ 3.2 mV                                                                                                                                                          |
| Result of temperature-rise test                                                           | Test passed                                                                                                                                                       |
| Short circuit stability result                                                            | Test passed                                                                                                                                                       |
| Conductor cross section short circuit testing                                             | 4 mm <sup>2</sup>                                                                                                                                                 |
| Short-time current                                                                        | 0.48 kA                                                                                                                                                           |
| Conductor cross section short circuit testing                                             | 6 mm <sup>2</sup>                                                                                                                                                 |
| Short-time current                                                                        | 0.72 kA                                                                                                                                                           |
| Result of thermal test                                                                    | Test passed                                                                                                                                                       |
| Proof of thermal characteristics (needle flame) effective duration                        | 30 s                                                                                                                                                              |

# Feed-through terminal block - UT 4-TWIN HV - 3000608

## Technical data

### General

|                                                                         |                                                     |
|-------------------------------------------------------------------------|-----------------------------------------------------|
| Oscillation, broadband noise test result                                | Test passed                                         |
| Test specification, oscillation, broadband noise                        | DIN EN 50155 (VDE 0115-200):2008-03                 |
| Test spectrum                                                           | Service life test category 1, class B, body mounted |
| Test frequency                                                          | $f_1 = 5 \text{ Hz}$ to $f_2 = 150 \text{ Hz}$      |
| ASD level                                                               | $1.857 \text{ (m/s}^2\text{)}^2/\text{Hz}$          |
| Acceleration                                                            | 0,8 g                                               |
| Test duration per axis                                                  | 5 h                                                 |
| Test directions                                                         | X-, Y- and Z-axis                                   |
| Shock test result                                                       | Test passed                                         |
| Test specification, shock test                                          | DIN EN 50155 (VDE 0115-200):2008-03                 |
| Shock form                                                              | Half-sine                                           |
| Acceleration                                                            | 5 g                                                 |
| Shock duration                                                          | 30 ms                                               |
| Number of shocks per direction                                          | 3                                                   |
| Test directions                                                         | X-, Y- and Z-axis (pos. and neg.)                   |
| Relative insulation material temperature index (Elec., UL 746 B)        | 130 °C                                              |
| Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) | 130 °C                                              |
| Static insulating material application in cold                          | -60 °C                                              |
| Behavior in fire for rail vehicles (DIN 5510-2)                         | Test passed                                         |
| Flame test method (DIN EN 60695-11-10)                                  | V0                                                  |
| Oxygen index (DIN EN ISO 4589-2)                                        | >32 %                                               |
| NF F16-101, NF F10-102 Class I                                          | 2                                                   |
| NF F16-101, NF F10-102 Class F                                          | 2                                                   |
| Surface flammability NFPA 130 (ASTM E 162)                              | passed                                              |
| Specific optical density of smoke NFPA 130 (ASTM E 662)                 | passed                                              |
| Smoke gas toxicity NFPA 130 (SMP 800C)                                  | passed                                              |
| Calorimetric heat release NFPA 130 (ASTM E 1354)                        | 28 MJ/kg                                            |
| Fire protection for rail vehicles (DIN EN 45545-2) R22                  | HL 1 - HL 3                                         |
| Fire protection for rail vehicles (DIN EN 45545-2) R23                  | HL 1 - HL 3                                         |
| Fire protection for rail vehicles (DIN EN 45545-2) R24                  | HL 1 - HL 3                                         |
| Fire protection for rail vehicles (DIN EN 45545-2) R26                  | HL 1 - HL 3                                         |

### Dimensions

|                  |         |
|------------------|---------|
| Width            | 6.2 mm  |
| End cover width  | 2.2 mm  |
| Length           | 57.8 mm |
| Height NS 35/7,5 | 50 mm   |
| Height NS 35/15  | 57.5 mm |

### Connection data

|                   |                  |
|-------------------|------------------|
| Connection method | Screw connection |
|-------------------|------------------|

## Feed-through terminal block - UT 4-TWIN HV - 3000608

### Technical data

#### Connection data

|                                                                                         |                      |
|-----------------------------------------------------------------------------------------|----------------------|
| Connection in acc. with standard                                                        | IEC 60947-7-1        |
| Conductor cross section solid min.                                                      | 0.14 mm <sup>2</sup> |
| Conductor cross section solid max.                                                      | 6 mm <sup>2</sup>    |
| Conductor cross section AWG min.                                                        | 26                   |
| Conductor cross section AWG max.                                                        | 10                   |
| Conductor cross section flexible min.                                                   | 0.14 mm <sup>2</sup> |
| Conductor cross section flexible max.                                                   | 6 mm <sup>2</sup>    |
| Min. AWG conductor cross section, flexible                                              | 26                   |
| Max. AWG conductor cross section, flexible                                              | 10                   |
| Conductor cross section flexible, with ferrule without plastic sleeve min.              | 0.14 mm <sup>2</sup> |
| Conductor cross section flexible, with ferrule without plastic sleeve max.              | 4 mm <sup>2</sup>    |
| Conductor cross section flexible, with ferrule with plastic sleeve min.                 | 0.14 mm <sup>2</sup> |
| Conductor cross section flexible, with ferrule with plastic sleeve max.                 | 4 mm <sup>2</sup>    |
| 2 conductors with same cross section, solid min.                                        | 0.14 mm <sup>2</sup> |
| 2 conductors with same cross section, solid max.                                        | 1.5 mm <sup>2</sup>  |
| 2 conductors with same cross section, stranded min.                                     | 0.14 mm <sup>2</sup> |
| 2 conductors with same cross section, stranded max.                                     | 1.5 mm <sup>2</sup>  |
| 2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, min. | 0.5 mm <sup>2</sup>  |
| 2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, max. | 1 mm <sup>2</sup>    |
| 2 conductors with same cross section, stranded, ferrules without plastic sleeve, min.   | 0.14 mm <sup>2</sup> |
| 2 conductors with same cross section, stranded, ferrules without plastic sleeve, max.   | 1.5 mm <sup>2</sup>  |
| Stripping length                                                                        | 9 mm                 |
| Internal cylindrical gage                                                               | A4                   |
| Screw thread                                                                            | M3                   |
| Tightening torque, min                                                                  | 0.6 Nm               |
| Tightening torque max                                                                   | 0.8 Nm               |

#### Standards and Regulations

|                                        |               |
|----------------------------------------|---------------|
| Connection in acc. with standard       | CUL           |
|                                        | IEC 60947-7-1 |
| Flammability rating according to UL 94 | V0            |

### Drawings

#### Circuit diagram



# Feed-through terminal block - UT 4-TWIN HV - 3000608

## Approvals

### Approvals

#### Approvals

UL Recognized / cUL Recognized / VDE Zeichengenehmigung / IECEx CB Scheme / EAC / CSA / EAC / cULus Recognized

#### Ex Approvals

IECEx / ATEX / EAC Ex

### Approval details

| UL Recognized  <a href="http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm">http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm</a> FILE E 60425 |       |       |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------|-------|
|                                                                                                                                                                                                                                                                    | B     | C     |
| mm <sup>2</sup> /AWG/kcmil                                                                                                                                                                                                                                         | 26-10 | 26-10 |
| Nominal current I <sub>N</sub>                                                                                                                                                                                                                                     | 30 A  | 30 A  |
| Nominal voltage U <sub>N</sub>                                                                                                                                                                                                                                     | 600 V | 600 V |

| cUL Recognized  <a href="http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm">http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm</a> FILE E 60425 |       |       |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------|-------|
|                                                                                                                                                                                                                                                                       | B     | C     |
| mm <sup>2</sup> /AWG/kcmil                                                                                                                                                                                                                                            | 26-10 | 26-10 |
| Nominal current I <sub>N</sub>                                                                                                                                                                                                                                        | 30 A  | 30 A  |
| Nominal voltage U <sub>N</sub>                                                                                                                                                                                                                                        | 600 V | 600 V |

| VDE Zeichengenehmigung  40040772 |          |
|---------------------------------------------------------------------------------------------------------------------|----------|
|                                                                                                                     |          |
| mm <sup>2</sup> /AWG/kcmil                                                                                          | 0.14-6.0 |
| Nominal current I <sub>N</sub>                                                                                      | 32 A     |
| Nominal voltage U <sub>N</sub>                                                                                      | 1000 V   |

| IECEx CB Scheme  <a href="http://www.iecee.org/">http://www.iecee.org/</a> DE1-54618 |        |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
|                                                                                                                                                                         |        |
| Nominal voltage U <sub>N</sub>                                                                                                                                          | 1000 V |

|                   |
|-------------------|
| EAC EAC-Zulassung |
|-------------------|

## Feed-through terminal block - UT 4-TWIN HV - 3000608

### Approvals

|                                                                                             |       |       |
|---------------------------------------------------------------------------------------------|-------|-------|
| CSA  13631 |       |       |
|                                                                                             | B     | C     |
| mm <sup>2</sup> /AWG/kcmil                                                                  | 26-10 | 26-10 |
| Nominal current I <sub>N</sub>                                                              | 30 A  | 30 A  |
| Nominal voltage U <sub>N</sub>                                                              | 600 V | 600 V |

|                         |
|-------------------------|
| EAC 7500651.22.01.00246 |
|-------------------------|

|                                                                                                                                                                                                                                                          |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| cULus Recognized  <a href="http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm">http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm</a> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Phoenix Contact 2016 © - all rights reserved  
<http://www.phoenixcontact.com>

PHOENIX CONTACT GmbH & Co. KG  
Flachsmarktstr. 8  
32825 Blomberg  
Germany  
Tel. +49 5235 300  
Fax +49 5235 3 41200  
<http://www.phoenixcontact.com>