DIN RAIL / PANEL MOUNT, AVERAGE RMS



Single Element - .79" Window 0.5 to 150 AAC Input Range



Two Element - .26" Window 0.5 to 30 AAC Input Range



Three Element - .26" Window 0.5 to 30 AAC Input Range

The **CR4400** Series, Current Transmitters produce a calibrated 4-20 mADC signal that is proportional to the average RMS input AC current. Designed for multi-point current sensing, these devices provide excellent features in a high value package. The output signal is generated from a user supplied 24 VDC power supply within the output current loop.

Applications

Multi-point current sensing and control panels Monitor motor faults Monitor heating elements Monitor lighting elements

Features

Low cost

DIN rail or panel mount

Available with 0-5 VDC, 0-10VDC or 4-20 mADC output High Accuracy

Interfaces with most commercially available instrumentation Connection diagram printed on case

Regulatory Agencies

Recognized to meet UL 61010B-1 Constructed to meet CAN/CSA-C22.2, No. 61010-1-2004 Meets requirement of IEC 61010-1 and BS EN 61010-1







E199795

Use a 5 Amp Secondary Current Transformer to extend the ranges of all CR Magnetics Current Transducers



All single phase current transducers are available in split core design. Simply put an "S" at the end of the prefix* I.E. CR4410S-10

* Not UL Recognized

PART NUMBERS						
CR4410(S)	-		Single element with 0 - 5 VDC output (split core design)			
CR4411(S)	-		Single element with 0 - 10 VDC output (split core design)*			
CR4420(S)	-		Single element with 4 - 20 mADC output (split core design)			
CR4450	-		Two element with 0 - 5 VDC output *			
CR4460	-		Two element with 4 to 20 mADC output *			
CR4470	-		Three element with 0 - 5 VDC output *			
CR4480	-		Three element with 4 - 20 mADC output *			

Two and three element transducers are available only in ranges of 0.5 to 30 AAC
* CR4411 Series not UL Recognized

Add suffix for input range

5 -	0-5 AAC
10 -	0-10 AAC
15 -	0-15 AAC
20 -	0-20 AAC
25 -	0-25 AAC
30 -	0-30 AAC
40 -	0-40 AAC
50 -	0-50 AAC
75 -	0-75 AAC
100 -	0-100 AAC
150 -	0-150 AAC

Ranges available up to and including 600 AAC

E-mail: sales@crmagnetics.com



3500 Scarlet Oak Blvd. St. Louis MO USA 63122 V: 636-343-8518 F: 636-343-5119

OUTPUT

OUTPUT 2

OUTPUT 2


OUTPUT 1

SUPPLY

SPECIFICATIONS

DIN RAIL / PANEL MOUNT, AVERAGE RMS

Basic Accuracy:	0.5%	Cleaning:	Water-dampe	ned cloth
Linearity:	10% to 100% FS	Relative Humidity:	80% for temp	eratures up
Thermal Drift:	500 PPM/°C	•	to 31°C and	decreasing
Operating Temperature:	0°C to +60°C		linearly to 50	% at 40°C
Installation Category:	CAT II	Supply Voltage:24	VDC ±10%	
Vibration Tested To:	IEC 60068-2-6,1995	Supply Current:		
Pollution Degree:	2	CR4410/11Ty	pical 20mA	Max 40mA
Response Time:	250 ms max., 0-90% FS	CR4420Ty	pical 25mA	Max 45mA
MTBF:	Greater than 100 K hours	CR4450Ty	pical 20mA	Max 75mA
Altitude:	2000 meter max.	CR4460Ty	pical 40mA	Max 90mA
Calibration: Average	e Sensing, RMS Calibrated	CR4470Ty	pical 25mA	Max 110mA
Insulation Voltage:	2500 VDC	CR4480Ty	pical 55mA	Max 120mA
Power Source:	24 VDC	CR4410STy	/picalmA	MaxmA
Frequency Range:	50Hz - 400Hz	CR4420STy	/picalmA	MaxmA
Output Load: 4-20 mADC - 0 to 300 Ω		Torque Specs.: 3.0 inch lbs. (0.4Nm)		
	0-5 VDC - 2K Ω or Greater	Weight:0.5 II	bs.	



NOTE: The building installation must have a switch or circuit-breaker that is in close proximity and within easy reach of the operator. The switch or circuit breaker shall be marked as the disconnecting device for the equipment.



OUTLINE DRAWING

3500 Scarlet Oak Blvd. St. Louis MO USA 63122 V: 636-343-8518 F: 636-343-5119

CONNECTION DIAGRAM

Web: http://www.crmagnetics.com E-mail: sales@crmagnetics.com 39