



# Certificate of Compliance

**Certificate:** 2602911 **Master Contract:** 181564  
**Project:** 2602911 **Date Issued:** March 27, 2013  
**Issued to:** **Delta Electronics (Thailand) Public**  
**Co., Ltd.**  
**909 Soi 9 Moo 4 Pattana 1 Rd**  
**Bangpoo Industrial Estate E.P.Z.**  
**Tambol Phraksa**  
**Amphur Muang, Samut Prakan 10280**  
**Thailand**  
**Attention: Surasit Kansaard**

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*John Yam*

Issued by: John Yam

## **PRODUCTS**

**CLASS 5318 01** - POWER SUPPLIES - For Hazardous Locations

**CLASS 5318 81** - POWER SUPPLIES - For Hazardous Locations - Certified to U.S. Standards

**Class I, Division 2, Groups A, B, C and D**

CliQ Series – DIN rail Component Type Switching Mode Power Supply for built in use

Models: (See following table)

Rating: (See following table)

Model	Input	Output	Ambient range (Derating: output power in %)	Temp. Code
DRP012V015W1AX				T4



Certificate: 2602911

Master Contract: 181564

Project: 2602911

Date Issued: March 27, 2013

	100-240V; 50-60Hz; 0,4A	12Vdc; 1,25A (Adj. 11-14V, 15W max.)	-20 – 80°C (-2,5% / °C above 50°C) (-4,0% / °C above 70°C)	
<b>DRP012V030W1AX</b>	100-240V; 50-60Hz; 0,8A	12Vdc; 2,5A (Adj. 11-14V, 30W max.)	-20 – 80°C (-2,5% / °C above 50°C) (-4,0% / °C above 70°C)	T4
<b>DRP012V060W1AX</b>	100-240V; 50-60Hz; 1,5A	12Vdc; 5,0A (Adj. 11-14V, 60W max.)	-20 – 80°C (-2,5% / °C above 50°C) (-4,0% / °C above 70°C)	T4
<b>DRP012V100W1AX</b>	100-240V; 50-60Hz; 2,5A	12Vdc; 8,33A (Adj. 11-14V, 100W max.)	-20 – 80°C (-2,5% / °C above 50°C, vertical position) (-2,5% / °C above 50°C, horizontal position) (-4,0% / °C above 70°C, horizontal position)	T4
<b>DRP024V060W1BX</b>	100-240V; 50-60Hz; 1,5A	24Vdc; 2,5A (Adj. 24-28V, 60W max.)	-25 – 80°C (-2,5% / °C above 50°C)	T4
<b>DRP024V120W1BX</b>	100-240V; 50-60Hz; 2,5A	24Vdc; 5,0A (Adj. 24-28V, 120W max.)	-25 – 80°C (-2,5% / °C above 50°C)	T4
<b>DRP024V240W1BX</b>	100-240V; 50-60Hz; 3,5A	24Vdc; 10,0A (Adj. 24-28V, 240W max.)	-25 – 80°C (-2,5% / °C above 50°C, vertical position) (-2,5% / °C above 40°C, horizontal position)	T4
<b>DRP024V480W1BX</b>	100-240V; 50-60Hz; 6,0A	24Vdc; 20,0A (Adj. 24-28V, 480W max.)	-25 – 75°C (-2,5% / °C above 50°C, vertical position) (-5% / °C above 70°C, vertical position)	T4
<b>DRP048V060W1BX</b>	100-240V; 50-60Hz; 1,5A	48Vdc; 1,25A (Adj. 48-56V, 60W max.)	-25 – 80°C (-2,5% / °C above 50°C)	T4
<b>DRP048V120W1BX</b>	100-240V; 50-60Hz; 2,5A	48Vdc; 2,5A (Adj. 48-56V, 120W max.)	-25 – 80°C (-2,5% / °C above 50°C, vertical position) (-2,5% / °C above 50°C, horizontal position) (-3,5% / °C above 70°C, horizontal position)	T4



**Certificate:** 2602911

**Master Contract:** 181564

**Project:** 2602911

**Date Issued:** March 27, 2013

<b>DRP048V240W1BX</b>	100-240V; 50-60Hz; 3,5A	48Vdc; 5A (Adj. 48-56V, 240W max.)	-25 – 80°C (-2,5% / °C above 50°C, vertical position) (-2,5% / °C above 40°C, horizontal position)	T4
<b>DRP048V480W1BX</b>	100-240V; 50-60Hz; 6,0A	48Vdc; 10A (Adj. 48-56V, 480W max.)	-25 -75°C (-2,5% / °C above 50°C, vertical position) (-5% / °C above 70°C, vertical position)	T4
<b>DRR-20X</b> (redundancy module)	22-60Vdc; 0-20A	Input -0,65Vdc; 20A	-40 – 80°C (-2,5% / °C above 50°C)	T4
<b>DRR-40X</b> (redundancy module)	22-60Vdc; 0-40A	Input -0,65Vdc; 40A	-40 – 80°C (-2,5% / °C above 50°C)	T4
<b>DRB-24V020ABX</b> (buffer module)	24Vdc; 20A	24Vdc; 20A (250ms), 1A (5s)	-25 – 75°C (-5% / °C above 70°C)	T4
<b>DRP024V060W1NX</b> (NEC Class 2)	100-240V; 50-60Hz; 1,5A	24Vdc; 2,5A (Adj. 24-28V, 60W max.)	-25 – 80°C (-2,5% / °C above 50°C) (-4% / °C above 70°C)	T4

- Suffix "X" may be any letter or digit, no safety relevant meaning.
- All models have a derating graph for ambient temperatures per the table above.

Notes:

- The unit was evaluated as component where the suitability of the combination must be determined with the end use product.
- The unit shall be provided with an appropriate disconnect device in the end use installation
- The wiring terminals are intended for Field wiring.
- The equipment must be built inside a suitable enclosure
- Each Apparatus is marked with the respective temperature range on the type label; the output rating must be derated according to the manufacturer's instructions.

**APPLICABLE REQUIREMENTS**

CSA C22.2 No. 60950-1-07 2nd Edition	-	Information Technology Equipment – Safety – Part 1: General Requirements
CSA-C22.2 No. 107.1-01	-	General Use Power Supplies - Industrial Products
CSA C22.2 No. 213-M1987	-	Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
UL 60950-1 2nd Edition	-	Information Technology Equipment – Safety – Part 1: General Requirements



**Certificate:** 2602911

**Master Contract:** 181564

**Project:** 2602911

**Date Issued:** March 27, 2013

---

ANSI/ISA-12.12.01-2011	-	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
------------------------	---	---



## *Supplement to Certificate of Compliance*

**Certificate:** 2602911

**Master Contract:** 181564

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
2602911	Mar 27, 2013	New Certification of Power Supply CliQ Series (16 Models) for use in Class I, Div. 2, Groups A,B,C & D, based on ATEX/IECEX Test Reports.