

New

Electro-Pneumatic Regulator Electronic Vacuum Regulator



- Stepless control of air pressure proportional to an electrical signal
- Added Fieldbus compliant specifications to Series ITV1000/2000/3000!



Reduced wiring

Applicable Fieldbus protocols



Built-in communication board, so no converter needed.

- Added RS-232C specification to serial communications!

Compact/lightweight (Integrated communication parts)

Weight: **350 g** ^{Note 1)} (ITV1000)

Power consumption: **4 w** ^{Note 1)} or less

Note 1) Value for communications type. (PROFIBUS DP)



Note 2) ITV1000. Dimensions in parentheses () are for the CC-Link or PROFIBUS DP.

Electro-Pneumatic Regulators

Series ITV0000

Maximum flow rate

6 l/min (ANR)

Set pressure: 0.6 MPa

Supply pressure: 1.0 MPa



Series ITV1000

Maximum flow rate

200 l/min (ANR)

Set pressure: 0.6 MPa

Supply pressure: 1.0 MPa

Grease-free specification (wetted parts)



Series ITV2000

Maximum flow rate

1500 l/min (ANR)

Set pressure: 0.6 MPa

Supply pressure: 1.0 MPa



Series ITV3000

Maximum flow rate

4000 l/min (ANR)

Set pressure: 0.6 MPa

Supply pressure: 1.0 MPa



Electronic Vacuum Regulators

Series ITV009 □



Series ITV209 □



Series **ITV**



CAT.ES60-15F

Compact Electro-Pneumatic Regulator Series *ITV0000* Compact Vacuum Regulator Series *ITV009*

Compact **15 mm**

With a simplified high-density circuit board design, an extremely compact size has been achieved.



Lightweight **100 g**

Realizes space-saving and reduction of weight for manifold use.

Stations can easily be increased or decreased due to DIN rail mount design.



Cable connectors

Straight type and right angle type are available.



Built-in One-touch fittings

With error indication LED

Brackets

Flat and L-brackets are available.



Flat bracket



L-bracket

Equivalent to IP65

Linearity: Within $\pm 1\%$ (F.S.)


Hysteresis: Within 0.5% (F.S.)

Repeatability: Within $\pm 0.5\%$ (F.S.)

High-speed response time: 0.1 sec (Without load)

High stability

Sensitivity within 0.2% (F.S.)



Electro-Pneumatic Regulator Series *ITV1000/2000/3000* Electronic Vacuum Regulator Series *ITV209*



New

Added Fieldbus compliant specifications to Series *ITV1000/2000/3000*!

Reduced wiring

Applicable Fieldbus protocols



New

Added RS-232C specification to serial communications!



ITV1000



ITV2000



ITV3000



ITV2090

Sensitivity: Within 0.2% (F.S.)

Linearity: Within $\pm 1\%$ (F.S.)



Hysteresis: Within 0.5% (F.S.)

IP65

Cable connections in 2 directions



Straight type

Right angle type



Grease-free specification (Series ITV1000)

Application examples



Electro-Pneumatic Regulator

Electronic Vacuum Regulator

Series ITV

- Stepless control of air pressure proportional to an electrical signal.

Series		Model	Set pressure range	Input signal	Port size	Page
Electro-Pneumatic Regulator	Series ITV0000		ITV001□	0.001 to 0.1 MPa	Current type: 4 to 20 mA DC Current type: 0 to 20 mA DC Voltage type: 0 to 5 VDC Voltage type: 0 to 10 VDC Built-in One-touch fittings Metric size: ø4 Inch size: ø5/32	1
			ITV003□	0.001 to 0.5 MPa		
			ITV005□	0.001 to 0.9 MPa		
	Series ITV1000		ITV101□	0.005 to 0.1 MPa	1/8, 1/4	9
			ITV103□	0.005 to 0.5 MPa		
			ITV105□	0.005 to 0.9 MPa		
	Series ITV2000		ITV201□	0.005 to 0.1 MPa	1/4, 3/8	9
			ITV203□	0.005 to 0.5 MPa		
			ITV205□	0.005 to 0.9 MPa		
	Series ITV3000		ITV301□	0.005 to 0.1 MPa	1/4, 3/8, 1/2	9
			ITV303□	0.005 to 0.5 MPa		
			ITV305□	0.005 to 0.9 MPa		
Electronic Vacuum Regulator	Series ITV009□		ITV009□	-1 to -100 kPa	Built-in One-touch fittings Metric size: ø4 Inch size: ø5/32	27
	Series ITV209□		ITV209□	-1.3 to -80 kPa	Current type: 4 to 20 mA DC (Sink type) Current type: 0 to 20 mA DC (Sink type) Voltage type: 0 to 5 VDC Voltage type: 0 to 10 VDC Preset input New CC-Link compatible New DeviceNet™ compatible New PROFIBUS DP compatible New RS-232C communication	34

Compact Electro-Pneumatic Regulator Series *ITV0000*



RoHS

How to Order

For single unit and single unit for manifold

ITV00 **1** **0** - **3** **□** **□** **□** **N** - **□**

Pressure range

1	0.1 MPa
3	0.5 MPa
5	0.9 MPa

Power supply voltage

0	24 VDC $\pm 10\%$
1	12 to 15 VDC

Input signal

0	Current type 4 to 20 mA DC
1	Current type 0 to 20 mA DC
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC

Built-in One-touch fittings type

For single unit

Symbol	SUP ¹	OUT ²	EXH ³
Nil	Metric size (Light gray)	$\phi 4$	
U	Inch size (Orange)	$\phi 5/32$ "	

For manifold

Symbol	SUP ¹	OUT ²	EXH ³
Nil	Metric size (Light gray)	$\phi 6$	$\phi 4$ $\phi 6$
U	Inch size (Orange)	$\phi 1/4$ "	$\phi 5/32$ " $\phi 1/4$ "

Cable connector (Option)



N	Without cable connector
S	Straight type 3 m
L	Right angle type 2 m

CE compliant

Nil	—
Q	CE compliant

* For detailed information on models for CE, refer to SMC's website.

Bracket/Option for single unit only

Nil	Without bracket
B	Flat Bracket 
C	L-bracket 

Base type

Nil	For single unit
M	For manifolds

Manifold

IITV00 - **02** **□** - **n**

Stations

02	2 stations
03	3 stations
⋮	⋮
10	10 stations

Option

If a DIN rail longer than the specified stations is required, specify the applicable stations in two digits.
(Maximum 10 stations)
Example) IITV00-05-07

One-touch fitting size for supply/exhaust parts (End plate)

Nil	$\phi 6$ (Light gray)
U	$\phi 1/4$ " (Orange)

Note) A DIN rail with the length specified by the number of stations is attached to the manifold. For dimensions of the DIN rail, refer to the external dimensions.

How to Order Manifold Assembly (Example)

Indicate the part numbers of electro-pneumatic regulators and options to be mounted below the manifold part number.

Example)

Due to the common supply/exhaust feature, note that different pressure range combinations are not available.

IITV00-03.....1 set (Manifold part no.)


*ITV0030-3MS.....2 sets (Electro-pneumatic regulator part no. (1, 2 stations))

*ITV0030-3ML.....1 set (Electro-pneumatic regulator part no. (3 stations))


Indicate part numbers in order starting from the first station on the D side.

Note) Combination with having different pressure ranges is not available due to common supply/exhaust features.

The asterisk (*) specifies mounting. Add an asterisk (*) at the beginning of electro-pneumatic regulator part numbers to be mounted.



Specifications



Model		ITV001□	ITV003□	ITV005□
Minimum supply pressure		Set pressure +0.1 MPa		
Maximum supply pressure		0.2 MPa	1.0 MPa	
Set pressure range		0.001 to 0.1 MPa	0.001 to 0.5 MPa	0.001 to 0.9 MPa
Maximum flow rate		3.5 ℓ/min(ANR) (Supply pressure: 0.2 MPa)	6 ℓ/min(ANR) (Supply pressure: 0.6 MPa)	6 ℓ/min(ANR) (Supply pressure: 0.6 MPa)
Power supply	Voltage	24 VDC ±10%, 12 to 15 VDC		
	Current consumption	Power supply voltage 24 VDC type: 0.12 A or less Power supply voltage 12 to 15 VDC type: 0.18 A or less		
Input signal	Voltage type	0 to 5 VDC, 0 to 10 VDC		
	Current type	4 to 20 mA DC, 0 to 20 mA DC		
Input impedance	Voltage type	Approximately 10 kΩ		
	Current type	Approximately 250 Ω		
Output signal	Analog output	1 to 5 VDC (Load impedance: 1 kΩ or more) Output accuracy: Within ±6% (Full span)		
Linearity		Within ±1% (Full span)		
Hysteresis		Within 0.5% (Full span)		
Repeatability		Within ±0.5% (Full span)		
Sensitivity		Within 0.2% (Full span)		
Temperature characteristics		Within ±0.12% (Full span)/°C		
Operating temperature range		0 to 50°C (No condensation)		
Enclosure		Equivalent to IP65 *		
Connection type		Built-in One-touch fittings		
Connection size	For single unit	Metric size	①, ②, ③: ø4	
		Inch size	①, ②, ③: ø5/32"	
	Manifold	Metric size	①, ③: ø6, ②: ø4	
		Inch size	①, ③: ø1/4", ②: ø5/32"	
Weight ^{Note 1)}		100 g or less (without option)		

Note 1) Indicates the weight of a single unit.

For IITV00-n

Total weight (g) ≤ Stations (n) x 100 + 130 (Weight of end block A, B assembly) + Weight (g) of DIN rail

Note 2) When there is a downstream flow consumption, pressure may become unstable depending on piping conditions.

Note 3) When the power is turned on, a noise may be generated. This noise is normal and does not indicate a fault.

* When using under the conditions equivalent to IP65, connect the fitting or tube to the breathing hole prior to use. (For details, refer to "Specific Product Precautions 1" on back page 2)

Accessories (Option)

Bracket

Flat bracket assembly (includes 2 mounting screws)
P39800022



L-bracket assembly (includes 2 mounting screws)
P39800023



Tightening torque when assembling is 0.3 N·m.

Cable connector

Straight type
M8-4DSX3MG4




Right angle type
ELWIKA-KV4408 PVC025 2M




Working Principle

When the input signal rises, the air supply solenoid valve ① turns ON. Due to this, part of the supply pressure passes through the air supply solenoid valve ① and changes to output pressure. This output pressure feeds back to the control circuit ④ via the pressure sensor ③. Here, pressure corrections continue until output pressure becomes proportional to the input signal, enabling output pressure that is proportional to the input signal.

Diagram of working principle




Block diagram




Series ITV001

Linearity, Hyteresis




Repeatability

With 50% of signal input




Pressure Characteristics

Set pressure: 0.05 MPa




Flow Characteristics

Supply pressure: 0.2 MPa




Series ITV003

Linearity, Hyteresis




Repeatability

With 50% of signal input




Pressure Characteristics

Set pressure: 0.25 MPa




Flow Characteristics

Supply pressure: 0.6 MPa




Series **ITV005**

Linearity, Hyteresis




Repeatability

With 50% of signal input




Pressure Characteristics

Set pressure: 0.45 MPa




Flow Characteristics

Supply pressure: 1.0 MPa




Dimensions

For Single Unit



Dimensions

Single unit for manifold




Note) When using under the conditions equivalent to IP65, connect the fittings or tube to the breathing hole prior to use. (For details, refer to "Specific Product Precautions 1" on back page 2)

Note) For dimensions of the cable connector, refer to single unit on page 6.

Dimensions




Manifold



Port Location

No.	1	2	3
1 ITV003 5	SUP	OUT	EXH

Note) Stations are counted starting from the D side.



Note) For dimensions of the cable connector, refer to single unit on page 6.

Note) When using under the conditions equivalent to IP65, connect the fittings or tubing to the breathing hole prior to use. (For details, refer to "Specific Product Precautions 1" on back page 2).

	(mm)									
Manifold stations n	2	3	4	5	6	7	8	9	10	
L1	60	75	90	105	120	135	150	165	180	
L2	110.5	123	148	160.5	173	185.5	198	223	235.5	
Weight of DIN rail (g)	20	22	27	29	31	34	36	41	43	

Electro-Pneumatic Regulator

Series *ITV1000/2000/3000*



How to Order

ITV 3 0 1 0 - 0 1 [] 2 [] S [] - [] - []

Model

1	1000 type
2	2000 type
3	3000 type

Pressure range

1	0.1 MPa
3	0.5 MPa
5	0.9 MPa

Power supply voltage

0	24 VDC
1	12 to 15 VDC

Note) Communication models (CC, DN, PR, RC) are available only for 24 VDC.

Input signal/

Communication model

0	Current type 4 to 20 mA DC (Sink type)
1	Current type 0 to 20 mA DC (Sink type)
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC
40	Preset input
CC	CC-Link
DN	DeviceNet™
PR	PROFIBUS DP
RC	RS-232C communication

Monitor output

1	Analog output 1 to 5 VDC
2	Switch output/NPN output
3	Switch output/PNP output
4	Analog output 4 to 20 mA DC (Sink type)
Nil	None

Thread type

Nil	Rc
N	NPT
T	NPTF
F	G

CE compliant

Nil	—
Q	CE compliant

Note) Refer to pages 11, 25, and 26 for information on CE compliant made to order products.

* For detailed information on models for CE, refer to SMC's website.

Made to Order Specifications

Refer to pages 11, 25, and 26 for details.

Pressure display unit

Nil	MPa
2 ^{Note)}	kgf/cm ²
3	bar
4 ^{Note)}	psi
5	kPa

Note) Under Japan's new Measurement Act, this is only for overseas sales (SI units are to be used inside Japan). For the communication models, CC, DN, PR and RC, only "Nil" is available as it does not have a pressure display.

Cable connector type

S	Straight type 3 m
L	Right angle type 3 m
N	Without cable connector

Note) Order communication cable (other than RS-232C) separately. See below.

Bracket

Nil	Without bracket
B	Flat bracket
C	L-bracket

Port size


1	1/8 (1000 type)
2	1/4 (1000, 2000, 3000 type)
3	3/8 (2000, 3000 type)
4	1/2 (3000 type)

For communication cables, use the parts listed below (refer to the catalog [M8/M12 Connector] CAT.ES100-73 for details) or order the product certified for the respective protocol (with M12 connector) separately.

Application	Communication cable part number	Remarks
CC-Link compatibility	PCA-1567720 (Socket type)	Dedicated Bus adapter supplied with the product.
	PCA-1567717 (Plug type)	
DeviceNet™ compatibility	PCA-1557633 (Socket type)	T-branch connector not supplied.
	PCA-1557646 (Plug type)	
PROFIBUS DP compatibility	PCA-1557688 (Socket type)	T-branch connector not supplied.
	PCA-1557691 (Plug type)	



JIS Symbol



Rated pressure




Figure 1. Input/output characteristics chart

Communication Specifications (CC, DN, PR, RC)

Standard Specifications

Model		ITV101□ ^{Note 10)}		ITV103□ ^{Note 10)}		ITV105□ ^{Note 10)}	
		ITV201□		ITV203□		ITV205□	
		ITV301□		ITV303□		ITV305□	
Minimum supply pressure		Set pressure +0.1 MPa					
Maximum supply pressure		0.2 MPa		1.0 MPa			
Set pressure range ^{Note 1)}		0.005 to 0.1 MPa		0.005 to 0.5 MPa		0.005 to 0.9 MPa	
Power supply	Voltage	24 VDC ± 10%, 12 to 15 VDC					
	Current consumption	Power supply voltage 24 VDC type: 0.12 A or less Power supply voltage 12 to 15 VDC type: 0.18 A or less					
Input signal	Current type ^{Note 2)}	4 to 20 mA DC, 0 to 20 mA DC (Sink type)					
	Voltage type	0 to 5 VDC, 0 to 10 VDC					
	Preset input	4 points (Negative common)					
Input impedance	Current type	250 Ω or less ^{Note 6)}					
	Voltage type	Approx. 6.5 kΩ					
	Preset input	Power supply voltage 24 VDC type: Approx. 4.7 kΩ Power supply voltage 12 VDC type: Approx. 2.0 kΩ					
^{Note 3)} Output signal (monitor output)	Analog output	1 to 5 VDC (Load impedance: 1 kΩ or more) 4 to 20 mA DC (Sink type) (Load impedance: 250 Ω or less) Output accuracy within ±6% (Full span)					
	Switch output	NPN open collector output: Max. 30 V, 80 mA PNP open collector output: Max. 80 mA					
Linearity		Within ±1% (Full span)					
Hysteresis		Within 0.5% (Full span)					
Repeatability		Within ±0.5% (Full span)					
Sensitivity		Within 0.2% (Full span)					
Temperature characteristics		Within ±0.12% (Full span)/°C					
Output pressure display ^{Note 4)}	Accuracy	±2%F.S. ± 1 digit					
	Minimum unit	MPa: 0.001, kgf/cm ² : 0.01, bar: 0.01, psi: 0.1 ^{Note 5)} , kPa: 1					
Ambient and fluid temperature		0 to 50°C (No condensation)					
Enclosure		IP65					
Weight ^{Note 9)}	ITV10□□	Approx. 250 g (without options)					
	ITV20□□	Approx. 350 g (without options)					
	ITV30□□	Approx. 645 g (without options)					

Note 1) Please refer to Figure 1 for the relationship between set pressure and input. Because the maximum set pressure differs for each pressure display, refer to back page 6.

Note 2) 2-wire type 4 to 20 mA DC is not available. Power supply voltage (24 VDC or 12 to 15 VDC) is required.

Note 3) Select either analog output or switch output.

Further, when switch output is selected, select either NPN output or PNP output.

Note 4) Adjustment of numerical values such as the zero/span adjustment or preset input type is set based on the minimum units for output pressure display (e.g. 0.01 to 0.50 MPa). Note that the unit cannot be changed.

Note 5) The minimum unit for 0.9 MPa (130 psi) types is 1 psi.

Note 6) Value for the state with no over current circuit included. If an allowance is provided for an over current circuit, the input impedance varies depending on the input current. This is 350 Ω or less for an input current of 20 mA DC.

Note 7) The above characteristics are confined to the static state. When air is consumed on the output side, the pressure may fluctuate.

Note 8) For communication models, the maximum current consumption is 0.16 A or less.

Note 9) For communication models, add roughly 80 g to the weight (100 g for the PROFIBUS DP).

Note 10) The ITV1000 series is a Grease-free specification (Wetted parts).

Model	ITV□□□0-CC	ITV□□□0-DN	ITV□□□0-PR	ITV□□□0-RC
Protocol	CC-Link	DeviceNet™	PROFIBUS DP	RS-232C
Version ^{Note 1)}	Ver 1.10	Release2.0	DP-V0	—
Communication speed	156 k/625 k 2.5 M/5 M/10 M bps	125 k/250 k/500 k bps	9.6 k/19.2 k/45.45 k 93.75 k/187.5 k/500 k 1.5 M/3 M/6 M/12 M bps	9.6 kbps
Configuration file ^{Note 2)}	—	EDS	GSD	—
I/O occupation area (input/output data)	4 word/4 word, 32 bit/32 bit (per station, remote device station)	16 bit/16 bit	16 bit/16 bit	—
Communication data resolution	12 bit (4096 resolution)	12 bit (4096 resolution)	12 bit (4096 resolution)	10 bit (1024 resolution)
Fail safe	HOLD ^{Note 3)} /CLEAR (Switch setting)	HOLD/CLEAR (Switch setting)	CLEAR	HOLD
Electric insulation ^{Note 4)}	No	No	Yes	No
Terminating resistor	—	—	Built into the product (Switch setting)	—


Note 1) Note that version information is subject to change.

Note 2) Configuration files can be downloaded from the SMC's website: <http://www.smcworld.com>

Note 3) The output HOLD value when a CC-Link communications error occurs can be set based on the bit area data.

Note 4) The insulation between the electrical signal of the communication system and ITV power supply.

Series ITV1000/2000/3000



Combinations

○ Standard specifications ○ Combination possible ■ Combination not possible

* ITV10□□ models are not applicable.

Specifications		Symbol	Applicable model	
			ITV20□□	ITV30□□
Standard specifications	Set pressure max. 0.1 MPa	1	○	○
	Set pressure max. 0.5 MPa	3	○	○
	Set pressure max. 0.9 MPa	5	○	○
	Connection Rc 1/4	02	○	○
	Connection Rc 3/8	03	○	○
	Connection Rc 1/2	04	■	○
Accessories	Bracket	B	○	○
	Bracket	C	○	○
Optional specifications	Connection NPT1/4	N02	○	○
	Connection NPT3/8	N03	○	○
	Connection NPT1/2	N04	■	○
	Connection G 1/4	F02	○	○
	Connection G 3/8	F03	○	○
	Connection G 1/2	F04	■	○

Modular Products and Accessory Combinations

* ITV10□□ models are not applicable.

Applicable products and accessories	Applicable model	
	ITV20□□	ITV30□□
① Air filter	AF30	AF40
② Mist separator	AFM30	AFM40
③ L-bracket	B310L	B410L
④ Spacer	Y30	Y40
⑤ Spacer with L-bracket (③ + ④)	Y30L	Y40L
⑥ Spacer with T-bracket	—	Y40T

Accessories (Option)/Part No.



Made to Order

(Refer to pages 25 and 26 for details.)

Symbol	CE-compliant	Specifications
X81	Not compliant	16 points preset input type
X156	Compliant	
X93	Not compliant	Digital input type
X157	Compliant	
X102	Not compliant	Reverse type
X321	Compliant	
X224	Not compliant	High pressure type (SUP 1.2 MPa, OUT 1.0 MPa)
X322	Compliant	
X25	Not compliant	Set pressure range 1 to 100 kPa (Except Series ITV3000)
X323	Compliant	
X88	Not compliant	High speed response type (Except Series ITV3000)
X154	Compliant	
X26	Not compliant	For manifold mounting (Except Series ITV3000)
X153	Compliant	


Note 1) Manifolds are compatible with 2 to 8 stations. Consult with SMC for 9 stations or more.

Note 2) Products without symbols are also compatible. Consult with SMC separately.


Description		Part No.		
		ITV10□□	ITV20□□	ITV30□□
Flat bracket assembly (including mounting screws)		KT-ITV-F1	KT-ITV-F2	
L-bracket assembly (including mounting screws)		KT-ITV-L1	KT-ITV-L2	
Power cable connector	Straight type 3 m	P398020-500-3 (P398020-504-3 for DeviceNet™)		
	Right angle type 3 m	P398020-501-3 (P398020-505-3 for DeviceNet™)		
Bus adapter (CC-Link model only)		EX9-ACY00-MJ		

Dimensions

Flat bracket



L-bracket




Working Principles

When the input signal rises, the air supply solenoid valve ① turns ON, and the exhaust solenoid valve ② turns OFF. Therefore, supply pressure passes through the air supply solenoid valve ① and is applied to the pilot chamber ③. The pressure in the pilot chamber ③ increases and operates on the upper surface of the diaphragm ④.


As a result, the air supply valve ⑤ linked to the diaphragm ④ opens, and a portion of the supply pressure becomes output pressure.

This output pressure feeds back to the control circuit ⑧ via the pressure sensor ⑦. Here, a correct operation functions until the output pressure is proportional to the input signal, making it possible to always obtain output pressure proportional to the input signal.

Working Principle Diagram




Block diagram




Series ITV1000/2000/3000

Series ITV101 ☐


Linearity




Hysteresis




Repeatability




Pressure characteristics Set pressure: 0.05 MPa



Flow characteristics Supply pressure: 0.2 MPa




Relief flow characteristics Supply pressure: 0.2 MPa




Series ITV201 ☐


Linearity




Hysteresis




Repeatability




Pressure characteristics Set pressure: 0.05 MPa



Flow characteristics Supply pressure: 0.2 MPa




Relief flow characteristics Supply pressure: 0.2 MPa




Series ITV301 ☐


Linearity




Hysteresis




Repeatability




Pressure characteristics Set pressure: 0.05 MPa



Flow characteristics Supply pressure: 0.2 MPa




Relief flow characteristics Supply pressure: 0.2 MPa




Series ITV1000/2000/3000

Series ITV103


Linearity




Hysteresis




Repeatability




Pressure characteristics Set pressure: 0.2 MPa



Flow characteristics Supply pressure: 0.7 MPa




Relief flow characteristics Supply pressure: 0.7 MPa




Series ITV203


Linearity




Hysteresis




Repeatability




Pressure characteristics Set pressure: 0.2 MPa



Flow characteristics Supply pressure: 0.7 MPa




Relief flow characteristics Supply pressure: 0.7 MPa




Series ITV303 ☐


Linearity




Hysteresis




Repeatability




Pressure characteristics Set pressure: 0.2 MPa



Flow characteristics Supply pressure: 0.7 MPa




Relief flow characteristics Supply pressure: 0.7 MPa




Series ITV1000/2000/3000

Series ITV105


Linearity




Hysteresis




Repeatability




Pressure characteristics Set pressure: 0.4 MPa



Flow characteristics Supply pressure: 1.0 MPa




Relief flow characteristics Supply pressure: 1.0 MPa




Series ITV205


Linearity




Hysteresis




Repeatability




Pressure characteristics Set pressure: 0.4 MPa



Flow characteristics Supply pressure: 1.0 MPa




Relief flow characteristics Supply pressure: 1.0 MPa




Series ITV305


Linearity




Hysteresis




Repeatability




Pressure characteristics Set pressure: 0.4 MPa



Flow characteristics Supply pressure: 1.0 MPa



Relief flow characteristics Supply pressure: 1.0 MPa




Series ITV1000/2000/3000

Dimensions


ITV10□□

Flat bracket

Note) Do not attempt to rotate, as the cable connector does not turn.




L-bracket




Dimensions (CC-Link, DeviceNet™, PROFIBUS DP and RS-232C)

CC-Link/ITV10□0-CC




* Dimensions not shown are as on page 19.

DeviceNet™/ITV10□0-DN




* Dimensions not shown are as on page 19.

PROFIBUS DP/ITV10□0-PR



* Dimensions not shown are as on page 19.


RS-232C/ITV10□0-RC



* Dimensions not shown are as on page 19.

With power cable connector * ITV10□0-CC, DN, PR, RC common dimensions

Note) Order communication cable (other than RS-232C) separately. (Refer to page 9.)



Note) Do not attempt to rotate, as the cable connector does not turn.


Series ITV1000/2000/3000

Dimensions


ITV20□□

Flat bracket

Note) Do not attempt to rotate, as the cable connector does not turn.




L-bracket




Dimensions (CC-Link, DeviceNet™, PROFIBUS DP and RS-232C)

CC-Link/ITV20□0-CC




* Dimensions not shown are as on page 21.

DeviceNet™/ITV20□0-DN




* Dimensions not shown are as on page 21.

PROFIBUS DP/ITV20□0-PR



* Dimensions not shown are as on page 21.


RS-232C/ITV20□0-RC



* Dimensions not shown are as on page 21.

With power cable connector * ITV20□0-CC, DN, PR, RC common dimensions

Note) Order communication cable (other than RS-232C) separately. (Refer to page 9.)



Note) Do not attempt to rotate, as the cable connector does not turn.


Series ITV1000/2000/3000

Dimensions

ITV30□□




Flat bracket

(Note) Do not attempt to rotate, as the cable connector does not turn.




Right angle type (4-wire)
Cable connector 3 m


Straight type (4-wire)
Cable connector 3 m



L-bracket




L-bracket assembly
KT-ITV-L2
(Option)




Dimensions (CC-Link, DeviceNet™, PROFIBUS DP and RS-232C)

CC-Link/ITV30□-CC




* Dimensions not shown are as on page 23.

DeviceNet™/ITV30□-DN




* Dimensions not shown are as on page 23.

PROFIBUS DP/ITV30□-PR



* Dimensions not shown are as on page 23.


RS-232C/ITV30□-RC



* Dimensions not shown are as on page 23.

With power cable connector

* ITV30□-
CC
DN
PR
RC
common dimensions



Note) Do not attempt to rotate, as the cable connector does not turn.

Series ITV1000/2000/3000

Made to Order Specifications 1

Please contact SMC for detailed dimensions, specifications and lead times.



1 16 Points Preset Input Type

Able to control 16-point-pressure by 4 bit switching input

ITV10 ☐ 0 - 4 $\frac{2}{3}$ ☐ ☐ ☐ ☐ ☐ - X81

ITV20 ☐ 0 - 4 $\frac{2}{3}$ ☐ ☐ ☐ ☐ ☐ - X81

ITV30 ☐ 0 - 4 $\frac{2}{3}$ ☐ ☐ ☐ ☐ ☐ - X81

Note 1) ☐ in part number is the same model no. for the standard products.

Note 2) Monitor output is switch output type only. This cannot be selected for types without a monitor output or with analog output.

Note 3) Values can be adjusted starting from the minimum output pressure display units.

MPa	kgf/cm ²	bar	psi	kPa
0.01	0.01	0.01	0.1	1

* 130 psi type: 1 psi

16 points preset type

Symbol	CE-compliant
X81	Not compliant
X156	Compliant

2 Digital Input Type

Parallel input type with digital 10 bit.

ITV10 ☐ 0 - 4 0 ☐ ☐ ☐ ☐ S N ☐ - X93

ITV20 ☐ 0 - 4 0 ☐ ☐ ☐ ☐ S N ☐ - X93

ITV30 ☐ 0 - 4 0 ☐ ☐ ☐ ☐ S N ☐ - X93

Digital input type

Symbol	CE-compliant
X93	Not compliant
X157	Compliant

Note 1) ☐ in part number is the same model no. for the standard products.

Note 2) Right angle type cable connectors cannot be selected.


3 Reverse Type

In compliance with input, inverse proportional pressure is displayed.

ITV10 ☐ ☐ - ☐ ☐ ☐ ☐ ☐ ☐ - X102

ITV20 ☐ ☐ - ☐ ☐ ☐ ☐ ☐ ☐ - X102

ITV30 ☐ ☐ - ☐ ☐ ☐ ☐ ☐ ☐ - X102



Reverse type

Symbol	CE-compliant
X102	Not compliant
X321	Compliant

Input/output characteristics chart

Note 1) ☐ in part number is the same model no. for the standard products.

Note 2) Except for preset input type.

4 High Pressure Type (SUP 1.2 MPa, OUT 1.0 MPa)

ITV10 5 ☐ - ☐ ☐ ☐ ☐ ☐ ☐ - X224

ITV20 5 ☐ - ☐ ☐ ☐ ☐ ☐ ☐ - X224

ITV30 5 ☐ - ☐ ☐ ☐ ☐ ☐ ☐ - X224

High pressure type (SUP 1.2 MPa, OUT 1.0 MPa)

Symbol	CE-compliant
X224	Not compliant
X322	Compliant

5 Set Pressure Range 1 to 100 kPa

ITV10 1 ☐ - ☐ ☐ ☐ ☐ ☐ ☐ - X25

ITV20 1 ☐ - ☐ ☐ ☐ ☐ ☐ ☐ - X25

Set pressure range 1 to 100 kPa

Symbol	CE-compliant
X25	Not compliant
X323	Compliant

Series ITV1000/2000/3000

Made to Order Specifications 2

Please contact SMC for detailed dimensions, specifications and lead times.



6 High-Speed Response Time Type

Pressure response with no load is approx. 0.1 sec.

ITV 2010-012S-X88

- Model**

1	1000 type
2	2000 type
- Pressure range**

1	0.1 MPa
3	0.5 MPa
5	0.9 MPa
- Power supply voltage**

0	24 VDC
1	12 to 15 VDC
- Input signal**

0	Current type 4 to 20 mA DC (Sink type)
1	Current type 0 to 20 mA DC (Sink type)
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC
- Monitor output**

1	Analog output 1 to 5 VDC
---	--------------------------
- Thread type**

Nil	Rc
N	NPT
T	NPTF
F	G
- Port size**

1	1/8 (1000 type)
2	1/4 (1000, 2000 type)
3	3/8 (2000 type)
- Pressure display unit**

Nil	MPa
2*	kgf/cm ²
3	bar
4*	psi
5	kPa

* Under Japan's new Measurement Act, this is only for overseas sales (SI units are to be used inside Japan).
- Cable connector type**

S	Straight type 3 m
L	Right angle type 3 m
N	Without cable connector
- Bracket**

Nil	Without bracket
B	Flat bracket
C	L-bracket
- High-speed response time specifications**

Symbol	CE-compliant
X88	Not compliant
X154	Compliant

7 Manifold Specifications (Except Series ITV3000)

2 through 8 station manifold.

How to Order Manifolds

IITV20-02-5

- ITV1000, 2000**
- Stations**

2	2 stations
...	...
8	8 stations
- OUT port size**

02	1/4
03	3/8
- Connection thread type**

Nil	PT
N	NPT
F	PF


IITV20-02-31 set (3 station manifold base part no.)
 *ITV1030-311S-X261 set (Electro-pneumatic regulator part no.) Note 2)
 *P398020-131 set (Blanking plate assembly part no.)
 *ITV2050-212S-X261 set (Electro-pneumatic regulator part no.) Note 2)
 The * is the symbol for mounting. Add the * symbol at the beginning of part numbers for electro-pneumatic regulators, etc. to be mounted on the base.

Note) Refer to the table below for possible mixed combination.

Model	ITV101	ITV103	ITV105	ITV201	ITV203	ITV205
ITV101	●	—	—	●	—	—
ITV103	—	●	—	—	●	—
ITV105	—	—	●	—	—	●
ITV201	●	—	—	●	—	—
ITV203	—	●	—	—	●	—
ITV205	—	—	●	—	—	●

How to Order Manifold Assemblies

Example



- Note 1) Electro-pneumatic regulators are counted starting from station 1 on the left side with the OUT ports in front.
- Note 2) The port size for mounted electro-pneumatic regulators is Rc 1/8 (ITV1000), Rc 1/4 (ITV2000) only.
- Note 3) When there is a large number of stations, use piping with the largest possible inside diameter for the supply side, such as steel piping.
- Note 4) The use of the straight type cable connector is recommended. To mount right angle type, be certain to check that no possible interference occurs.
- Note 5) When mounting a blanking plate and the regulator with different pressure set, please inform SMC of the order of a manifold station beside a purchase order.

Compact Vacuum Regulator

Series *ITV009*



How to Order

For single unit and single unit for manifold

ITV00 9 0 - 3     **N** - 

• **Pressure range**

9	-100 kPa
----------	----------

• **Power supply voltage**

0	24 VDC ±10%
1	12 to 15 VDC

• **Input signal**

0	Current type 4 to 20 mA DC
1	Current type 0 to 20 mA DC
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC

• **Built-in One-touch fittings type**

For single unit

	Symbol	VAC[1]	OUT[2]	ATM[3]
Nil	Metric size (Light gray)		ø4	
U	Inch size (Orange)		ø5/32"	

For manifold

	Symbol	VAC[1]	OUT[2]	ATM[3]
Nil	Metric size (Light gray)	ø6	ø4	ø6
U	Inch size (Orange)	ø1/4"	ø5/32"	ø1/4"

• **CE compliant**



Nil	—
Q	CE compliant

* For detailed information on models for CE, refer to the SMC's website.

• **Cable connector (Option)**

N	Without cable connector
S	Straight type 3 m
L	Right angle type 2 m

• **Bracket/Option for single unit only**

	Without bracket
Nil	Flat Bracket 
B	L-bracket 
C	

• **Base type**

Nil	For single unit
M	For manifolds

Manifold

IITV00 - 02 - n

• **Stations**

02	2 stations
03	3 stations
:	:
10	10 stations

• **Option**

If a DIN rail longer than the specified stations is required, specify the applicable stations in two digits.
(Maximum 10 stations)
Example) IITV00-05-07

Note) A DIN rail with the length specified by the number of stations is attached to the manifold. For dimensions of the DIN rail, refer to the external dimensions.

How to Order Manifold Assembly (Example)

Indicate the part numbers of electro-pneumatic regulators and options to be mounted below the manifold part number.

Example)

Due to the common supply/exhaust feature, note that different pressure range combinations are not available.

IITV00-03.....1 set (Manifold part no.)


*IITV0090-3MS.....2 sets (Vacuum regulator part no. (1, 2 stations))

*IITV0090-3ML.....1 set (Vacuum regulator part no. (3 stations))


Indicate part numbers in order starting from the first station on the D side.

Note) Combination with having different pressure ranges is not available due to common supply/exhaust features.

The asterisk (*) specifies mounting. Add an asterisk (*) at the beginning of electro-pneumatic regulator part numbers to be mounted.



Specifications



Model		ITV009□	
Minimum supply pressure		Set pressure −1 kPa	
Maximum supply pressure		−101 kPa	
Set pressure range		−1 to −100 kPa	
Maximum flow rate		2 ℓ/min (ANR) (Supply pressure: −101 kPa)	
Power supply	Voltage	24 VDC ±10%, 12 to 15 VDC	
	Current consumption	Power supply voltage 24 VDC type: 0.12 A or less Power supply voltage 12 to 15 VDC type: 0.18 A or less	
Input signal	Voltage type	0 to 5 VDC, 0 to 10 VDC	
	Current type	4 to 20 mA DC, 0 to 20 mA DC	
Input impedance	Voltage type	Approximately 10 kΩ	
	Current type	Approximately 250 Ω	
Output signal	Analog output	1 to 5 VDC (Load impedance: 1 kΩ or more) Output accuracy: Within ±6% (Full span)	
Linearity		Within ±1% (Full span)	
Hysteresis		Within 0.5% (Full span)	
Repeatability		Within ±0.5% (Full span)	
Sensitivity		Within 0.2% (Full span)	
Temperature characteristics		Within ±0.12% (Full span)/°C	
Operating temperature range		0 to 50°C (No condensation)	
Enclosure		IP65 equivalent *	
Connection type		Built-in One-touch fittings	
Connection size	For single unit	Metric size	①, ②, ③: ø4
		Inch size	①, ②, ③: ø5/32"
	Manifold	Metric size	①, ③: ø6, ②: ø4
		Inch size	①, ③: ø1/4", ②: ø5/32"
Weight Note 1)		100 g or less (without option)	

Note 1) Indicates the weight of a single unit.

For ITV00-n

Total weight (g) $\leq$ Stations (n) $\times$ 100 + 130 (Weight of end block A, B assembly) + Weight (g) of DIN rail

Note 2) When there is a downstream flow consumption, pressure may become unstable depending on piping conditions.

* When using under the conditions equivalent to IP65, connect the fitting or tube to the breathing hole prior to use. (For details, refer to "Specific Product Precautions 1" on back page 2)

Accessories (Option)

Bracket

Flat bracket assembly (including 2 mounting screws)
P39800022



L-bracket assembly (including 2 mounting screws)
P39800023



Tightening torque when assembling is 0.3 N·m.

Cable connector

Straight type
M8-4DSX3MG4




Right angle type
ELWIKA-KV4408 PVC025 2M




Working Principle

When the input signal rises, the air supply solenoid valve ① turns ON. Due to this, part of the supply pressure passes through the air supply solenoid valve ① and changes to output pressure. This output pressure feeds back to the control circuit ④ via the pressure sensor ③. Here, pressure corrections continue until output pressure becomes proportional to the input signal, enabling output pressure that is proportional to the input signal.

Diagram of working principle




Block diagram




Series ITV009

Linearity, Hyteresis




Repeatability

With 50% of signal input




Pressure Characteristics

Set pressure: -10 kPa




Flow Characteristics




Dimensions

For Single Unit




Dimensions

Single unit for manifold



Dimensions




Manifold



Port Location

No.	1	2	3
ITV009□	VAC	OUT	ATM

Note) Stations are counted starting from the D side.



Note) For dimensions of the cable connector, refer to single unit on page 31.

Note) When using under the conditions equivalent to IP65, connect the fittings or tubing to the breathing hole prior to use. (For details, refer to "Specific Product Precautions 1" on back page 2)

	(mm)									
Manifold stations n	2	3	4	5	6	7	8	9	10	
L1	60	75	90	105	120	135	150	165	180	
L2	110.5	123	148	160.5	173	185.5	198	223	235.5	
Weight of DIN rail (g)	20	22	27	29	31	34	36	41	43	

Electronic Vacuum Regulator

Series *ITV2090/2091*



How to Order

ITV 209 0 - 0 1 2 S 5 -

Pressure range

9	-1.3 to -80 kPa
---	-----------------

Power supply voltage

0	24 VDC
1	12 to 15 VDC

Note) Communication models are available only for 24 V DC.

CE compliant

Nil	—
Q	CE compliant

Pressure display unit

5	kPa
---	-----

Note) For the communication models, CC, DN, PR and RC, only "Nil" is available as it does not have a pressure display.

Input signal/ Communication model

0	Current type 4 to 20 mA DC (Sink type)
1	Current type 0 to 20 mA DC (Sink type)
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC
40	Preset input
CC	CC-Link
DN	DeviceNet™
PR	PROFIBUS DP
RC	RS-232C communication

Monitor output

1	Analog output 1 to 5 VDC
2	Switch output/NPN output
3	Switch output/PNP output
4	Analog output 4 to 20 mA DC (Sink type)
Nil	None

Cable connector type

S	Straight type 3 m
L	Right angle type 3 m
N	Without cable connector

Note) Order communication cable (other than RS-232C) separately. See below.

Bracket

Nil	Without bracket
B	Flat bracket
C	L-bracket

Port size

2	1/4
---	-----

Thread type

Nil	Rc
N	NPT
T	NPTF
F	G

For communications cables, use the parts listed below
(refer to the catalog [M8/M12 Connector] CAT.ES100-73 for details)
or order the product certified for the respective protocol (with M12 connector) separately.


Application	Communication cable part number	Remarks
CC-Link compatibility	PCA-1567720 (Socket type)	Dedicated Bus adapter supplied with the product.
	PCA-1567717 (Plug type)	
DeviceNet™ compatibility	PCA-1557633 (Socket type)	T-branch connector not supplied.
	PCA-1557646 (Plug type)	
PROFIBUS DP compatibility	PCA-1557688 (Socket type)	T-branch connector not supplied.
	PCA-1557691 (Plug type)	

Series ITV2090/2091

Stepless control of vacuum pressure in proportion to an electrical signal



Piping/Wiring Diagram



Standard Specifications

Model		ITV2090	ITV2091
Power supply	Voltage	24 VDC $\pm 10\%$	12 to 15 VDC
	Current consumption	Power supply voltage 24 VDC type: 0.12 A or less ^{Note 6)} Power supply voltage 12 to 15 VDC type: 0.18 A or less	
Minimum supply vacuum pressure ^{Note 1)}		Set pressure -13.3 kPa	
Maximum supply vacuum pressure		-101 kPa	
Set pressure range		-1.3 to -80 kPa	
Input signal	Current type ^{Note 2)}	4 to 20 mA DC, 0 to 20 mA DC	
	Voltage type	0 to 5 VDC, 0 to 10 VDC	
	Preset input	4 points (Negative common)	
Input impedance	Current type	250 Ω or less ^{Note 3)}	
	Voltage type	Approximately 6.5 k Ω	
	Preset input	Power supply voltage 24 VDC type: Approximately 4.7 k Ω Power supply voltage 12 VDC type: Approximately 2.0 k Ω	
Output signal (Monitor output) ^{Note 4)}	Analog output	1 to 5 VDC (Load impedance: 1 k Ω or more) 4 to 20 mA DC (Sink type) (Load impedance: 250 Ω or less) Output accuracy within $\pm 6\%$ (Full span)	
	Switch output	NPN open collector output: Max. 30 V, 80 mA PNP open collector output: Max. 80 mA	
Linearity		Within $\pm 1\%$ (Full span)	
Hysteresis		Within 0.5% (Full span)	
Repeatability		Within $\pm 0.5\%$ (Full span)	
Sensitivity		Within 0.2% (Full span)	
Temperature characteristics		Within $\pm 0.12\%$ (Full span)/ $^{\circ}\text{C}$	
Output pressure display	Accuracy	$\pm 2\%$ F.S. 1 digit	
	Units	kPa ^{Note 5)} Minimum display: 1	
Ambient and fluid temperature		0 to 50 $^{\circ}\text{C}$ (No condensation)	
Enclosure		IP65	
Weight ^{Note 7)}		350 g	



Note 1) The minimum supply vacuum pressure should be 13.3 kPa less than the maximum vacuum pressure setting value.

Note 2) 4 to 20 mA DC is not possible with the 2-wire type. Power supply voltage (24 VDC or 12 to 15 VDC) is required.

Note 3) Value for the state with no over current circuit included. If an allowance is provided for an over current circuit, the input impedance varies depending on the input power supply. This is 350 Ω or less for an input current of 20 mA DC.

Note 4) Either analog output or switch output must be selected. Furthermore, when switch output is selected, either NPN output or PNP output must also be selected. Use caution that the preset input type is not equipped with an output signal function.

Note 5) Please contact SMC regarding indication with other units of pressure.

Note 6) For communication models, the maximum current consumption is 0.16 A or less.

Note 7) For communication models, add roughly 80 g to the weight (100 g for the PROFIBUS DP).

Communication Specifications (CC, DN, PR, RC)


Model	ITV□□□□-CC□□	ITV□□□□-DN□□	ITV□□□□-PR□□	ITV□□□□-RC□□
Protocol	CC-Link	DeviceNet™	PROFIBUS DP	RS-232C
Version ^{Note 1)}	Ver 1.10	Release2.0	DP-V0	—
Communication speed	156 k/625 k 2.5 M/5 M/10 M bps	125 k/250 k/500 k bps	9.6 k/19.2 k/45.45 k 93.75 k/187.5 k/500 k 1.5 M/3 M/6 M/12 M bps	9.6 kbps
Configuration file ^{Note 2)}	—	EDS	GSD	—
I/O occupation area (input/output data)	4 word/4 word, 32 bit/32 bit (per station, remote device station)	16 bit/16 bit	16 bit/16 bit	—
Communication data resolution	12 bit (4096 resolution)	12 bit (4096 resolution)	12 bit (4096 resolution)	10 bit (1024 resolution)
Fail safe	HOLD ^{Note 3)} /CLEAR (Switch setting)	HOLD/CLEAR (Switch setting)	CLEAR	HOLD
Terminating resistor	—	—	Built into the product (Switch setting)	—

Note 1) Note that version information is subject to change.

Note 2) Configuration files can be downloaded from the SMC's website: <http://www.smcworld.com>

Note 3) The output HOLD value when a CC-Link communications error occurs can be set based on the bit area data.


Working Principle



Working Principle


When the input signal increases, the vacuum pressure solenoid valve ① turns ON, and the atmospheric pressure solenoid valve ② turns OFF. Because of this, VAC. and the pilot chamber ③ are connected, the pressure in the pilot chamber ③ becomes negative and acts on the top of the diaphragm ④. As a result, the vacuum pressure valve ⑤ which is linked to the diaphragm ④ opens, VAC. and OUT. are connected, and the set pressure becomes negative. This negative pressure feeds back to the control circuit ⑧ via the pressure sensor ⑦. Then, a correct operation works until a vacuum pressure proportional to the input signal is reached, and a vacuum pressure is obtained which is always proportional to the input signal.

Block Diagram




Series ITV209


Linearity



Hysteresis




Repeatability




Pressure Characteristics

Set pressure: -20 kPa



Flow Characteristics

Supply vacuum pressure: -100 kPa



Flow characteristics measurement conditions

- Exhaust flow rate of the vacuum pump used for measurement: 500 l/min (ANR)
- Inlet vacuum pressure: -100 kPa (When outlet flow rate is 0 l/min (ANR))
- Maximum flow rate: 132 l/min (ANR) (With inlet vacuum pressure at -39 kPa)

Dimensions





ITV209 Flat bracket




Note) Do not attempt to rotate the cable connector, as it does not turn.

Right angle type (4-wire)
Cable connector 3 m

Straight type (4-wire)
Cable connector 3 m




L-bracket




Dimensions (CC-Link, DeviceNet™, PROFIBUS DP and RS-232C)

CC-Link/ITV2090-CC




* Dimensions not shown are as on page 37.

DeviceNet™/ITV2090-DN




* Dimensions not shown are as on page 37.

PROFIBUS DP/ITV2090-PR



* Dimensions not shown are as on page 37.


RS-232C/ITV2090-RC



* Dimensions not shown are as on page 37.

With power cable connector

* **ITV2090-CC
DN
PR
RC** common dimensions




Note) Do not attempt to rotate the cable connector, as it does not turn.

Accessories (Option)/Part No.


Description		Part no.
Flat bracket assembly		KT-ITV-F2
L-bracket assembly		KT-ITV-L2
Power cable connector	Straight type 3 m	P398020-500-3
	Right angle type 3 m	P398020-501-3
Bus adapter (CC-Link model only)		EX9-ACY00-MJ

Dimensions

Flat bracket



L-bracket



Safety Instructions

These safety instructions are intended to prevent hazardous situations and/or equipment damage. These instructions indicate the level of potential hazard with the labels of “**Caution**,” “**Warning**” or “**Danger**.” They are all important notes for safety and must be followed in addition to International Standards (ISO/IEC)*1), and other safety regulations.

-  **Caution:** **Caution** indicates a hazard with a low level of risk which, if not avoided, could result in minor or moderate injury.
-  **Warning:** **Warning** indicates a hazard with a medium level of risk which, if not avoided, could result in death or serious injury.
-  **Danger :** **Danger** indicates a hazard with a high level of risk which, if not avoided, will result in death or serious injury.

- *1) ISO 4414: Pneumatic fluid power – General rules relating to systems.
ISO 4413: Hydraulic fluid power – General rules relating to systems.
IEC 60204-1: Safety of machinery – Electrical equipment of machines.
(Part 1: General requirements)
ISO 10218-1: Manipulating industrial robots - Safety.
etc.

Warning

1. The compatibility of the product is the responsibility of the person who designs the equipment or decides its specifications.

Since the product specified here is used under various operating conditions, its compatibility with specific equipment must be decided by the person who designs the equipment or decides its specifications based on necessary analysis and test results. The expected performance and safety assurance of the equipment will be the responsibility of the person who has determined its compatibility with the product. This person should also continuously review all specifications of the product referring to its latest catalog information, with a view to giving due consideration to any possibility of equipment failure when configuring the equipment.

2. Only personnel with appropriate training should operate machinery and equipment.

The product specified here may become unsafe if handled incorrectly. The assembly, operation and maintenance of machines or equipment including our products must be performed by an operator who is appropriately trained and experienced.

3. Do not service or attempt to remove product and machinery/equipment until safety is confirmed.

1. The inspection and maintenance of machinery/equipment should only be performed after measures to prevent falling or runaway of the driven objects have been confirmed.
2. When the product is to be removed, confirm that the safety measures as mentioned above are implemented and the power from any appropriate source is cut, and read and understand the specific product precautions of all relevant products carefully.
3. Before machinery/equipment is restarted, take measures to prevent unexpected operation and malfunction.

4. Contact SMC beforehand and take special consideration of safety measures if the product is to be used in any of the following conditions.

1. Conditions and environments outside of the given specifications, or use outdoors or in a place exposed to direct sunlight.
2. Installation on equipment in conjunction with atomic energy, railways, air navigation, space, shipping, vehicles, military, medical treatment, combustion and recreation, or equipment in contact with food and beverages, emergency stop circuits, clutch and brake circuits in press applications, safety equipment or other applications unsuitable for the standard specifications described in the product catalog.
3. An application which could have negative effects on people, property, or animals requiring special safety analysis.
4. Use in an interlock circuit, which requires the provision of double interlock for possible failure by using a mechanical protective function, and periodical checks to confirm proper operation.

Caution

1. The product is provided for use in manufacturing industries.

The product herein described is basically provided for peaceful use in manufacturing industries.

If considering using the product in other industries, consult SMC beforehand and exchange specifications or a contract if necessary.

If anything is unclear, contact your nearest sales branch.

Limited warranty and Disclaimer/ Compliance Requirements

The product used is subject to the following “Limited warranty and Disclaimer” and “Compliance Requirements”.

Read and accept them before using the product.

Limited warranty and Disclaimer

1. The warranty period of the product is 1 year in service or 1.5 years after the product is delivered.*2)
Also, the product may have specified durability, running distance or replacement parts. Please consult your nearest sales branch.

2. For any failure or damage reported within the warranty period which is clearly our responsibility, a replacement product or necessary parts will be provided.

This limited warranty applies only to our product independently, and not to any other damage incurred due to the failure of the product.

3. Prior to using SMC products, please read and understand the warranty terms and disclaimers noted in the specified catalog for the particular products.

*2) Vacuum pads are excluded from this 1 year warranty.

A vacuum pad is a consumable part, so it is warranted for a year after it is delivered.

Also, even within the warranty period, the wear of a product due to the use of the vacuum pad or failure due to the deterioration of rubber material are not covered by the limited warranty.

Compliance Requirements

1. The use of SMC products with production equipment for the manufacture of weapons of mass destruction (WMD) or any other weapon is strictly prohibited.
2. The exports of SMC products or technology from one country to another are governed by the relevant security laws and regulations of the countries involved in the transaction. Prior to the shipment of a SMC product to another country, assure that all local rules governing that export are known and followed.

Safety Instructions

Be sure to read “Handling Precautions for SMC Products” (M-E03-3) before using.



Series ITV0000/1000/2000/3000

Specific Product Precautions 1

Be sure to read before handling. Refer to back page 1 for Safety Instructions, "Handling Precautions for SMC Products" (M-E03-3) for Common Precautions.

Series ITV0000/009 Precautions

Air Supply

⚠ Caution

1. Install an air filter near this product on the supply side. Select a filtration degree of 5 μm or less.
2. Compressed air containing large amounts of drainage can cause malfunction of this product and other pneumatic equipment. As a countermeasure, install an aftercooler, air dryer or Drain Catch, etc.
3. If large amounts of carbon dust are generated by the compressor, it can accumulate inside this product and cause malfunction.


For details on the above compressed air quality, refer to SMC's "Air Preparation Systems".

Wiring



⚠ Caution

Connect the cable to the connector on the body with the wiring arranged as shown below. Proceed carefully, as incorrect wiring can cause damage.

Further, use DC power with sufficient capacity and a low ripple.




Terminal No.	1	2	3	4
Lead wire color	Brown	White	Blue	Black
Wiring	Power	Signal	COM	Monitor



Note) A right angle type cable is also available. The entry direction for the right angle type connector is to downwards (SUP port side).
Never turn the connector as it is not designed to turn. Using force to turn the connector will damage the connector coupling.


Wiring Diagrams

Current signal type



Vs: Power Supply 24 VDC $\pm 10\%$
12 to 15 VDC
A: Input signals 4 to 20 mA DC
0 to 20 mA DC


Voltage signal type



Vs: Power Supply 24 VDC $\pm 10\%$
12 to 15 VDC
Vin: Input signals 0 to 5 VDC
0 to 10 VDC

Monitor output wiring diagram

Analog output, voltage type



Handling

⚠ Caution

1. Do not use a lubricator on the supply side of this product, as this can cause malfunction. When lubrication of terminal equipment is necessary, connect a lubricator on the output side of this equipment.
2. If electric power is shut off while pressure is being applied, pressure will be retained on the output side.
However, this output pressure is held only temporarily and is not guaranteed. If exhausting of this pressure is desired, shut off the power after reducing the set pressure, and discharge the air using a residual pressure exhaust valve, etc.
3. If power to this product is cut off due to a power failure, etc. when it is in a controlled state, output pressure will be retained temporarily. Handle carefully when operating with output pressure released to the atmosphere, as air will continue to flow out.
4. If supply pressure to this product is interrupted while the power is still on, the internal solenoid valve will continue to operate and a humming noise may be generated.
Since the life of the product may be shortened, shut off the power supply also when supply pressure is shut off.
5. This product is adjusted for each specification at the time of shipment from the factory. Avoid careless disassembly or removal of parts, as this can lead to malfunction.
6. The optional cable connector is a 4 wire type. When the monitor output (analog output or switch output) is not being used, keep it from touching the other wires as this can cause malfunction.
7. Please note that the right angle cable does not rotate and is limited to only one entry direction.
8. Take the following steps to avoid malfunction due to noise.
 - 1) Remove power supply noise during operation by installing a line filter, etc. in the AC power line.
 - 2) For avoiding the influence of noise or static electricity, install this product and its wiring as far as possible from strong electric fields such as those of motors and power lines, etc.
 - 3) Be sure to implement protective measures against load surge for induction loads (solenoid valves, relays, etc.).
9. The product characteristics are confined to the static state. When air is consumed on the output side, and especially used in the system with large leakage, pressure cannot approach the set pressure and the service life is drastically shortened with a humming noise of the solenoid valve.

10. For details on the handling of this product, refer to the instruction manual which is included with the product.

11. In locations where the body is exposed to water, dust, etc., there is a possibility that moisture or dust could enter the body through the breathing hole.

Mount a fitting and tube (M-3AU-3 fitting and TIU01m-mm tube recommended) onto the breathing hole and run the tube to a location not exposed to moisture or dust, etc.

Breathing hole
M3 x 0.5

12. If this product will be used in a sealed environment, such as inside an inspection box, a ventilation fan should be installed to ensure adequate ventilation as this product can generate heat in some operating conditions.
When the power is turned on, a noise may be generated as a means of checking the operating condition of the solenoid valve. This noise is normal and does not indicate a fault.



Series ITV0000/1000/2000/3000

Specific Product Precautions 2

Be sure to read before handling. Refer to back page 1 for Safety Instructions, "Handling Precautions for SMC Products" (M-E03-3) for Common Precautions.

Series ITV1000/2000/3000/209□ Precautions

Piping


⚠ Warning

1. Screw piping together with the recommended proper torque while holding the side that has female threads.

Looseness or faulty sealing will occur if tightening torque is insufficient, while thread damage will result if the torque is excessive. Furthermore, if the side with the female threads is not held while tightening, excessive force will be applied directly to piping brackets, etc. causing damage or other problems.


Recommended proper torque: N · m

Connection thread	1/8	1/4	3/8	1/2
Torque	7 to 9	12 to 14	22 to 24	28 to 30



2. Do not allow twisting or bending moment to be applied other than the weight of the equipment itself.

Provide separate support for external piping, as damage may otherwise occur.



3. Since excessive moment loads and the propagation of vibrations, etc. can easily result from inflexible piping made of materials such as steel, avoid these problems by using flexible tubing for intermediate connections.

⚠ Caution


1. Preparation before piping

Before piping is connected, it should be thoroughly blown out with air (flushing) or washed to remove chips, cutting oil and other debris from inside the pipe.

2. Wrapping of pipe tape

When screwing together pipes and fittings, etc., be certain that chips from the pipe threads and sealing material do not get inside the piping.

Also, when pipe tape is used, leave 1.5 to 2 thread ridges exposed at the end of the threads.



Operating Environment

⚠ Warning

1. Do not operate in locations having an atmosphere of corrosive gases, chemicals, sea water, or where there will be contact with the same.
2. Do not operate in locations where vibration or impact occurs.

⚠ Caution

1. In locations where the body is exposed to water, steam, dust, etc., there is a possibility that moisture or dust could enter the body through the EXH (solenoid) ports, thereby causing problems.
2. To overcome this, simply install tubing to each port, using the fittings, and extend the tubing so that the other end is at a location where no water splash, etc. occurs. Make sure not to bend, or block the I.D. of the tubing as this will have a detrimental affect on the pressure control.
3. Do not operate in locations where vibration or impact occurs.
4. In locations which receive direct sunlight, provide a protective cover, etc.
5. In locations near heat sources, block off any radiated heat.
6. In locations where there is contact with spatter from water, oil or solder etc., implement suitable protective measures.

Air Supply

⚠ Warning

1. Employ suitable protective measures in locations where there is contact with water droplets, oil or welding spatter, etc.
2. Consult with SMC when used in power plants, or if instrumentation related.

⚠ Caution

1. Install an air filter near this product on the supply side. Select a filtration degree of 5 μm or less.
2. Compressed air containing large amounts of drainage can cause malfunction of this product and other pneumatic equipment. As a countermeasure, install an aftercooler, air dryer or Drain Catch, etc.
3. If large amounts of carbon dust are generated by the compressor, it can accumulate inside this product and cause malfunction. For details on the above compressed air quality, refer to SMC's "Air Preparation Systems".



Series ITV0000/1000/2000/3000

Specific Product Precautions 3

Be sure to read before handling. Refer to back page 1 for Safety Instructions, "Handling Precautions for SMC Products" (M-E03-3) for Common Precautions.

Series ITV1000/2000/3000/209□ Precautions

Handling

⚠ Caution

1. Do not use a lubricator on the supply side of this product, as this can cause malfunction. When lubrication of terminal equipment is necessary, connect a lubricator on the output side of this equipment.
2. If electric power is shut off while pressure is being applied, pressure will be retained on the output side.
However, this output pressure is held only temporarily and is not guaranteed. If exhausting of this pressure is desired, shut off the power after reducing the set pressure, and discharge the air using a residual pressure exhaust valve, etc.
3. If power to this product is cut off due to a power failure, etc. when it is in a controlled state, output pressure will be retained temporarily. Handle carefully when operating with output pressure released to the atmosphere, as air will continue to flow out.
4. If supply pressure to this product is interrupted while the power is still on, the internal solenoid valve will continue to operate and a humming noise may be generated. Since the life of the product may be shortened, shut off the power supply also when supply pressure is shut off.
5. In this product, the output side pressure cannot be completely relieved within the range of 0.005 MPa or less. If it is desired to reduce the pressure completely to 0 MPa, install a 3 way valve or other device on the output side to exhaust the pressure.
6. This product is adjusted for each specification at the time of shipment from the factory. Avoid careless disassembly or removal of parts, as this can lead to malfunction.
7. The optional cable connector is a 4-wire type. When the monitor output (analog output or switch output) is not being used, keep it from touching the other wires as this can cause malfunction.
8. Please note that the right angle cable does not rotate and is limited to only one entry direction.
9. Take the following steps to avoid malfunction due to noise.
 - 1) Remove power supply noise during operation by installing a line filter, etc. in the AC power line.
 - 2) For avoiding the influence of noise or static electricity, install this product and its wiring as far as possible from strong electric fields such as those of motors and power lines, etc.
 - 3) Be sure to implement protective measures against load surge for induction loads (solenoid valves, relays, etc.).

Handling

⚠ Caution

10. Due to the large volume of the output side, a loud exhaust noise will be produced when being used for the purpose of a relief function. Therefore, install a silencer (SMC Series AN200 or AN400) on the exhaust port (EXH port). The port sizes are Rc 1/8, Rc 1/4 and Rc 1/2.
11. Specifications on page 10 is in case of static environment. Pressure may fluctuate when air is consumed at the output side.
12. For details on the handling of this product, refer to the instruction manual which is included with the product.

Design and Selection

⚠ Caution

1. The direct-current power supply to combine should be UL authorized power supply.

- (1) Limited voltage current circuit in accordance with UL 508.
A circuit in which power is supplied by the secondary coil of a transformer that meets the following conditions.
 - Maximum voltage (with no load):
30 Vrms (42.4 V peak) or less
 - Maximum current:
 - (1) 8 A or less (including when short circuited)
 - (2) limited by circuit protector (such as fuse) with the following ratings.


No load voltage (V peak)	Max. current rating
0 to 20 [V]	5.0
Above 20 to 30 [V]	100 Peak voltage

- (2) A circuit using max. 30 Vrms or less (42.4 V peak), which is powered by UL1310 or UL1585 compatible Class-2 power supply.

2. Operate these products only within the specified voltage.

Using voltages beyond the specified levels could cause faults or malfunctions.

3. Use 0 V as the baseline for the power supplied to the unit for output, control and input.





Series ITV0000/1000/2000/3000

Specific Product Precautions 4

Be sure to read before handling. Refer to back page 1 for Safety Instructions, "Handling Precautions for SMC Products" (M-E03-3) for Common Precautions.

Series ITV1000/2000/3000/209□ Precautions

Wiring

Caution

Connect the cable to the connector on the body with the wiring arranged as shown below. Proceed carefully, as incorrect wiring can cause damage. Further, use DC power with sufficient capacity and a low ripple.




Current Signal Type Voltage Signal Type


1	Brown	Power supply
2	White	Input signal
3	Blue	GND (COMMON)
4	Black	Monitor output

Preset Input Type


1	Brown	Power supply
2	White	Input signal 1
3	Blue	GND (COMMON)
4	Black	Input signal 2



CC-Link



PROFIBUS DP



DeviceNet™, RS-232C

IN/OUT communication connector				
Pin No.	CC-Link	DeviceNet™	PROFIBUS DP	RS-232C
1	SLD	DRAIN	NC	NC
2	DB	V+	RxD/TxD-N	TxD
3	DG	V-	NC	RxD
4	DA	CAN_H	RxD/TxD-P	GND
5	NC	CAN_L	NC	NC

Power supply connector				
Pin No.	CC-Link	DeviceNet™	PROFIBUS DP	RS-232C
1	Vcc	Vcc	Vcc	Vcc
2	FG	No connection	NC	NC
3	GND	GND	GND	GND
4	NC	No connection	NC	FG

Note) The cable is also available in a right angle type. (Communication cable: straight type only)
A right angle type connector is attached facing left (towards the SUP port). On communication models, the connector faces backwards (towards the EXH port). Do not attempt to rotate, as the connector does not turn.


Trademark Information

DeviceNet™ is a trademark of ODVA.

Back page 5


Wiring diagram

Current signal type




Vs : Power supply 24 VDC
12 to 15 VDC
A : Input signal 4 to 20 mA DC
0 to 20 mA DC

Voltage signal type



Vs : Power supply 24 VDC
12 to 15 VDC
Vin: Input signal 0 to 5 VDC
0 to 10 VDC

Preset input type



Vs : Power supply 24 VDC
12 to 15 VDC

One of the preset pressures P1 through P4 is selected by the ON/OFF combination of S1 and S2.

S1	OFF	ON	OFF	ON
S2	OFF	OFF	ON	ON
Preset pressure	P1	P2	P3	P4

* For safety reasons, it is recommended that one of the preset pressures be set to 0 MPa.


* Preset pressures are set based on the minimum unit for output display.

MPa	kgf/cm ²	bar	psi	kPa
0.001	0.01	0.01	0.1	1


· Note that this is 1 psi for 130 psi types.

Monitor output wiring diagram


Analogue output: Voltage type




Analogue output: Current type (Sink type)



Switch output: NPN type



Switch output: PNP type



* When 80 mA DC or more is applied, detecting device for overcurrent starts activating and then emits an error signal. (Error number "5")



Series ITV0000/1000/2000/3000

Specific Product Precautions 5

Be sure to read before handling. Refer to back page 1 for Safety Instructions, “Handling Precautions for SMC Products” (M-E03-3) for Common Precautions.

Series ITV1000/2000/3000/209□ Precautions

Set Pressure Range

The set pressure range, by unit of standard measured pressure, is shown in the table below.

Set pressure range, by unit of standard measured pressure

Unit	Set pressure range			
	ITV□01□	ITV□03□	ITV□05□	ITV209□
MPa	0.005 to 0.1	0.005 to 0.5	0.005 to 0.9	—
kgf/cm ²	0.05 to 1	0.05 to 5	0.05 to 9	—
bar	0.05 to 1	0.05 to 5	0.05 to 9	—
psi	0.7 to 15	0.7 to 70	0.7 to 130	—
kPa	5 to 100	5 to 500	5 to 900	−1.3 to −80

CE Marking

When using the power supply cable for the CE compliant product (including Made to Order), mount the ferrite core on the cable according to the following “Ferrite core necessity”.

• Series ITV0000

Model	Ferrite core necessity	Recommended power supply cable
ITV0000-□□-Q	Unnecessary	M8-4DSX3MG4 (Straight type) ELWIKA-KV4408 PVC025 2M (Right angle type)

• Series ITV1000/2000/3000

Model	Ferrite core necessity	Recommended power supply cable
ITV□□-□□-Q	Necessary	P398010-12 (Straight type) (With ferrite core) P398010-13 (Right angle type) (With ferrite core)
ITV□□-CC□-Q	Unnecessary	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
ITV□□-DN□-Q	Necessary (Ferrite core is supplied as an accessory for the body.)	P398020-504-3 (Straight type) P398020-505-3 (Right angle type)
ITV□□-PR□-Q ITV□□-RC□-Q	Necessary (Ferrite core is supplied as an accessory for the body.)	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)

Note) Recommended power supply cable length is 3 m. (ELWIKA-KV4408 PVC025 2M is 2 m.) If any other length is desired, please consult with SMC.



Series ITV0000/1000/2000/3000

Specific Product Precautions 6

Be sure to read before handling. Refer to back page 1 for Safety Instructions, "Handling Precautions for SMC Products" (M-E03-3) for Common Precautions.

Series ITV009□/209□ Precautions

Handling

Caution

1. Connect the vacuum pump to the port, which is labeled "VAC".
2. Pressure adjustment changes from "atmospheric pressure to vacuum pressure" when the input signal is increased, and from "vacuum pressure to atmospheric pressure" when the input signal is decreased.
3. When adjusting the vacuum pressure, be careful not to block the atmospheric pressure inlet port labeled "ATM".
4. Since this product is designed exclusively for use with negative pressure, be careful not to apply positive pressure in error.
5. In cases where the vacuum pump being used has a relatively small capacity, or the piping has a small inside diameter, etc., large variations in the set pressure (the range of pressure variation when changing from no flow to flow state) may appear. In this situation, the vacuum pump or the piping, etc. should be changed. In cases where it is not practical to change the vacuum pump, install a capacity tank (volume depending on the operating conditions) on the VAC side.
6. The vacuum pressure response time after a change in the input signal is influenced by the internal volume on the setting side (including piping). Since the capacity of the vacuum pump also influences the response time, give careful consideration to these points before operation.
7. If the electric power is shut off when in a control state, the pressure on the setting side will go into a holding condition. However, this setting side pressure will be held only temporarily and is not guaranteed. In addition, when atmospheric pressure is desired, shut off the power after reducing the set pressure, and then introduce atmospheric pressure by using a vacuum release valve, etc.
8. If the power for this product is cut off by a power failure, etc. when it is in a controlled state, the setting side pressure will be held temporarily. Further, if operated without sealing the setting side so that atmospheric air is sucked in, handle with care as air will continue to be sucked in.
9. If the VAC side pressure to this product is interrupted while the power is still on, the internal solenoid valve will continue to operate and may cause a humming noise. Since this may shorten the life of the product, be sure to shut off the power when the VAC side pressure is shut off.
10. The setting side pressure cannot be completely released from this product in the range below -1.3 kPa. In cases where the pressure needs to be reduced completely to 0 kPa, install a 3 port valve, etc. on the setting side to discharge the residual pressure.
11. This product is adjusted for each specification at the factory before shipment. Avoid careless disassembly or removal of parts, as this can cause failure.
12. The optional cable connector is a 4-wire type. When the monitor output (analog output, switch output) is not being used, keep it from touching the other wires, as this can cause malfunction.
13. Use caution that the right angle cable does not rotate and is limited to only one entry direction.
14. Take the following steps to avoid malfunction due to noise.
 - 1) Eliminate power supply noise during operation by installing a line filter, etc. in the AC power line.
 - 2) For avoiding the influence of noise or static electricity, install this product and its wiring as far as possible from strong electric fields such as those of motors and power lines, etc.
 - 3) Make sure to take protective measures against load surge for an induction load (solenoid valves, relays, etc.).
15. Refer to the instruction manual included with the product for details on its handling.

SMC Corporation

Akihabara UDX 15F,
4-14-1, Sotokanda, Chiyoda-ku, Tokyo 101-0021, JAPAN
Phone: 03-5207-8249 Fax: 03-5298-5362
URL <http://www.smcworld.com>
© 2010 SMC Corporation All Rights Reserved

Revision history		
Edition D	* Addition of Series ITV1000. * Number of pages from 16 to 20.	HX
Edition E	* Addition of Series ITV0000/009□. * Addition of Series ITV209□. * Addition of Fieldbus-compatible specifications CC-Link, DeviceNet™ and PROFIBUS DP. * Addition of RS-232C serial communication specification. * Addition of CE [option] and UL. * Number of pages from 20 to 52.	NS
Edition F	* Change of dimensions of Series ITV1000/2000/3000/209□. * Change of enclosure for Series ITV209□ to conform to IP65.	OZ