

B28919 R25


NOTA TÉCNICA GTT-Nº 02/88  
GAC-Nº 07/88

CNEN - DR - GTT - NT -- 02 | 88

IMPLANTAÇÃO DO CÓDIGO TRAC-PF1 NO VAX-11/750

# *nota técnica*

*Departamento de Reatores*



**cnen**

*comissão nacional de energia nuclear*

CNEN  
DR

DOCUMENTO:

NOTA TÉCNICA GTT-Nº 02/88  
CAC-Nº 07/88

DATA:

NOVEMBRO/88

REVISÃO:

0

TÍTULO:

IMPLANTAÇÃO DO CÓDIGO TRAC-PF1 NO VAX-11/750

AUTOR (ES):

ALZIRA ABRANTES MADEIRA  
LEO DE SOUZA GOUVEA  
MARIA REGINA DA SILVA GALETTI

REFERÊNCIAS:

ORIGEM: SDS-DAS-Nº 111/88  
ENCAMINHAMENTO: CI-GTT-Nº 38/88  
OUTRAS:

ÓRGÃO:

GRUPO DE TRANSITÓRIOS E TERMO-HIDRÁULICA  
GRUPO DE APOIO COMPUTACIONAL

RAMAL: 324/428

APROVADO POR:

AURO CORREIA PONTEDEIRO/  
LEO DE SOUZA GOUVEA/  
CLAUDIO T.M. CAMARGO/

*Auro Correia Pontedeiro*  
*Leo de Souza Gouveia*  
*Claudio Camargo*

CNEN  
DR

AUTOR: AAM/ *A*  
LSG/ *Lio*  
MRSG/ *Regina*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88

PÁGINA:

NOTA TÉCNICA

1/11

PARTE:

REVISÃO:

DATA:

0

NOVEMBRO/88

### SUMÁRIO

Esta nota técnica descreve a implantação do código TRAC-PF1-  
versão IBM, no VAX-11/750 da Diretoria Executiva I. Este trabalho se  
configura na obtenção de uma ferramenta avançada de cálculo "best-  
estimate", disponível no Departamento de Reatores para análise de aci-  
dentes de perda de refrigerante.

### ABSTRACT

This technical note describes the implantation of TRAC-PF1  
code, IBM version, in VAX-11/750. This work provides Reactor  
Department with an advanced best-estimate tool to perform loss-of-  
coolant accident analysis.

CNEN  
DR

AUTOR: AAM/ *Am*  
LSG/ *Lio*  
MRSR/ *Regina*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88  
NOTA TÉCNICA

PAGINA:  
11/11

PARTE:

REVISÃO:

0

DATA:  
NOVEMBRO/88

ÍNDICE

	Páginas
SUMÁRIO .....	1/11
ABSTRACT .....	1/11
I. Introdução .....	01/08
II. Conversão .....	02/08
II.1 - Descrição do Sistema Computacional .....	02/08
II.2 - Modificações Necessárias para a Compilação e Linkedição .....	02/08
II.3 - Modificações Necessárias para a Execução .....	03/08
III. Conclusão .....	07/08
IV. Referências .....	08/08
 APÊNDICES :	
Apêndice A - Divisão do Programa Fonte - TRAC-PF1 .....	A1/07
Apêndice B - Organização do Programa Fonte .....	B1/13
B.1 Descrição do JCL .....	B2/13
B.2 Mapa de Chamada das Rotinas .....	B3/13
Apêndice C - Caso Exemplo 1 - "Four Pipe Heated Wall Blowdown - Five Nodes in Heated Wall, H = 10 Post CHF HT MOD" ...	C1/31

**I. INTRODUÇÃO**

Dentre as atribuições do Grupo de Transitórios e Termo-hidráulica (GTT) está o desenvolvimento de capacitação técnica na área de análise de acidentes por perda de refrigerante.

Neste contexto inclui-se a familiarização com ferramentas de cálculo pertinentes à área, entre elas o código TRAC-PF1 (1), utilizado na análise de acidentes, cujo aprendizado foi dividido em quatro etapas, a saber:

- 1ª - Implantação no VAX-11/750 do Departamento de Reatores (DR);
- 2ª - Simulação de experimentos;
- 3ª - Simulação de Angra 1;
- 4ª - Implantação de saída gráfica e "re-start".

Esta nota técnica descreve o trabalho efetuado para a execução da primeira etapa, que constou da implantação da versão 7.6 (2) do código, em conjunto com o Grupo de Apoio Computacional (GAC).

O código TRAC vem sendo desenvolvido no LANL (Los Alamos National Laboratory) a fim de se obter uma ferramenta avançada para o cálculo "best-estimate" na análise de acidentes postulados em reatores a água leve. O código TRAC-PF1 possui esta capacidade de análise para reatores pressurizados a água e para vários aparatos experimentais termo-hidráulicos, e é programado em linguagem FORTRAN IV para utilização em um computador CDC-7600.

O GRS (Gesellschaft für Reaktorsicherheit, Munique - Alemanha) converteu a versão 6.0 do TRAC-PF1 para o FORTRAN-IBM e a atualizou até a versão 7.6, a qual foi obtida pelo DR através do NESC (National Energy Software Center).

## II. CONVERSÃO

### II.1 - Descrição do Sistema Computacional

O sistema disponível no DR compõe-se de um computador ELEBRA MX-850 e periféricos. Este computador é a versão nacional do VAX-11/750 da DIGITAL, uma máquina amplamente utilizada para o cálculo científico em todo o mundo. O sistema operacional VAX-VMS é o mesmo utilizado em todas as máquinas da DIGITAL, e o compilador FORTRAN é uma extensão do FORTRAN-77.

Tendo em vista que o FORTRAN-CDC é bastante diferente do padrão FORTRAN-77, a conversão seria bastante complexa e como o GRS fez esta conversão para o FORTRAN-IBM, este mais próximo do FORTRAN-77, optou-se pela implantação desta versão que estava disponível no NESC.

### II.2 - Modificações Necessárias para a Compilação e Linkedição

Nesta primeira etapa da implantação foram necessárias as seguintes modificações para compatibilizar a versão IBM ao compilador do VAX:

- nas definições de funções, sub-rotinas e "entry points" alguns argumentos que estavam entre barras, indicando a forma de passagem do argumento, tiveram estas retiradas;
- nomes de sub-rotinas e COMMON's que começavam com o caracter \$ tiveram seus nomes modificados, visto que o VAX não aceita \$ como primeiro caracter;
- diversos "holleriths" foram modificados, substituindo-se o H por ' porque, no processo de buscar o fonte de fita para disco, os caracteres brancos finais de cada linha foram truncados ocasionando erro de compilação;
- algumas variáveis, que estavam definidas pelo tipo mais de uma vez na mesma rotina, ficaram definidas apenas uma vez;

- o limite de valor de números reais que podem ser utilizados com o processador de ponto flutuante é de  $10^{38}$  e não  $10^{78}$ , como na maioria de outros computadores, portanto as variáveis que excediam àquele limite foram reduzidas;
- alguns ajustes de sintaxe em FORMAT's foram realizados.

Na linkedição foi verificada a necessidade de troca dos nomes das funções ITIME, IXOR, DARCOS e DFLOAT para SECNDS, IEOR, ACOS e FLOAT respectivamente, pois estas são internas à máquina e portanto seus nomes dependem do sistema utilizado.

### II.3 - Modificações Necessárias para a Execução

Os casos exemplos escolhidos pelo GRS foram:

- 1- "Four Pipe Heated Wall Blowdown  
Five Nodes in Heated Wall, H = 10 Post CHF HT MOD"
- 2- "FLECHT Flooding Rate Test No. 04831"
- 3- "Zion Reactor Core Test of Reactivity Feedback from No to Full Power"
- 4- "Pressurized Water Reactor (PWR) - 12 kW/ft  
Coarse Node Version with 2 Loops - Steady State  
Based on Zion 4-Loop PWR - 5/80 - J.R.I."

Todos estes casos exemplos foram simulados na implantação, estando a saída do caso exemplo 1 no apêndice C.

Vários erros foram sendo encontrados ao longo das execuções em diversos pontos do programa, e podem ser resumidos em:

- o dimensionamento variável tem a seguinte restrição no VAX: a variável utilizada como dimensão não pode valer zero. A exe

cução é interrompida mesmo que o vetor não seja utilizado. É necessário evitar esta chamada ou modificar o dimensionamento, o que levou a modificações específicas para cada caso, como descrito a seguir:

```
...  
N = 0  
...  
...  
CALL SUB(A,N)  
...  
...  
SUBROUTINE SUB(A,N)  
DIMENSION A(N)  
IF (N.LE.0) RETURN  
...  
...
```

A programação acima causa a interrupção do programa na chamada da sub-rotina por erro ADJARDIM - "adjustable array dimension error".

Foram utilizadas duas formas distintas para solucionar este problema. Caso a dimensão zero indique não ser necessário ir à sub-rotina, a modificação descrita abaixo é feita em todas as chamadas:

```
...  
...  
IF (N.GT.0) CALL SUB(A,N)  
...  
...  
SUBROUTINE SUB(A,N)  
...  
...
```

Como exemplo citamos a sub-rotina LOAD, que serve para inicializar vetores, e não precisa ser chamada se o número de elemen

tos a inicializar (terceiro parâmetro) é zero. Foram colocados diversos comandos IF's para evitar a chamada.

Havendo a necessidade de ir à sub-rotina, apenas esta é modificada, como a seguir:

```
...  
...  
CALL SUB(A,N)  
...  
...  
SUBROUTINE SUB(A,N)  
DIMENSION A(*)  
...  
...
```

Um exemplo do caso acima está relacionado ao dimensionamento variável de matrizes, o qual é mais restrito, sendo irrelevante somente o valor da última das dimensões. É o caso da sub-rotina TFIDS, com as matrizes AOU(..., 1), TWL(..., 1) e TWV(..., 1), que ocasionalmente recebem valor zero na primeira dimensão. Neste caso estas foram transformadas em vetores de uma só dimensão, e modificado convenientemente seu índice, assim:

DIMENSION AOU(NODES, 1) substituído por DIMENSION AOU(\*)

AOU(I,J) substituído por AOU( (I-1) \* NODES + J);

- os COMMON's foram feitos de tamanho igual em todas as rotinas em que aparecem. Por exemplo:

A(40000), ALCM(131071);

- como no FORTRAN-77 o tratamento de caracteres é diferente do tratamento de variáveis numéricas, foi necessário colocá-las explicitamente como sendo do tipo CHARACTER, e substituir as constantes de "hollerith" (n H texto) por constantes do tipo CHARACTER ('texto').

Esta modificação pode ser ilustrada com as sub-rotinas WARRAY e WIARR que foram alteradas, sendo a variável ARRID definida como do tipo CHARACTER\*8. Conseqüentemente em todas as chamadas a estas duas rotinas o parâmetro correspondente foi trocado de "hollerith" (n H texto), considerado constante numérica, para a forma "string" 'texto', considerada constante caracter pelo VAX.

Este mesmo procedimento foi adotado em relação ao último parâmetro da sub-rotina SCLTBL. Nas chamadas, este parâmetro deve conter sempre os oito caracteres, não sendo permitido "strings" menores.

Também nas chamadas da sub-rotina GRFPUT os parâmetros que contêm "strings" foram completados para o tamanho correto;

- o valor da variável LLAST no BLOCK DATA foi modificado para 131071, igual à dimensão do vetor ALCM no COMMON/LCMSP/;
- no padrão FORTRAN-77 um "loop" controlado pelo comando DO não é executado nenhuma vez caso o limite superior seja menor que o limite inferior. O GRS colocou um comando IF antes de cada comando DO a fim de garantir este funcionamento. Como no VAX este comando DO funciona conforme o padrão FORTRAN-77, os comandos IF's tornaram-se desnecessários e foram retirados;
- foi retirada a chamada para a sub-rotina ERRSET, que é do sistema IBM, e controla a impressão de mensagem de erro;
- compatibilizou-se o tipo da variável a ser impressa com o FORMAT correspondente, quando necessário;
- tendo em vista o limite de  $10^{38}$  para valores reais no VAX, foi necessário modificar expressões aritméticas para evitar "overflow" no cálculo.

### III. CONCLUSÕES

Com o término da primeira etapa do aprendizado da utilização do código TRAC-PF1, o GTT já possui uma ferramenta de cálculo para análises de acidentes com perda de refrigerante (APR).

A segunda etapa, que consiste na simulação de experimentos, já foi iniciada com a modelagem de um teste de despressurização em um tubo horizontal<sup>(3)</sup>, sob a supervisão do Dr. G. Yadigaroglu<sup>(4)</sup>, por ocasião de sua consultoria técnica ao GTT em agosto de 1988. Este trabalho se encontra em andamento e uma nota técnica será publicada.

Ainda nesta segunda etapa será analisado um problema padrão proposto pelo VII Encontro Nacional de Física de Reatores (ENFIR), a realizar-se de 26 a 28 de abril de 1989 em Recife, PE. Este problema consiste na simulação de uma experiência de despressurização, na qual foram efetuadas medidas de pressão, temperatura e fração de vazio durante a evolução do transiente.

Uma análise do tempo de CPU gasto para os quatro casos exemplos mostrou que a execução da versão do TRAC-PF1 implantada no VAX é da ordem de 12 vezes mais lenta que a versão do GRS executada no IBM. Algumas modificações para tornar o programa menor e mais rápidas, o que levará à otimização do uso do código.

CNEN DR	AUTOR: AAM/ <i>As</i> LSG/ <i>Lin</i> MRSG/ <i>Ragina</i> GTT ÓRGÃO GAC	DOCUMENTO: Nº 02/88	PAGINA: 08/08
		NOTA TÉCNICA	
		PARTE:	REVISÃO: 9
			DATA: NOVEMBRO/88

#### IV. REFERÊNCIAS

- 1 - TRAC-PF1 : An Advanced Best-Estimate Computer Program for Pressurized Water Reactor Analysis - Safety Code Development Group - Energy Division - Los Alamos Scientific Laboratory.
- 2 - Transient Reactor Analysis Code - Input Specifications - TRAC-PF1 7.0/EXTUPD7.6 - Safety Code Development - Energy Division - Los Alamos National Laboratory - June 1982.
- 3 - N. Aksan, M. Andreani, G. Analytis, G. Yadigaroglu: PROBLEM 18 - BLOWDOWN - Second International Workshop on Two-Phase Flow Fundamentals - PHYSICAL BENCHMARK EXERCISE, 16-20 March 1987, RPI, Troy, New York, USA.
- 4 - A.C. Pontedeiro: Missão de Perito da AIEA, Prof. Dr.G.Yadigaroglu em Serviço de Assistência Técnica ao GTT - Relatório de Atividades-GTT - Nº 021/88, Setembro/88.

CNEN  
DR

AUTOR: AAM/ *Aq*  
LSG/ *lio*  
MRSG/ *Regina*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88  
NOTA TÉCNICA

PAGINA:  
A1/07

PARTE:  
APÊNDICE A

REVISÃO:  
Ø

DATA:  
NOVEMBRO/88

APÊNDICE A

DIVISÃO DO PROGRAMA FONTE - TRAC-PFI

DIVISÃO DO PROGRAMA FONTE - TRAC-PF1

O programa fonte utilizado está na fita DRF303, arquivos 13 e 15.

O grande número de linhas do TRAC-PF1 (87954 linhas) levou à necessidade de subdividir o programa fonte em 17 módulos de aproximadamente 5000 linhas.

A seguir é fornecido o nome de cada módulo, bem como suas sub-rotinas, funções (reais (F), lógicas (LF) e inteiras (IF) ) associadas:

- Módulo 1 → TRAC01.FOR (linhas 1 a 5040)

- |              |                  |                 |
|--------------|------------------|-----------------|
| 1 - DATE     | 12 - RXVSLR      | 23 - BACIT      |
| 2 - RDCODI   | 13 - RXVSRR      | 24 - BFALOC     |
| 3 - RHSET    | 14 - ACCMBD      | 25 - BFCLOS     |
| 4 - RID (LF) | 15 - ACCM1X      | 26 - BFIN       |
| 5 - RWRLCM   | 16 - ACCUM1      | 27 - BFOUT      |
| 6 - RXCMPR   | 17 - ACCUM2      | 28 - BKMOM      |
| 7 - RXCOMR   | 18 - ACCUM3      | 29 - BKSMOM     |
| 8 - RXCORR   | 19 - ALLBLK (LF) | 30 - BKSSTB     |
| 9 - RXPTRS   | 20 - ANNSH       | 31 - BLOCK DATA |
| 10 - RKREAD  | 21 - ASIGN       | 32 - BREAKX     |
| 11 - RXVSCR  | 22 - AXPOW       | 33 - BREAK1     |

CNEN  
DR

AUTOR: AAM/ *Am*  
LSG/ *Leo*  
MRSRG/ *Regina*  
GTT  
GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

A3/07

PARTE:

REVISÃO:

DATA:

APÊNDICE A

0

NOVEMBRO/88

- Módulo 2 → TRACØ2.FOR (linhas 5041 a 10079)

1 - BREAK2	10 - CHOKE	19 - COREC3
2 - BREAK3	11 - CIVSSL	20 - CORE1
3 - BREBAL	12 - CLEAN	21 - CORE3
4 - CDTHEX (F)	13 - CLEAR	22 - CPLL (F)
5 - CHBD	14 - CLOCK	23 - CPVV (F)
6 - CHEN	15 - COMPI	24 - CPVV1 (F)
7 - CHF	16 - CONSTB	25 - CTAIN1
8 - CHF1	17 - COREC1	26 - CTAIN2
9 - CHKSR	18 - COREC2	27 - CTAIN3
		28 - CWVSSL

- Módulo 3 → TRACØ3.FOR (linhas 10080 a 16106)

1 - CYLHT	10 - DPIPE	19 - ENDGRF
2 - DBRK	11 - DPUMP	20 - EOVLV
3 - DCODF	12 - DTEE	21 - ERROR
4 - DCOMP	13 - DVLVE	22 - ESTGEN
5 - DCORE	14 - DVSSL	23 - ETEE
6 - DELTAR	15 - ECOMP	24 - EVALDF
7 - DFHT	16 - EDIT	25 - EXPAND
8 - DFILL	17 - ELGR	26 - FAXPOS
9 - DMPIT	18 - ENDDMP	27 - FEMOM

- Módulo 4 → TRACØ4.FOR (linhas 16107 a 20784)

1 - FF3D	8 - FNMESH	15 - GETCRV
2 - FILLX	9 - FPROP	16 - GRAF
3 - FILL1	10 - FROD	17 - GRFGET
4 - FILL2	11 - FTHEX (F)	18 - GRFPUT
5 - FILL3	12 - FWALL	19 - GVSSL1
6 - FLUX	13 - GAPHT	20 - GVSSL2
7 - FNDLP	14 - GETBIT (IF)	21 - HLS (F)
		22 - HOUT

- Módulo 5 → TRACØ5.FOR (linhas 20785 a 25642)

- |                |                |             |
|----------------|----------------|-------------|
| 1 - HTCOR      | 9 - ICHL (F)   | 17 - ICOMP  |
| 2 - HTPIPE     | 10 - ICMPR (F) | 18 - IGCORE |
| 3 - HTVSSL     | 11 - ICOMP     | 19 - IGFILL |
| 4 - HUNTS (LF) | 12 - ICORE     | 20 - IGPIPE |
| 5 - HVFILM     | 13 - IDEL (F)  | 21 - IGPRZR |
| 6 - HVS (F)    | 14 - IFILL     | 22 - IGPUMP |
| 7 - IACCUM     | 15 - IGACUM    | 23 - IGRAF  |
| 8 - IBRK       | 16 - IGBRAK    |             |

- Módulo 6 → TRACØ6.FOR (linhas 25643 a 31436)

- |               |             |             |
|---------------|-------------|-------------|
| 1 - IGSTGN    | 7 - INNER   | 13 - IPUMP  |
| 2 - IGTEE     | 8 - INPUT   | 14 - ISORT  |
| 3 - IGVLVE    | 9 - IOVLY   | 15 - ISTGEN |
| 4 - IGVSSL    | 10 - IPIPE  | 16 - ITEE   |
| 5 - INDEL (F) | 11 - IPRIZR | 17 - ITR1   |
| 6 - INIT      | 12 - IPROP  | 18 - IVLVE  |
|               |             | 19 - IVSSL  |

- Módulo 7 → TRACØ7.FOR (linhas 31437 a 36479)

- |                |             |             |
|----------------|-------------|-------------|
| 1 - JFIND (F)  | 12 - LPSET  | 23 - MZIRC  |
| 2 - JUNSOL     | 13 - MANAGE | 24 - NEWDLT |
| 3 - JVALUE (F) | 14 - MBN    | 25 - NXTCMP |
| 4 - J1D        | 15 - MFROD  | 26 - ORIEN  |
| 5 - KXOR (F)   | 16 - MFUEL  | 27 - OUTER  |
| 6 - LCMOVE     | 17 - MGAP   | 28 - OUT1D  |
| 7 - LEVEL      | 18 - MHTR   | 29 - OUT3D  |
| 8 - LININT     | 19 - MIXPRP | 30 - ØØTIM  |
| 9 - LOAD       | 20 - MPROD  | 31 - PACKIT |
| 10 - LPCOM     | 21 - MSTRCT | 32 - PATH   |
| 11 - LPRPL     | 22 - MWRX   | 33 - PIPE1  |
|                |             | 34 - PIPE1X |

CNEN  
DR

AUTOR: AAM/ *As*  
LSG/ *lio*  
MRSG/ *Regina*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

A5/07

PARTE:  
APÊNDICE A

REVISÃO:  
Ø

DATA:  
NOVEMBRO/88

- Módulo 8 → TRACØ8.FOR (linhas 36480 a 41645)

1 - PIPE2	7 - POST3D	13 - PRIZR1
2 - PIPE3	8 - PREINP	14 - PRIZR2
3 - PMPP	9 - PREP	15 - PRIZR3
4 - POLY (F)	10 - PREPER	16 - PRZR1X
5 - POST	11 - PREP1D	17 - PRZR3X
6 - POSTER	12 - PREP3D	18 - PSTEPQ
		19 - PUMPD

- Módulo 9 → TRACØ9.FOR (linhas 41646 a 46657)

1 - PUMPI	6 - PUMP3	11 - RCORE
2 - PUMPSR	7 - RACCUM	12 - RDCOMP
3 - PUMPX	8 - RBREAK	13 - RDCRDS
4 - PUMP1	9 - RCNTL	14 - RDCRVS
5 - PUMP2	10 - RCOMP	15 - RDDIN
		16 - RDLCM

- Módulo 10 → TRAC1Ø.FOR (linhas 46658 a 51863)

1 - RDLOOP	5 - READR	9 - RECORE
2 - RDREST	6 - REBRK	10 - REFILL
3 - REACCM	7 - RECNTL	11 - REPIPE
4 - READI	8 - RECOMP	12 - REPRZR
		13 - REPUMP

- Módulo 11 → TRAC11.FOR (linhas 51864 a 57317)

1 - RESTGN	6 - RFILL	11 - RPPH
2 - RETEE	7 - RHOLIQ	12 - RPRIZR
3 - REVLVE	8 - RKIN	13 - RPSCA
4 - REVSSL	9 - RODHT	14 - RPUMP
5 - RFDBK	10 - RPIPE	15 - RSTGEN

CNEN  
DR

AUTOR: AAM/ *Am*  
LSG/ *lio*  
MRSG/ *Regina*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88  
NOTA TÉCNICA

PAGINA:  
A6/07

PARTE:  
APÊNDICE A

REVISÃO:  
0

DATA:  
NOVEMBRO/88

- Módulo 12 → TRAC12.FOR (linhas 57318 a 62546)

1 - RTEE	10 - SETBD	19 - SGTEC
2 - RVLVE	11 - SETBID	20 - SHRINK
3 - RVSSL	12 - SETLCM	21 - SIGMA (F)
4 - SAVDB	13 - SETNET	22 - SLABHT
5 - SCLTBL	14 - SETPOW	23 - SLVLP
6 - SCMLCM	15 - SETPRP	24 - SMOVE
7 - SCMOVE	16 - SETSCM	25 - SMOVEN
8 - SECOND	17 - SGEFA	26 - SOLVE
9 - SEDIT	18 - SGESL	27 - SPLIT
		28 - SREBAL

- Módulo 13 → TRAC13.FOR (linhas 62547 a 67192)

1 - SRTLP	6 - STGEN1	11 - STGNIX
2 - SSWTCH	7 - STGEN2	12 - STGNIX
3 - STBME	8 - STGEN3	13 - STGN3X
4 - STDIR	9 - STGNA	14 - SVSTET
5 - STEADY	10 - STGNP	

- Módulo 14 → TRAC14.FOR (linhas 67193 a 72515)

1 - SVSET1	5 - TEE1	9 - TEMPL
2 - SVSET3	6 - TEE1X	10 - TF1D
3 - S1DPTR	7 - TEE2	11 - TF1DS
4 - TEEP	8 - TEE3	12 - TF1DS1

- Módulo 15 → TRAC15.FOR (linhas 72516 a 77089)

1 - ,TF1DS3	3 - TF3DI	5 - THCV (F)
2 - TF3DE	4 - THCL (F)	6 - THERMO

CNEN  
DR

AUTOR: AAM/ *As*  
LSG/ *Lio*  
MRSG/ *Regina*

GTT  
ORGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

A7/07

PARTE:  
APÊNDICE A

REVISÃO:  
0

DATA:  
NOVEMBRO/88

- Módulo 16 → TRAC16.FOR (linhas 77090 a 82257)

1 - TIMCHK	8 - TRIP	15 - VISCV
2 - TIMSTB	9 - TRISLV	16 - VLVE1
3 - TLOTVO	10 - TRPSET	17 - VLVE2
4 - TMSFB	11 - UNPKIT	18 - VLVE3
5 - TRAC16\$MAIN	12 - VALUE	19 - VOLFA
6 - TRANS	13 - VELCK	20 - VOLV
7 - TRCE	14 - VISCL	21 - VSCON
		22 - VSCON

- Módulo 17 → TRAC17.FOR (linhas 82258 a 87954)

1 - VSSL1	8 - WCORE	15 - WRCLM
2 - VSSL2	9 - WFILL	16 - WRSLP
3 - VSSL3	10 - WIARR	17 - WSTGEN
4 - WACCUM	11 - WPIPE	18 - WTEE
5 - WARRAY	12 - WPRIZR	19 - WVLVE
6 - WBREAK	13 - WPUMP	20 - WVSSL
7 - WCOMP	14 - WRCOMP	21 - XACCUM

CNEN  
DR

AUTOR: AAM/ *As*  
LSG/ *Lio*  
MRSG/ *Regina*  
GTT  
GAC

ÓRGÃO

DOCUMENTO: Nº 02/88

NOTA TÉCNICA

PAGINA:

B1/13

PARTE:

APÊNDICE B

REVISÃO:

0

DATA:

NOVEMBRO/88

APÊNDICE B

ORGANIZAÇÃO DO PROGRAMA FONTE

B.1 - DESCRIÇÃO DO JCL

1 - JCL para uma execução simples :

```
$ SET DEF SYSSYSDEVICE:[DR.REGINA]
$ DEF/USER FOR001 dados.DAT      ! TRACIN --> dados de entrada
$ DEF/USER FOR005 dados.AUX      ! TRCINP --> dados de entrada transformados
$ DEF/USER FOR006 dados.LIS      ! TRCOUT --> saída impressa
$ DEF/USER FOR007 dados.MSG      ! TRCMMSG --> saída de mensagens
$ RUN TRACPF1
$ PRINT dados.LIS
$ PRINT dados.MSG
```

2 - JCL para uma execução gravando "RESTART" :

```
$ SET DEF SYSSYSDEVICE:[DR.REGINA]
$ DEF/USER FOR001 dados.DAT      ! TRACIN --> dados de entrada
$ DEF/USER FOR005 dados.AUX      ! TRCINP --> dados de entrada transformados
$ DEF/USER FOR006 dados.LIS      ! TRCOUT --> saída impressa
$ DEF/USER FOR007 dados.MSG      ! TRCMMSG --> saída de mensagens
$ DEF/USER FOR012 arg-restart.RST ! TRCDMP --> saída para restart
$ RUN TRACPF1
$ PRINT dados.LIS
$ PRINT dados.MSG
```

3 - JCL para uma execução lendo "RESTART" :

```
$ SET DEF SYSSYSDEVICE:[DR.REGINA]
$ DEF/USER FOR001 dados.DAT      ! TRACIN --> dados de entrada
$ DEF/USER FOR005 dados.AUX      ! TRCINP --> dados de entrada transformados
$ DEF/USER FOR006 dados.LIS      ! TRCOUT --> saída impressa
$ DEF/USER FOR007 dados.MSG      ! TRCMMSG --> saída de mensagens
$ DEF/USER FOR013 arg-restart.RST ! TRCRST --> dados do restart
$ RUN TRACPF1
$ PRINT dados.LIS
$ PRINT dados.MSG
```

4 - JCL para uma execução lendo e gravando "RESTART" :

```
$ SET DEF SYSSYSDEVICE:[DR.REGINA]
$ DEF/USER FOR001 dados.DAT      ! TRACIN --> dados de entrada
$ DEF/USER FOR005 dados.AUX      ! TRCINP --> dados de entrada transformados
$ DEF/USER FOR006 dados.LIS      ! TRCOUT --> saída impressa
$ DEF/USER FOR007 dados.MSG      ! TRCMMSG --> saída de mensagens
$ DEF/USER FOR012 arg-rest-novo.RST ! TRCDMP --> saída para novo restart
$ DEF/USER FOR013 arg-rest-ant.RST ! TRCRST --> dados do restart anterior
$ RUN TRACPF1
$ PRINT dados.LIS
$ PRINT dados.MSG
```

5 - Saída para gráficos :

Para utilizar a saída para gráficos basta acrescentar a qualquer um dos JCL's anteriores a seguinte linha :

```
$ DEF/USER FOR011 arg-plot.DAT    ! TRCGRF --> dados para gráficos
```

B.2 - TRACFF1 - MAPA DE CHAMADA DAS ROTINAS

Entrada	rotina	chamada por				
ACCIX	(ACCIX)	) ACCUM1				
ACCND	(ACCND)	) ACCUM1	ACCUM2	ACCUM3	IACCUM	
ACCUM1	(ACCUM1)	) PREP10				
ACCUM2	(ACCUM2)	) OUT10				
ACCUM3	(ACCUM3)	) POST				
ALLBLK	(ALLBLK)	) FREEINP				
AMNSH	(AMNSH)	) FENOM	TF30E			
ASIGN	(ASIGN)	) INPUT				
AXPOW	(AXPOW)	) CORE3	CCREC1	COREC3	ICORE	
		) IVSSL	VSSL1			
SACIT	(SACIT)	) VSSL2				
BFALOC	(BFALOC)	) DNPIT	IGRAF	ROREST		
BFCLS	(BFCLS)	) ENDDMP	ENDGRF			
BFIN	(BFIN)	) ROREST	REACCM	REBRK	RECOMP	
		) RECORE	REFILL	REPIPE	REPRZR	
		) REPUMP	RESTGN	RETEE	REVLVE	
		) REVSSL				
BFOUT	(BFOUT)	) DERK	DCOMP	DCORE	DFILL	
		) DNPIT	DPIPE	DPUMP	DTEE	
		) DULVE	DVSSL	GRAF	IGRAF	
BKMON	(BKMON)	) ACCUM1	COREC1	PIPE1	PRIZR1	
		) PUMP1	STOEN1	TEE1	VLVE1	
BKSMON	(BKSMON)	) BKRCF				
BKSTB	(BKSTB)	) POSTEF				
BKSUB	(SOLVE)	)				
BREAK1	(BREAK1)	) PREP10				
BREAK2	(BREAK2)	) OUT10				
BREAK3	(BREAK3)	) POST				
BREAKX	(BREAKX)	) BREAK1				
BREBAL	(BREBAL)	) VSSL2				
COHEX	(COHEX)	) DELTAR				
CHED	(CHED)	) INNER				
CHEN	(CHEN)	) HICOR				
CHF	(CHF)	) HICOR				
CHF1	(CHF1)	) CHF				
CHCPT	(SETPIT)	) VELCK				
CHKR	(CHKR)	) RVSSL				
CHKE	(CHKE)	) TF10G1				
CHVSSL	(CHVSSL)	) ICOMP				
CLEAN	(CLEAN)	) ERROR	TRACFF1			
CLEAR	(CLEAR)	) HOUT	ICOMP	INIT	INPUT	
		) LOAD	LFSET	OUT10	GCT30	
		) OUTER	POST	PREP10	PREPER	
		) RCNTL	RCOMP	RCORE	RDCOMP	
		) RDDIX	RDLOC7	RECCRE	REPUMP	
		) REVSSL	RVSSL	SIDPTR	SCMLCH	
		) SEDIT	TRACFF1	TACE	VSSL1	
		) VSSL2				
CLOCK	(CLOCK)	) SECOND				
CONPI	(CONPI)	) ICORE	IPIFE	IPUMP	ISTSEN	

TRACPF1 - MAPA DE CHAMADA DAS ROTINAS (continuação)

Entrada	rotina	chamada por	ITEE	IVLVE		
CONC	(CONC)	)	BKSTB	FF3D		
CONSTB	(CONSTB)	)	ACCUM3	COREC3	PIPE3	PRIZ3
		)	PUMP3	STGEN3	TEE3	VLVE3
CORE1	(CORE1)	)	VSSL1			
CORE3	(CORE3)	)	VSSL3			
COREC1	(COREC1)	)	PREP1D			
COREC2	(COREC2)	)	OUT1D			
COREC3	(COREC3)	)	POST			
CPLL	(CPLL)	)	FPROP			
CPV	(CPV)	)				
CPV1	(CPV1)	)	FPROP			
CTAIN1	(CTAIN1)	)	PREP1D			
CTAIN2	(CTAIN2)	)	OUT1D			
CTAIN3	(CTAIN3)	)	POST			
CVSSL	(CVSSL)	)	WCORP			
CYLHT	(CYLHT)	)	POSTER	STGN3X		
DATE	(DATE)	)				
DBRK	(DBRK)	)	DMPIT			
DCORF	(DCORF)	)	LOAD	READI	REACK	
DCORP	(DCORP)	)	DCORE	DMPIT	DPIPE	DPUMP
		)	DTEE	DVLVE		
DCORE	(DCORE)	)	DMPIT			
DELTA	(DELTA)	)	GAFT			
DFHT	(DFHT)	)	HTCOR			
DFILL	(DFILL)	)	DMPIT			
DMPIT	(DMPIT)	)	ERRR	PSTEP8	TINCHK	TRACPF1
		)	TRANS			
DPIPE	(DPIPE)	)	DMPIT			
DPUMP	(DPUMP)	)	DMPIT			
DTEE	(DTEE)	)	DMPIT			
DVLVE	(DVLVE)	)	DMPIT			
DVSSL	(DVSSL)	)	DMPIT			
ECORP	(ECORP)	)	WACCUM	WBEAK	WCORE	WFILL
		)	WPIPE	WPRIER	WPUMP	WSTGEN
		)	WTEE	WVLVE		
EDIT	(EDIT)	)	ERRR	HOUT	PSTEP9	STEADY
		)	TINCHK	TRANS		
ELGR	(ELGR)	)	IACCUM	ICORP	IPIPE	IPRIER
		)	IFUMP	ISTGEN	ITEE	IVLVE
ENDORP	(ENDORP)	)	CLEAN			
ENDORF	(ENDORF)	)	CLEAN			
EOVLY	(EOVLY)	)	CLEAN	DMPIT	EDIT	ERRR
		)	GRAF	INIT	INPUT	LPSET
		)	OUTER	POST	PREP	
ERROR	(ERROR)	)	BFIN	BFOUT	BREAKX	CH2D
		)	CHF	CHKR	CVSSL	CCRE3
		)	COREC1	COREC3	CTAIN1	CTAIN2
		)	CTAIN3	DMPIT	ENDORP	ENDORF
		)	EOVLY	FILLX	FNOLP	GETBIT

TRACPF1 - MAPA DE CHAMADA DAS ROTINAS (continuação)

Entrada	rotina	chamada por	GRAF	GRFPUT	HOUT	ICOMP
			ICORE	IGRAF	INPUT	IOVLY
			IULVE	IUSSL	JFIND	LOAD
			LPCON	LPSET	MANAGE	RSTRCT
			MXTCMP	ORIENT	OUTID	OUT30
			CUTER	PATH	PIPE1	PGST
			POST30	POSTER	PREIMP	PREPID
			PREP30	PUMP0	PURPSR	RBREAK
			RCNTL	RCOMP	RCORE	RDCOMP
			RDDIM	RLOOP	RREST	REACCH
			READ1	READR	REBRK	RECNTL
			RECORE	REFILL	REPIPE	REPZZZ
			RIPUMP	RESTGN	RETEE	REVLVE
			REVSSL	RIFILL	RKIN	RPPH
			RIPUMP	RSTGEN	RVLVE	RUSSL
			SCHLCH	SETBIT	SETPON	STEADY
			STGN0X	SUSET3	TEELX	TEML
			THERMO	TIMCHK	TINSTP	TRACPF1
			TRCE	TRIP	TRFSET	VLVEX
			VSSL1			
ESTGEN	(ESTGEN)	)	ISTGEN	STGEN3		
EITE	(EITE)	)	IITE	ITE3		
EVALDF	(EVALDF)	)	ACOUN3	CORE3	COREC3	PIFE3
			PRIZR3	PUMP3	STGEN3	TEE3
			VLVE3	VSSL3		
EXPAND	(EXPAND)	)	CORE1	COREC1		
FAXPOS	(FAXPOS)	)	RVLVE	VLVEX		
FEMCH	(FEMCH)	)	PREPER			
FF30	(FF30)	)	VSSL3			
FILL1	(FILL1)	)	PREPID			
FILL2	(FILL2)	)	OUTID			
FILL3	(FILL3)	)	POST			
FILLX	(FILLX)	)	FILL1			
FLUX	(FLUX)	)	PREPER			
FINDP	(FINDP)	)	RLOOP			
FNHSH	(FNHSH)	)	CORE1	COREC1		
FF30F	(FF30F)	)	BREAKX	FEMCH	FILLX	TEE3
			IFILL	IPROP	IUSSL	POSTER
			TFID31	TF3EE	VSSL3	
F300	(F300)	)	CORE3	COREC3		
FTHEX	(FTHEX)	)	DELTA			
FWALL	(FWALL)	)	PREPER			
GAFT	(GAFT)	)	F300			
GETBIT	(GETBIT)	)	BREAK1	FILL1	FLUX	ITR1
			POSTER	READ1	STGN2	TFID3
			TFID31	TFID33	TF3DE	TF331
			VELCK	VSSL2		
GETCV	(GETCV)	)	PUMP0			
GRAF	(GRAF)	)	ERROR	PSTEP0	TIMCHK	
GRFGET	(GRFGET)	)	GRAF	IGRAF		

TRACFF1 - MAPA DE CHAMADA DAS ROTINAS (continuação)

Entrada	rotina	chamada por				
GRFPUT	(GRFPUT)	)	IGACUM	IGBRAX	IGCOMP	IGCORE
			IGFILL	IGPIPE	IGFRZR	IGPUMP
			IGRAF	IGSTON	IGTEE	IGVLVE
			IGVSSL			
GVSSL1	(GVSSL1)	)	FF30			
GVSSL2	(GVSSL2)	)	VSSL3			
MLS	(MLS)	)	FPROP	HTCOR		
HOUT	(HOUT)	)	STEADY	TRANS		
HTCOR	(HTCOR)	)	CORE1	COREC1	HTPIPE	HTVSSL
HTPIPE	(HTPIPE)	)	PREPER	STGNIX		
HTVSSL	(HTVSSL)	)	VSSL1			
HUNTS	(HUNTS)	)	PREINP			
HVFILM	(HVFILM)	)	HTCOR			
HVS	(HVS)	)	FPROP			
IACUM	(IACUM)	)	ICOMP			
IERR	(IERR)	)	ICOMP			
ICHL	(ICHL)	)	HUNTS	IDEL	INDEL	PREINP
			VALUE			
ICNFR	(ICNFR)	)	CONSTB	INNER	PREPER	SAVBO
			SETB			
ICOMP	(ICOMP)	)	INIT			
ICORE	(ICORE)	)	ICOMP			
IDEL	(IDEL)	)	HUNTS	PREINP		
IFILL	(IFILL)	)	ICOMP			
IGACUM	(IGACUM)	)	IGRAF			
IGBRAX	(IGBRAX)	)	IGRAF			
IGCOMP	(IGCOMP)	)	IGACUM	IGCORE	IGPIPE	IGFRZR
			IGPUMP	IGSTON	IGTEE	IGVLVE
IGCORE	(IGCORE)	)	IGRAF			
IGFILL	(IGFILL)	)	IGRAF			
IGPIPE	(IGPIPE)	)	IGRAF			
IGFRZR	(IGFRZR)	)	IGRAF			
IGPUMP	(IGPUMP)	)	IGRAF			
IGRAF	(IGRAF)	)	INIT			
IGSTON	(IGSTON)	)	IGRAF			
IGTEE	(IGTEE)	)	IGRAF			
IGVLVE	(IGVLVE)	)	IGRAF			
IGVSSL	(IGVSSL)	)	IGRAF			
INDEL	(INDEL)	)	ALL2LK	PREINP		
INIT	(INIT)	)	TRACFF1			
INNER	(INNER)	)	ACCUM2	COREC2	PIPE2	FRZR2
			PUMP2	STGEN2	TEE2	VLVE2
INPUT	(INPUT)	)	TRACFF1			
IOPLY	(IOPLY)	)	CLEAN	DN?IT	EDIT	GRAF
			INIT	INPUT	LPSET	OUTER
			POST	PREP		
IPIPE	(IPIPE)	)	ICOMP			
IFRZR	(IFRZR)	)	ICOMP			
IFROP	(IFROP)	)	IACUM	ICORE	IPIPE	IFRZR
			IFUMP	ISTGEN	ITEE	IVLVE

TRACPF1 - MAPA DE CHAMADA DAS ROTINAS (continuação)

Entrada	rotina	chamada por				
IPUMP	(IPUMP)	ICOMP				
ISORT	(ISORT)	INPUT				
ISTGEN	(ISTGEN)	ICOMP				
ITEE	(ITEE)	ICOMP				
ITR1	(ITR1)	VSSL2				
IULVE	(IULVE)	ICOMP				
IUSSL	(IUSSL)	CIUSSL				
JID	(JID)	ACCMS0	ACCUM1	BREAK1	BREAK2	
		BREAK3	CONSTB	FILL1	FILL2	
		FILL3	IBAK	IFILL	INNER	
		ISTGEN	PRIZR2	SETGD	SIGEX	
		TEE1X				
JFIND	(JFIND)	CIUSSL	IACCUM	IERK	ICORE	
		IFILL	IPIPE	IPRIZR	IPUMP	
		ISTEEN	ITEE	IULVE		
JURSQL	(JURSQL)	IACCUM	ICORE	IPIPE	IPRIZR	
		IFUMP	ISTGEN	ITEE	IULVE	
JVALUE	(JVALUE)	PREINP	VALUE			
KXOR	(KXOR)	READI				
LCHOVE	(LCHOVE)	RUSL	VSSL1			
LEVEL	(LEVEL)	FEXOM				
LININT	(LININT)	BREAKX	COTRFX	CORE2	CORE3	
		COREC3	FILLX	NZIRC	PIPE1	
		PUMP0	PUMPO	PUMPX	RKIN	
		TEE1X	VLVEX	VSSL1		
LOAD	(LOAD)	INPUT	RBREAK	RCOMP	RCORE	
		RDCV3	PFILL	PIPE	RPUMP	
		RSTGEN	RTEE	PULVE	RUSL	
LPCON	(LPCON)	LPSET				
LPFL	(LPFL)	LPSET				
LPSET	(LPSET)	STEADY				
MANAGE	(MANAGE)	CORE1	CORE3	DVSL	GRAF	
		IGRAF	IUSSL	CLT30	PFEX	
		SUBSET	VSSL1	VSSL2	VSSL2	
		WVSSL				
MBN	(MBN)	MFROD				
MFROD	(MFROD)	CORE1	CORE3	HTVSL		
MFUEL	(MFUEL)	MFROD				
MGAF	(MGAF)	GAFT				
MHTR	(MHTR)	MFROD				
MIXFAP	(MIXFAP)	BREAKX	FILLX	IERK	IFILL	
		IPRCP				
MPRCP	(MPRCP)	PREPR				
MSTRCT	(MSTRCT)	MFROD	MPRCP			
MURX	(MURX)	FROD				
MZIRC	(MZIRC)	MFROD				
NEWOLT	(NEWOLT)	LINSTP				
NXTCHP	(NXTCHP)	RDCOMP				
OGTIN	(OGTIN)	TIDCHK	TRACPF1			
OF1123	(SETBIT)	POSTER				

TRACPE1 - MAPA DE CHAMADA DAS ROTINAS (continuação)

Entrada	rotina	chamada por			
OFFBIT	(SETBIT)	) ITR1	TF1DS	TF1DS3	TF3DE
		) VELCK			
ORIENT	(ORIENT	) STGNP	TEEP		
OUT1D	(OUT1D	) OUTER			
OUT3D	(OUT3D	) OUTER			
OUTER	(OUTER	) HOUT			
PACKIT	(PACKIT	) GRAF	IGRAF		
PATH	(PATH	) FRDLP	TRCE		
PIPE1	(PIPE1	) PREP1D			
PIPE1X	(PIPE1X	) PIPE1			
PIPE2	(PIPE2	) OUT1D			
PIPE3	(PIPE3	) POST			
PNFP	(PNFP	) LPCCN			
POLY	(POLY	)			
POST	(POST	) HOUT	STEADY	TRANS	
POST3D	(POST3D	) FOST			
POSTER	(POSTER	) ACCUM3	COREC3	PIPE3	PRIZR3
		) PUMP3	STGEN3	TEE3	VLVE3
PREINP	(PREINP	) INPUT			
PREP	(PREP	) STEADY	TRANS		
PREP1D	(PREP1D	) PREP			
PREP3D	(PREP3D	) PREP			
PREPER	(PREPER	) ACCUM1	COREC1	PIPE1	PRIZR1
		) PUMP1	STGEN1	TEE1	VLVE1
PRIZR1	(PRIZR1	) PREP1D			
PRIZR2	(PRIZR2	) OUT1D			
PRIZR3	(PRIZR3	) POST			
PRIZR1X	(PRIZR1X	) PRIZR1			
PRIZR3X	(PRIZR3X	) PRIZR3			
PRSTEP	(PRSTEP	) STEADY	TRANS		
PUMP1	(PUMP1	) PREP1D			
PUMP2	(PUMP2	) OUT1D			
PUMP3	(PUMP3	) POST			
PUMP3D	(PUMP3D	) PUMEX	RFPH		
PUMP1	(PUMP1	) POCRV3			
PUMP3D	(PUMP3D	) PREPER			
PUMPA	(PUMPA	) PUMPA			
RACCUM	(RACCUM	) RDCOMP			
RBREAK	(RBREAK	) RDCOMP			
RCTL	(RCTL	) INPUT			
RCOMP	(RCOMP	) RACCUM	RCCRE	RPIPE	RPRIZR
		) RFUMF	RSTGEN	RTEE	RVLVE
RCCRE	(RCCRE	) RDCOMP			
RCCODI	(RCCODI	) LOAD			
RDCOMP	(RDCOMP	) INPUT			
RDCRDS	(RDCRDS	) STEADY			
RDCRV3	(RDCRV3	) RPUMP			
RDDIM	(RDDIM	) RPUMP			
RDLCH	(RDLCH	) BF IN	CVSSL	CVSSL	CBRK
		) DCONP	DFILL	DMPT	DVSSL

TRACPF1 - MAPA DE CHAMADA DAS ROTINAS (continuação)

Entrada	rotina	chamada por			
			GRAF	IBRK	ICOMP
			IGRAF	MANAGE	OUT10
			PMP	POST	POST30
			PREP30	RDLOOP	RPPH
			SETPOW	SETPRF	STGNA
			SUSET	SUSET3	TEEP
			WCOMP		VSCON
RDLOOP	(RDLOOP	)	INPUT		
RDREST	(RDREST	)	INPUT		
REACCH	(REACCH	)	RDREST		
READI	(READI	)	INPUT	RACCUH	RBREAK
			RCORE	RDDIN	RDLOOP
			RPIPE	RPRIZR	RPUMP
			RTEE	RVLVE	RVSSL
READR	(READR	)	INPUT	RREAK	RCNTL
			RDLOOP	RFILL	RCORE
			RPUMP	RSTGEN	RPIPE
			RVSSL	TINSTP	RTEE
REBRK	(REBRK	)	RDREST		
RECNTL	(RECNTL	)	RDREST		
RECOMP	(RECOMP	)	REACCH	RECORE	REPIPE
			REPUMP	RESTGN	RETEE
RECORE	(RECORE	)	RDREST		
REFILL	(REFILL	)	RDREST		
REPIPE	(REPIPE	)	RDREST		
REFRZR	(REFRZR	)	RDREST		
REPUMP	(REPUMP	)	RDREST		
RESTGN	(RESTGN	)	RDREST		
RZTEE	(RZTEE	)	RDREST		
REVOLVE	(REVOLVE	)	RDREST		
RVSSL	(RVSSL	)	RDREST		
RFDEX	(RFDEX	)	DCRECI	VSSL1	
RFILL	(RFILL	)	RDCOMP		
RHOL10	(RHOL10	)	HLS	THERMO	
RHSET	(RHSET	)	PACKIT	UNPKIT	
RI0	(RI0	)			
RKIN	(RKIN	)	CCRECI	VSSL1	
RKCHT	(RKCHT	)	FR00		
RPIPE	(RPIPE	)	RDCOMP		
RPPH	(RPPH	)	LFAPL		
RPRIZR	(RPRIZR	)	RDCOMP		
RPSGA	(RPSGA	)	LFAPL		
RPUMP	(RPUMP	)	RDCOMP		
RSTGEN	(RSTGEN	)	RDCOMP		
RTEE	(RTEE	)	RDCOMP		
RVLVE	(RVLVE	)	RDCOMP		
RVSSL	(RVSSL	)	RDCOMP		
RWRLCH	(RWRLCH	)	RCORE	RVSSL	
RXCPR	(RXCPR	)	RACCUH	RCORE	RPIPE
			RPUMP	RSTGEN	RTEE
					RVLVE

TRACPF1 - MAPA DE CHAMADA DAS ROTINAS (continuação)

Entrada	rotina	chamada por			
RXCORR	(RXCORR)	) RDCOMP			
RXCORR	(RXCORR)	) RCORE			
RXPTPS	(RXPTPS)	) RDCOMP			
RXREAD	(RXREAD)	) RCORE	RXCMPR	RXCORR	RXCORR
		) RXVSGR	RXVSLR	RXVSRR	
RXVSGR	(RXVSGR)	) RVSSL			
RXVSLR	(RXVSLR)	) RVSSL			
RXVSRR	(RXVSRR)	) RVSSL			
S10PTR	(S10PTR)	) RACCUH	RBREAK	RCORE	REACCH
		) REBRK	RECCRE	REFILL	REFIPE
		) REPRZR	REPUMP	RESTGN	RETEE
		) REVULV	RFILL	RPIPE	RPRIZR
		) RPUMP	RSTGEN	RTEE	RVLVE
SAV3D	(SAV3D)	) ACCUM1	ACCUM3	COPEC1	COREC3
		) PIPE1	PIPE3	PRIZR1	PRIZR3
		) PUMP1	PUMP3	STGEN1	STGEN3
		) TEE1	TEE3	VLVE1	VLVE3
SCLT3L	(SCLT3L)	) RBREAK	RCORE	RFILL	RPIPE
		) RPUMP	RTEE	RVSSL	
SCHLCH	(SCHLCH)	) RACCUH	REACCH	REPIPE	REPRZR
		) REPUMP	RESTGN	RETEE	REVULV
		) RPIPE	RPRIZR	RPUMP	RSTGEN
		) RTEE	RVLVE		
SCMOVE	(SCMOVE)	) BREAK1	COPEC1	COREC3	FILL1
		) IACCUH	IBRK	ICOMP	ICORE
		) IFILL	INFUT	IPIPE	IPRIZR
		) IPUMP	ISTGEN	ITEE	IULVE
		) OUT1D	POSTER	RCOMP	REPUMP
		) SAV3D	VSSL1	VSSL2	VSSL3
SECOND	(SECOND)	) DMPIT	EDIT	ERRCR	PSTEP9
		) TINCH1	TRACPF1		
SEDTT	(SEDTT)	) EDIT	PSTEP9		
SET3D	(SET3D)	) COPEC1	COREC3	ICORE	IFIFE
		) IPRIZR	IPUMP	ISTGEN	ITEE
		) IULVE	IFIFE1	IFIFE3	FRIZR1
		) PRIZR3	PUMP1	PUMP3	STGEN1
		) STGEN3	TEE1	TEE1	VLVE1
		) VLVE2			
SET3IT	(SET3IT)	) POSTER	TF103	TF1031	TF1033
		) TFODE	VELCK	VSSL2	
SETIME	(SETIME)	) TRACPF1			
SETLCH	(SETLCH)	) IGRAF	INFUT	RUBREAK	RCORE
		) REBRK	RECCRE	REFILL	REVSSL
		) RFILL	RVSSL	SCHLCH	TRACPF1
SETNET	(SETNET)	) ICOMP			
SETFOW	(SETFOW)	)			
SETPRP	(SETPRP)	) FNDLP	LPSET		
SETSCH	(SETSCH)	) IOVLY			
SGEFA	(SGEFA)	) BKSSTB	ITR1	OUT3D	OUTER
		) POST	FRCP10	TF103	VSSL2

CNEN  
DR

AUTOR: AAM/ *Am*  
LSG/ *Lio*  
MRSRG/ *Regina*  
GTT  
GAC  
ÓRGÃO

DOCUMENTO: Nº 02/88

PAGINA:

B11/13

NOTA TÉCNICA

PARTE:  
APÊNDICE B

REVISÃO:  
Ø

DATA:  
NOVEMBRO/88

TRACPF1 - MAPA DE CHAMADA DAS ROTINAS (continuação)

Entrada	rotina	chamada por			
SGESL	(SGESL)	) BKSSTB	ITR1	OUT3D	OUTER
		) POST	PREP10	TF10S	VSSL2
SGTBC	(SGTBC)	) STGEN1			
SHRINK	(SHRINK)	) CORE1	COREC1		
SIGNA	(SIGNA)	) FPRCP			
SLABHT	(SLABHT)	) VSSL3			
SLVLP	(SLVLP)	) LPSET			
SMOVE	(SMOVE)	) PREINF	SMOVN		
SMOVN	(SMOVN)	) PREINP			
SOLVE	(SOLVE)	) TF301			
SPLIT	(SPLIT)	) GETCRV			
SREBAL	(SREBAL)	) OUT3D	VSSL2		
SRTL	(SRTL)	) INPUT			
SSWTCN	(SSWTCN)	) TINCHK			
STBME	(STBME)	) CONST3			
STDIR	(STDIR)	) VSSL2			
STEADY	(STEADY)	) TRACPF1			
STGEN1	(STGEN1)	) PREP10			
STGEN2	(STGEN2)	) OUT10			
STGEN3	(STGEN3)	) PCOT			
STGENX	(STGENX)	) STGEN1			
STGENY	(STGENY)	) STGEN3			
STGNA	(STGNA)	) SETFRP			
STGNF	(STGNF)	) LFCOM			
STGNTX	(STGNTX)	) STGEN1			
SUSET	(SUSET)	) FREP			
SUSET1	(SUSET1)	) SUSET			
SUSET3	(SUSET3)	) SUSET			
TEE1	(TEE1)	) PREP10			
TEE1X	(TEE1X)	) TEE1			
TEE2	(TEE2)	) OUT10			
TEE3	(TEE3)	) PCOT			
TEEP	(TEEP)	) LFCOM			
TEML	(TEML)	) LFCOM			
TF10	(TF10)	) INVER			
TF100	(TF100)	) TF10			
TF1001	(TF1001)	) TF10			
TF1003	(TF1003)	) TF10			
TF30E	(TF30E)	) VSSL2			
TF30I	(TF30I)	) VSSL2			
THCL	(THCL)	) FPROP			
THCV	(THCV)	) FRACP			
THERMO	(THERMO)	) BREAKX	CHOKE	FF30	FILLX
		) IBRK	IFILL	IPROP	IVSSL
		) PGSTER	TEMPL	TF10	TF10S3
		) TF30I	VSSL2	VSSL3	
TINCHK	(TINCHK)	) STEADY	TRANS		
TINSTP	(TINSTP)	) STEADY	TRANS		
TLOTVO	(TLOTVO)	) ISTGEN	STGN3X		
THSFB	(THSFB)	) HTCCP			

TRACPF1 - MAPA DE CHAMADA DAS ROTINAS (continuação)

Entrada	rotina	chamada por			
TRACPF1	(TRACPF1)	)			
TRANS	(TRANS)	)	TRACPF1		
TRCE	(TRCE)	)	FNDLP		
TRIP	(TRIP)	)	CORE1	CORE3	COREC1
			FILLX	PUMPSR	RKIN
			TIMSTP	VLVEX	VSSL1
					WUPMP
TRISLU	(TRISLU)	)	ROOHT	SLAGHT	
TRPSET	(TRPSET)	)	PREP		
URPKIT	(URPKIT)	)			
VALUE	(VALUE)	)	FREIMP		
VELCK	(VELCK)	)	VSSL2		
VISCL	(VISCL)	)	FPROP		
VISCV	(VISCV)	)	FPROP		
VLVE1	(VLVE1)	)	PREP10		
VLVE2	(VLVE2)	)	OUT10		
VLVE3	(VLVE3)	)	POST		
VLVEX	(VLVEX)	)	VLVE1		
VOLFA	(VOLFA)	)	IACCUM	ICORE	IPIPE
			IPUMP	ISTGEN	ITEE
					IPRIZR
VOLV	(VOLV)	)	PREPER		
VSDOM	(VSDOM)	)	LFSET		
VSSL1	(VSSL1)	)	PREP30		
VSSL2	(VSSL2)	)	OUT30		
VSSL3	(VSSL3)	)	POST30		
WACCUM	(WACCUM)	)	WCOMP		
WARRAY	(WARRAY)	)	ELGR	IVSSL	PUMPX
			RCOMP	RCORE	POCRVS
			RECORE	REFILL	REPIPF
			RETEE	REVLVE	REVSGL
			RPIPE	RPUMP	RSTGEN
			RVLVE	RVSSL	RXCORE
			RXVRR	SCLTSL	WCOMP
					WVSSL
WBREAK	(WBREAK)	)	WCOMP		
WCOMP	(WCOMP)	)	EDIT		
WCORE	(WCORE)	)	WCOMP		
WFILL	(WFILL)	)	WCOMP		
WIARR	(WIARR)	)	WCOMP	RCORE	RDDIA
			REVSGL	RESTGEN	RVSSL
			RAVSGR	RAVERR	WCOMP
WPIPE	(WPIPE)	)	WCOMP		
WPRIZR	(WPRIZR)	)	WCOMP		
WPUMP	(WPUMP)	)	WCOMP		
WRCOMP	(WRCOMP)	)	FEACCM	RECORE	REPIPE
			REPUMP	RESTGEN	RECTE
WRLCM	(WRLCM)	)	EFOUT	CIVSSL	IACCUM
			ICORE	IFILL	IGPAF
			IPRIZR	IPUMP	ISTGEN
			IULVE	MANAGE	OUT10
			POST	POST30	PREP10
			RACCUM	RBREAK	RCORE
					REACCM

CNEN  
DR

AUTOR: AAM/ *A*  
LSG/ *lio*  
MRSR/ *Regina*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

B13/13

PARTE:

REVISÃO:

DATA:

APENDICE B

0

NOVEMBRO/88

TRACFF - MAPA DE CHAMADA GAS ROTINAS (continuação)

Entrada	rotina	chamada por
		REBR
		REPRZ
		REVLVE
		RPPH
		RSTGEN
		SCHLCK
		RECOGE
		REPUMP
		REVSSL
		RPRIZR
		RTEE
		SETPOW
		REFILL
		RESTGN
		RFILL
		RPSGA
		RVLVE
		SETPRP
		REPIPE
		RETEE
		RPIPE
		RPUMP
		RVSSL
		STGNA
VRSLP	(VRSLP )	FNDLP
WSTGEN	(WSTGEN )	WCOMP
WTEE	(WTEE )	WCOMP
WVLVE	(WVLVE )	WCOMP
WVSSL	(WVSSL )	WVSSL
XACCUH	(XACCUH )	RDREST
XBREAK	(XACCUH )	RDREST
XCOGEO	(XACCUH )	RECOGE
XCOPOD	(XACCUH )	RECOGE
XFILL	(XACCUH )	REREST
XPIPE	(XACCUH )	RDREST
XPRIZR	(XACCUH )	RDREST
XPUMP	(XACCUH )	RDREST
XSTGEN	(XACCUH )	RDREST
XTEE	(XACCUH )	RDREST
XVLVE	(XACCUH )	RDREST
XVSCW	(XACCUH )	
XVSGEO	(XACCUH )	REVSSL
XVSLV	(XACCUH )	REVSSL
XVSLVL	(XACCUH )	
XVSRCD	(XACCUH )	REVSSL

CNEN  
DR

AUTOR: AAM/ *A*  
LSG/ *li*  
MRSG/ *Regina*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº /88

PAGINA:

NOTA TÉCNICA

C1/31

PARTE:

REVISÃO:

DATA:

APÊNDICE C

0

NOVEMBRO/88

APÊNDICE C

CASO EXEMPLO 1 - "FOUR PIPE HEATED WALL  
BLÓWDOWN - FIVE NODES IN HEATED WALL,  
H - 10 POST CHF HT MOD"

CNEN  
DR

AUTOR: AAN/ *Ar*  
LSG/ *Liv*  
MRS/ *Regina*  
GTT  
GAC  
ÓRGÃO

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C2/31

PARTE:  
APÊNDICE C

REVISÃO:  
0

DATA:  
NOVEMBRO/88

THIS CODE WAS CREATED ON 08/10/81 FROM TRAC VERSION, A.0 .  
\*\* CONVERTED TO IBM-FORTRAN BY GRS 10/15/81 \*\*  
\*\* UPDATED TO VERSION A.1 BY GRS 11/02/81 \*\*  
\*\* UPDATED TO VERSION 7.0 BY GRS 01/14/82 \*\*  
\*\* UPDATED TO VERSION 7.4E - GRS 04/14/82 \*\*  
\*\* UPDATED TO VERSION 7.6 BY GRS 07/21/82 \*\*

EXECUTED ON : 17-NOV-8 TIME : 0

NUMBER OF TITLE CARDS IS 2  
FOUR PIPE HEATED WALL BLOWDOWN  
FIVE NODES IN HEATED WALL, N=10 POST CNF HT MOD

)) GRAPHIC FILE IN BOTH POLYLOT (FT10F001) AND TRAC POST PROCESSOR FORMAT (FT11F001) REQUESTED ((

)) TIME STEP AUGMENTATION FACTOR D01 = 1.0500E+00 COUANT FACTOR CSF = 1.0000E+00 ((

)) CONDENSATION FACTOR CNDFC = 1.0000E+00 EVAPORATION FACTOR EVAPCF = 1.0000E+00 ((

MAIN CONTROL CARD PARAMETERS ARE

STEADY STATE = 0 TRANSIENT = 1  
RESTART TIME STEP = 0 NUMBER OF COMPONENTS = 6  
NUMBER OF JUNCTIONS = 5  
START TIME = 0.0000E+00  
OUTER CONVERGENCE CRITERION = 1.00E-02  
VESSEL CONVERGENCE CRITERION = 1.00E-02  
STEADY STATE CONVERGENCE CRITERION = 1.00E+00  
PWR INITIALIZATION CONVERGENCE CRITERION = 0.00E+00  
VESSEL ITERATION MAXIMUM = 20 OUTER ITERATION MAXIMUM = 10  
STEADY STATE ITERATION MAXIMUM = 20  
NUMBER OF SIGNAL VARIABLES = 0  
NUMBER OF TRIPS = 0  
NUMBER OF CONTROLLEKS = 0  
WATER PACKING OPTION = 0  
HOMOGENEOUS NUCLEATION TAIN IS USED

SYSTEM COMPONENTS 1 2 3 4 5 6

COMPONENT NO. 1 TYPE = FILL ID = 1

JUN1 = 1 , IFTY = 1 , IFSV = 0 , IFTR = 0 , NTFX = 0  
NTRF = 0 , TWTOLD = 0.000000E+00, CONC = 0.000000E+00, ICFE = 0.  
DWIN = 1.016300E+00, VOLIN = 5.364000E-04, ALPIN = 0.000000E+00, VLIN = 0.030000E+00, TLIN = 5.835000E+02  
PIN = 9.870000E+06, PAIN = 0.000000E+00, FLOVIN = 0.000000E+00, WIN = 0.000000E+00, TVIN = 5.835600E+02  
CONC = 0.000000E+00 KG/K: FLUID

COMPONENT NO. 2 TYPE = PIPE ID = 2

NCELS = 10 NODES = 2 JUN1 = 1 JUN2 = 2 NAT = 0 ICF = 0



CNEN  
DR

AUTOR: AAM/  
LSG/ *Leo*  
MRS/G/ *Regina*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C4/31

PARTE:

REVISÃO:

DATA:

APÊNDICE C

0

NOVEMBRO/88

TU 5.79000E+02 5.79000E+02 5.79000E+02 5.79000E+02 5.79000E+02 5.79000E+02 5.79000E+02 5.79000E+02  
5.79000E+02 5.79000E+02 5.79000E+02 5.79000E+02 5.79000E+02 5.79000E+02 5.79000E+02 5.79000E+02  
5.79000E+02 5.79000E+02 5.79000E+02 5.79000E+02

TOTAL VOLUME IN COMPONENT SECTION= 5.364000E+03

TOTAL LENGTH OF COMPONENT SECTION= 1.010300E+01

COMPONENT NO. 3 TYPE = PIPE ID = 3

NCELLS = 10 NODES = 5 JUM1 = 2 JUM2 = 3 MAT = 0 ICM = 1  
POWER TABLE PAIRS = 0 IACT = 0

RADIN = 1.050E-02 TH = 2.000E-03 HOUTL = 0.000E+00 HOUTV = 1.000E+01  
TOTL = 3.000E+02 TOUTV = 3.000E+02  
COMPONENT TYPE = PIPE  
COMPONENT NUM = 3  
ADDITIONAL LCM REQUIRED = 1752  
LAST UTILIZED LOCATION = 0235  
COMPONENT TYPE = PIPE  
COMPONENT NUM = 3  
ADDITIONAL SCX REQUIRED = 1545  
LAST UTILIZED LOCATION = 441

DX 4.00000E-01 4.00000E-01 4.00000E-01 4.00000E-01 4.00000E-01 4.00000E-01 4.00000E-01 4.00000E-01  
4.00000E-01 4.00000E-01

VE 1.38540E-04 1.38540E-04 1.38540E-04 1.38540E-04 1.38540E-04 1.38540E-04 1.38540E-04 1.38540E-04  
1.38540E-04 1.38540E-04

FA 3.46360E-04 3.46360E-04 3.46360E-04 3.46360E-04 3.46360E-04 3.46360E-04 3.46360E-04 3.46360E-04  
3.46360E-04 3.46360E-04 2.26930E-04

FRIC 0.00000E+00 0.00000E+00 0.00000E+00 0.00000E+00 0.00000E+00 0.00000E+00 0.00000E+00 0.00000E+00  
0.00000E+00 0.00000E+00 0.00000E+00

GRAV 1.00000E+00 1.00000E+00 1.00000E+00 1.00000E+00 1.00000E+00 1.00000E+00 1.00000E+00 1.00000E+00  
1.00000E+00 1.00000E+00 1.00000E+00

ND 2.10000E-02 2.10000E-02 2.10000E-02 2.10000E-02 2.10000E-02 2.10000E-02 2.10000E-02 2.10000E-02  
2.10000E-02 2.10000E-02 1.70000E-02

NET 4 4 4 4 4 4 4 4 4  
4 4

ALP 0.00000E+00 0.00000E+00 0.00000E+00 0.00000E+00 0.00000E+00 0.00000E+00 0.00000E+00 0.00000E+00  
0.00000E+00 0.00000E+00

VL -1.99300E+00 -1.99300E+00 -1.99300E+00 -1.99300E+00 -1.99300E+00 -1.99300E+00 -1.99300E+00 -1.99300E+00  
-1.99300E+00 -1.99300E+00 -3.04100E+00

VV -1.99300E+00 -1.99300E+00 -1.99300E+00 -1.99300E+00 -1.99300E+00 -1.99300E+00 -1.99300E+00 -1.99300E+00  
-1.99300E+00 -1.99300E+00 -3.04100E+00

TL 5.79000E+02 5.75000E+02 5.71000E+02 5.67000E+02 5.63000E+02 5.59000E+02 5.55000E+02 5.51000E+02  
5.47000E+02 5.43000E+02



CNEN  
DR

AUTOR: AAM/ *for*  
LSG/ *Leo*  
MRSGL/ *Regina*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C6/31

PARTE:  
APÊNDICE C

REVISÃO:  
Ø

DATA:  
NOVEMBRO/88

FRIC	0.00000E+00								
	0.00000E+00	0.00000E+00	0.00000E+00						
GRW	1.66000E-01	3.66000E-01							
	3.66000E-01	3.66000E-01	3.66000E-01						
MD	1.70000E-02								
	1.70000E-02	1.70000E-02	1.70000E-02						
HT	4	4	4	4	4	4	4	4	4
	4	4							
ALP	0.00000E+00								
	0.00000E+00	0.00000E+00							
VL	-3.04100E+00								
	-3.04100E+00	-3.04100E+00	-3.04100E+00						
VV	-3.04100E+00								
	-3.04100E+00	-3.04100E+00	-3.04100E+00						
TL	5.43000E+02	5.43300E+02	5.43670E+02	5.44000E+02	5.44330E+02	5.44670E+02	5.45000E+02	5.45330E+02	5.45670E+02
	5.45670E+02	5.46000E+02							
TV	5.43000E+02	5.43300E+02	5.43670E+02	5.44000E+02	5.44330E+02	5.44670E+02	5.45000E+02	5.45330E+02	5.45670E+02
	5.45670E+02	5.46000E+02							
P	9.86000E+06	9.86670E+06	9.87330E+06	9.88000E+06	9.88670E+06	9.89330E+06	9.90000E+06	9.90670E+06	9.91330E+06
	9.91330E+06	9.92000E+06							
PA	0.00000E+00								
	0.00000E+00	0.00000E+00							
PP	0.00000E+00								
	0.00000E+00								
	0.00000E+00	0.00000E+00	0.00000E+00	0.00000E+00					
MATID	1								
TV	5.44000E+02								
	5.44000E+02								
	5.44000E+02	5.44000E+02	5.44000E+02	5.44000E+02					

TOTAL VOLUME IN COMPONENT SECTION= 2.167000E-03

TOTAL LENGTH OF COMPONENT SECTION= 9.557000E+00

COMPONENT NO. 5 TYPE = PIPE ID = 5

WELLS = 0 NOOCS = 2 JUN1 = 4 JUN2 = 5 MAT = 6 ICF = 0  
POWER TABLE PAIRS = 0 IACC = 0

RADIN = 0.500E-03 TH = 1.500E-03 HOUTL = 0.000E+00 HOUTV = 0.000E+00  
TOUTL = 3.000E+02 TOUTV = 3.000E+02  
COMPONENT TYPE = PIPE  
COMPONENT NUM = 5  
ADDITIONAL LCM REQUIRED = 1290

CNEN  
DR

AUTOR: AAM/ *Am*  
LSG/ *Leo*  
MRSR/ *Rayna*  
GIT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C7/31

PARTE:

REVISÃO:

DATA:

APÊNDICE C

0

NOVEMBRO/88

LAST UTILIZED LOCATION = 11547  
COMPONENT TYPE = PIPE  
COMPONENT MIN = 5  
ADDITIONAL SCH REQUIRED = 1111  
LAST UTILIZED LOCATION = 441

DX	1.0000E-01	1.0000E-01	1.0000E-01	2.0000E-02	2.0000E-02	2.0000E-02	2.0000E-02	2.0000E-02	2.0000E-02
WOL	2.2700E-05	2.2700E-05	2.2700E-05	4.5400E-06	4.5400E-06	4.5400E-06	4.5400E-06	4.5400E-06	4.5400E-06
FA	2.2670E-04 2.2670E-04	2.2670E-04							
FXIC	0.0000E+00 0.0000E+00	0.0000E+00							
GRW	3.4600E-01 0.0000E+00	0.0000E+00							
ND	1.7000E-02 1.7000E-02	1.7000E-02							
NFT	4	4	4	4	4	4	4	4	4
ALP	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00
VL	-3.0410E+00 0.0000E+00	0.0000E+00							
VV	-3.0410E+00 0.0000E+00	0.0000E+00							
TL	5.4400E+02	5.4200E+02	5.3970E+02	5.3600E+02	5.3450E+02	5.2900E+02	5.2350E+02	5.1850E+02	
TV	5.4400E+02	5.4200E+02	5.3970E+02	5.3600E+02	5.3450E+02	5.2900E+02	5.2350E+02	5.1850E+02	
P	9.9200E+06	9.9200E+06	9.9200E+06	9.9200E+06	9.9200E+06	9.9200E+06	9.9200E+06	9.9200E+06	9.9200E+06
PA	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00
PPP	0.0000E+00 0.0000E+00	0.0000E+00							
KATSD									
TU	5.4400E+02 5.4400E+02	5.4400E+02							

TOTAL VOLUME IN COMPONENT SECTION= 9.000000E-05

CNEN  
DR

AUTOR: AAM/ *M. S. S.*  
LSG/ *S. S.*  
MRS/ *R. S. S.*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C8/31

PORTE:  
APÊNDICE C

REVISÃO:  
0

DATA:

NOVEMBRO/88

TOTAL LENGTH OF COMPONENT SECTION= 4.00000E-01

COMPONENT NO. 6 TYPE = BREAK ID = 6

JMID = 3 ZBRP = 0 MTR = 0 ISAT = 0 ZWV = 0

DLIN = 2.000E-02 ULIN = 4.500E-06 ALPIN = 1.00E+00 TIN = 3.7E+02 PIN = 1.00E+05

AIR PRESSURE = 0.00E+00

COMPONENT ICM = 6

ADDITIONAL LCM REQUIRED = 326

LAST UTILIZED LOCATION = 12045

COMPONENT ICM = 6

ADDITIONAL SCM REQUIRED = 173

LAST UTILIZED LOCATION = 441

SYSTEM COMPONENTS 2 3 4 5 1 6

WEIGHT CHANGE ACROSS COMPONENT 2 FROM CELL 1 TO CELL 10 IS 1.300E+00 N.

WEIGHT CHANGE ACROSS COMPONENT 3 FROM THE JOINING CELL OF COMPONENT 0 TO CELL 10 IS 4.3052E+00 N.

WEIGHT CHANGE ACROSS COMPONENT 4 FROM THE JOINING CELL OF COMPONENT 0 TO CELL 10 IS 3.8259E+00 N.

WEIGHT CHANGE ACROSS COMPONENT 5 FROM THE JOINING CELL OF COMPONENT 0 TO CELL 0 IS 1.9319E-01 N.

GRAPHICS PROBLEM ID IS

FOUR PIPE HEATED WALL BLOWDOWN  
FIVE MODES IN HEATED WALL, N-10 POST CHF HT MOD

NO. OF COMPONENTS.....	6
NO. OF CATALOG ENTRIES.....	102
NO. OF 4 X PACKED HISTORY BLKS.	254
NO. OF 4 X PACKED GEOMETRY BLKS.	535

ICOMP= 0: NUM= 0: ITYPE= 0: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	1: TIMET : REACTOR TIME (S)
ICOMP= 0: NUM= 0: ITYPE= 0: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	2: DELT : TIME STEP SIZE (S)
ICOMP= 0: NUM= 0: ITYPE= 0: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	3: DTLMAX : MAXIMUM TL CHANGE(DEG-K)
ICOMP= 0: NUM= 0: ITYPE= 0: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	4: DTVMAX : MAXIMUM TV CHANGE(DEG-K)
ICOMP= 0: NUM= 0: ITYPE= 0: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	5: DTSMAX : MAXIMUM TS CHANGE(DEG-K)
ICOMP= 0: NUM= 0: ITYPE= 0: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	6: DTRMAX : MAXIMUM TR CHANGE(DEG-K)
ICOMP= 0: NUM= 0: ITYPE= 0: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	7: DPRMAX : MAX FRAC PRESSURE CHANGE
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	8: MFLOW : MASS FLOW-RATE (KG/S)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	19: RHOH : MIXTURE DENSITY(KG/M**3)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	29: TSAT : SATURATION TEMP (DEG-K)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	39: ALPHA : VOID FRACTION
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	49: VL : LIQUID VELOCITY (M/S)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	60: VV : VAPOR VELOCITY (M/S)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	71: TL : LIQUID TEMP (DEG-K)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	81: TV : VAPOR TEMP (DEG-K)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	91: P : PRESSURE (PA)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	101: AH : AIR MASS (KG)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	111: ROAH : AIR DENSITY (KG/M**3)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	121: PA : PARTIAL PRESSURE (PA)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	131: TW : WALL TEMP (DEG-K)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	151: HL : HL (M/M**2/DEG-K)
ICOMP= 1: NUM= 2: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	161: HW : HW (M/M**2/DEG-K)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	171: MFLOW : MASS FLOW-RATE (KG/S)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	182: RHOH : MIXTURE DENSITY(KG/M**3)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	192: TSAT : SATURATION TEMP (DEG-K)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	202: ALPHA : VOID FRACTION
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	212: VL : LIQUID VELOCITY (M/S)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	223: VV : VAPOR VELOCITY (M/S)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	234: TL : LIQUID TEMP (DEG-K)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	244: TV : VAPOR TEMP (DEG-K)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	254: P : PRESSURE (PA)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	264: AH : AIR MASS (KG)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	274: ROAH : AIR DENSITY (KG/M**3)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	284: PA : PARTIAL PRESSURE (PA)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	294: TW : WALL TEMP (DEG-K)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	344: HL : HL (M/M**2/DEG-K)
ICOMP= 2: NUM= 3: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	354: HW : HW (M/M**2/DEG-K)
ICOMP= 3: NUM= 4: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	364: MFLOW : MASS FLOW-RATE (KG/S)
ICOMP= 3: NUM= 4: ITYPE= 2: MWD= 1: ILRN 0: POLYPLOT INDEX OF 1ST ITEM=	375: RHOH : MIXTURE DENSITY(KG/M**3)

CNEN  
DR

AUTOR: AAM/ *Am*  
LSG/ *Liv*  
MRSJ/ *Região*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C10/31

PARTE:  
APÊNDICE C

REVISÃO:  
0

DATA:  
NOVEMBRO/88

ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 10: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	385: TSAT	: SATURATION TEMP (DEG-K)
ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 10: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	395: ALPHA	: VOID FRACTION
ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 11: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	465: VL	: LIQUID VELOCITY (M/S)
ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 11: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	464: WV	: VAPOR VELOCITY (M/S)
ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 10: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	427: TL	: LIQUID TEMP (DEG-K)
ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 10: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	437: TV	: VAPOR TEMP (DEG-K)
ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 10: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	447: P	: PRESSURE (PA)
ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 10: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	457: AA	: AIR MASS (KG)
ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 10: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	467: ROAN	: AIR DENSITY (KG/M**3)
ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 10: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	477: PA	: PARTIAL PRESSURE (PA)
ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 20: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	487: TW	: WALL TEMP (DEG-K)
ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 10: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	507: ML	: ML (M/M**2/DEG-K)
ICOMP= 3: NUM= 4: ITYPE= 2: NORD= 10: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	517: MW	: MW (M/M**2/DEG-K)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 9: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	527: MFLOW	: MASS FLOW-RATE (KG/S)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 8: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	534: RHOH	: MIXTURE DENSITY(KG/M**3)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 8: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	544: TSAT	: SATURATION TEMP (DEG-K)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 8: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	552: ALPHA	: VOID FRACTION
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 9: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	564: VL	: LIQUID VELOCITY (M/S)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 9: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	569: WV	: VAPOR VELOCITY (M/S)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 8: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	578: TL	: LIQUID TEMP (DEG-K)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 8: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	584: TV	: VAPOR TEMP (DEG-K)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 8: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	594: P	: PRESSURE (PA)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 8: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	602: AA	: AIR MASS (KG)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 8: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	610: ROAN	: AIR DENSITY (KG/M**3)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 8: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	618: PA	: PARTIAL PRESSURE (PA)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 16: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	626: TW	: WALL TEMP (DEG-K)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 8: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	642: ML	: ML (M/M**2/DEG-K)
ICOMP= 4: NUM= 5: ITYPE= 2: NORD= 8: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	654: MW	: MW (M/M**2/DEG-K)
ICOMP= 5: NUM= 1: ITYPE= 2: NORD= 1: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	458: VM	: MIXTURE VELOCITY (M/S)
ICOMP= 6: NUM= 6: ITYPE= 1: NORD= 1: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	659: MFLOW	: MASS FLOW-RATE (KG/S)
ICOMP= 6: NUM= 6: ITYPE= 1: NORD= 1: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	660: MFLOW	: MASS FLOW (KG)
ICOMP= 6: NUM= 6: ITYPE= 1: NORD= 1: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	661: 8XA	: AIR MASS FLOW-RATE(KG/S)
ICOMP= 6: NUM= 6: ITYPE= 1: NORD= 1: IIRN 0: POLYPLOT INDEX OF 1ST ITEM=	662: 8SA	: AIR MASS FLOW (KG)

FOR POLYPLOT.....MPARN..... 662  
.....DATA..... 2656 BYTES  
.....BLKSIZE... 2664 BYTES

CNEN  
DR

AUTOR: AAM/ *Am*  
LSG/ *Liv*  
MRSGL/ *Rajira*  
GTT  
GAC

ÓRGÃO

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C11/31

PARTE:

REVISÃO:

DATA:

APÊNDICE C

0

NOVEMBRO/88

GRAPHICS PROBLEM ID IS

FOR PIPE HEATED WALL BLOWDOWN  
FIVE NODES IN HEATED WALL, N=10 POST CHF HT 800

NO. OF COMPONENTS.....	6
NO. OF CATALOG ENTRIES.....	102
NO. OF 4 X PACKED HISTORY BLKS.	256
NO. OF 4 X PACKED GEOMETRY BLKS.	535

ICOMP	0:	NUM	0:	ITYPE	0:	WARD	1:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	TIMET	:	REACTOR TIME (S)
ICOMP	0:	NUM	0:	ITYPE	0:	WARD	1:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	DELT	:	TIME STEP SIZE (S)
ICOMP	0:	NUM	0:	ITYPE	0:	WARD	1:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	DTLMAX	:	MAXIMUM TL CHANGE(DEG-K)
ICOMP	0:	NUM	0:	ITYPE	0:	WARD	1:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	DTVMAX	:	MAXIMUM TV CHANGE(DEG-K)
ICOMP	0:	NUM	0:	ITYPE	0:	WARD	1:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	DTSMAX	:	MAXIMUM TS CHANGE(DEG-K)
ICOMP	0:	NUM	0:	ITYPE	0:	WARD	1:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	DTRMAX	:	MAXIMUM TR CHANGE(DEG-K)
ICOMP	0:	NUM	0:	ITYPE	0:	WARD	1:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	DPRMAX	:	MAX FRAC PRESSURE CHANGE
ICOMP	1:	NUM	2:	ITYPE	31:	WARD	50:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:		:	FIXLTAB
ICOMP	1:	NUM	2:	ITYPE	32:	WARD	37:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:		:	ULTAB
ICOMP	1:	NUM	2:	ITYPE	11:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	DX	:	DELTA-X (R)
ICOMP	1:	NUM	2:	ITYPE	14:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	VOL	:	VOLUME (M**3)
ICOMP	1:	NUM	2:	ITYPE	15:	WARD	11:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	FLOWAREA	:	FLOW AREA (M**2)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	11:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	NFLOW	:	MASS FLOW-RATE (KG/S)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	RHOH	:	MIXTURE DENSITY(KG/M**3)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	TSAT	:	SATURATION TEMP (DEG-K)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	ALPHA	:	VOID FRACTION
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	11:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	VL	:	LIQUID VELOCITY (M/S)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	11:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	VV	:	VAPOR VELOCITY (M/S)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	TL	:	LIQUID TEMP (DEG-K)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	TV	:	VAPOR TEMP (DEG-K)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	P	:	PRESSURE (PA)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	AM	:	AIR MASS (KG)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	RCAM	:	AIR DENSITY (KG/M**3)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	16:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	PA	:	PARTIAL PRESSURE (PA)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	20:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	TV	:	WALL TEMP (DEG-K)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	ML	:	ML (M/M**2/DEG-K)
ICOMP	1:	NUM	2:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	MV	:	MV (M/M**2/DEG-K)
ICOMP	2:	NUM	3:	ITYPE	31:	WARD	50:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:		:	FIXLTAB
ICOMP	2:	NUM	3:	ITYPE	32:	WARD	37:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:		:	ULTAB
ICOMP	2:	NUM	3:	ITYPE	11:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	DX	:	DELTA-X (R)
ICOMP	2:	NUM	3:	ITYPE	14:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	VOL	:	VOLUME (M**3)
ICOMP	2:	NUM	3:	ITYPE	15:	WARD	11:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	FLOWAREA	:	FLOW AREA (M**2)
ICOMP	2:	NUM	3:	ITYPE	2:	WARD	11:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	NFLOW	:	MASS FLOW-RATE (KG/S)
ICOMP	2:	NUM	3:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	RHOH	:	MIXTURE DENSITY(KG/M**3)
ICOMP	2:	NUM	3:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	TSAT	:	SATURATION TEMP (DEG-K)
ICOMP	2:	NUM	3:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	ALPHA	:	VOID FRACTION
ICOMP	2:	NUM	3:	ITYPE	2:	WARD	11:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	VL	:	LIQUID VELOCITY (M/S)
ICOMP	2:	NUM	3:	ITYPE	2:	WARD	11:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	VV	:	VAPOR VELOCITY (M/S)
ICOMP	2:	NUM	3:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	TL	:	LIQUID TEMP (DEG-K)
ICOMP	2:	NUM	3:	ITYPE	2:	WARD	10:	ILRN	0:	NSKIP	1:	IPOS	1:	KP/IPKG	0:	TV	:	VAPOR TEMP (DEG-K)

CNEN  
DR

AUTOR: AAM/ *Lu*  
LSG/ *Leo*  
MRSGL/ *Regina*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:  
C12/31

NOTA TÉCNICA  
PARTE: APÊNDICE C REVISÃO: 0 DATA: NOVENBRO/88

ICOMP	2:	NUM	3:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	P	:	PRESSURE (PA)
ICOMP	2:	NUM	3:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	AM	:	AIR MASS (KG)
ICOMP	2:	NUM	3:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	ROAN	:	AIR DENSITY (KG/M**3)
ICOMP	2:	NUM	3:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	PA	:	PARTIAL PRESSURE (PA)
ICOMP	2:	NUM	3:	ITYPE	2:	WORD	50:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	TM	:	WALL TEMP (DEG-K)
ICOMP	2:	NUM	3:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	HL	:	HL (M/M**2/DEG-K)
ICOMP	2:	NUM	3:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	HV	:	HV (M/M**2/DEG-K)
ICOMP	3:	NUM	4:	ITYPE	31:	WORD	50:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:		:	FIXTAG
ICOMP	3:	NUM	4:	ITYPE	32:	WORD	37:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:		:	ULTAB
ICOMP	3:	NUM	4:	ITYPE	11:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	DX	:	DELTA-X (M)
ICOMP	3:	NUM	4:	ITYPE	14:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	VOL	:	VOLUME (M**3)
ICOMP	3:	NUM	4:	ITYPE	15:	WORD	11:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	FLOWAREA:	:	FLOW AREA (M**2)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	11:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	MFLOW	:	MASS FLOW-RATE (KG/S)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	RHON	:	MIXTURE DENSITY (KG/M**3)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	TSAT	:	SATURATION TEMP (DEG-K)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	ALPHA	:	VOID FRACTION
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	11:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	VL	:	LIQUID VELOCITY (M/S)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	11:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	UV	:	VAPOR VELOCITY (M/S)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	TL	:	LIQUID TEMP (DEG-K)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	TV	:	VAPOR TEMP (DEG-K)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	P	:	PRESSURE (PA)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	AM	:	AIR MASS (KG)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	ROAN	:	AIR DENSITY (KG/M**3)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	PA	:	PARTIAL PRESSURE (PA)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	28:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	TM	:	WALL TEMP (DEG-K)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	HL	:	HL (M/M**2/DEG-K)
ICOMP	3:	NUM	4:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	HV	:	HV (M/M**2/DEG-K)
ICOMP	4:	NUM	5:	ITYPE	31:	WORD	50:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:		:	FIXTAG
ICOMP	4:	NUM	5:	ITYPE	32:	WORD	37:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:		:	ULTAB
ICOMP	4:	NUM	5:	ITYPE	11:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	DX	:	DELTA-X (M)
ICOMP	4:	NUM	5:	ITYPE	14:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	VOL	:	VOLUME (M**3)
ICOMP	4:	NUM	5:	ITYPE	15:	WORD	11:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	FLOWAREA:	:	FLOW AREA (M**2)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	11:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	MFLOW	:	MASS FLOW-RATE (KG/S)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	RHON	:	MIXTURE DENSITY (KG/M**3)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	TSAT	:	SATURATION TEMP (DEG-K)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	ALPHA	:	VOID FRACTION
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	11:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	VL	:	LIQUID VELOCITY (M/S)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	11:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	UV	:	VAPOR VELOCITY (M/S)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	TL	:	LIQUID TEMP (DEG-K)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	TV	:	VAPOR TEMP (DEG-K)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	P	:	PRESSURE (PA)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	AM	:	AIR MASS (KG)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	ROAN	:	AIR DENSITY (KG/M**3)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	PA	:	PARTIAL PRESSURE (PA)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	28:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	TM	:	WALL TEMP (DEG-K)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	HL	:	HL (M/M**2/DEG-K)
ICOMP	4:	NUM	5:	ITYPE	2:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	HV	:	HV (M/M**2/DEG-K)
ICOMP	5:	NUM	1:	ITYPE	31:	WORD	50:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:		:	FIXTAG
ICOMP	5:	NUM	1:	ITYPE	32:	WORD	37:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:		:	ULTAB
ICOMP	5:	NUM	1:	ITYPE	11:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	DX	:	DELTA-X (M)
ICOMP	5:	NUM	1:	ITYPE	14:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	VOL	:	VOLUME (M**3)
ICOMP	5:	NUM	1:	ITYPE	15:	WORD	11:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	FLOWAREA:	:	FLOW AREA (M**2)
ICOMP	5:	NUM	1:	ITYPE	2:	WORD	11:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	MV	:	MIXTURE VELOCITY (M/S)
ICOMP	6:	NUM	6:	ITYPE	31:	WORD	50:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:		:	FIXTAG
ICOMP	6:	NUM	6:	ITYPE	32:	WORD	37:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:		:	ULTAB
ICOMP	6:	NUM	6:	ITYPE	11:	WORD	10:	ILRN	0:	MSKIP	1:	IPOS	1:	XP/IPKG	0:	DX	:	DELTA-X (M)

CNEN  
DR

AUTOR: AAM/ *Ar*  
LSG/ *Sw*  
MRSO/ *Regina*  
GTT  
ORGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C13/31

PARTE:

REVISÃO:

DATA:

APÊNDICE C

Ø

NOVEMBRO/88

ICOMP	6:	NUM	6:	ITYPE	14:	NUMD	1:	ILRN	0:	MSKIP	1:	IPOS	1:	RP/IPKG	0:	VOL	:	VOLUME (M <sup>3</sup> )
ICOMP	6:	NUM	6:	ITYPE	15:	NUMD	2:	ILRN	0:	MSKIP	1:	IPOS	1:	RP/IPKG	0:	FLOWAREA	:	FLOW AREA (M <sup>2</sup> )
ICOMP	6:	NUM	6:	ITYPE	1:	NUMD	1:	ILRN	0:	PSKIP	1:	IPOS	1:	RP/IPKG	0:	MFLOW	:	MASS FLOW-RATE (KG/S)
ICOMP	6:	NUM	6:	ITYPE	1:	NUMD	1:	ILRN	0:	MSKIP	1:	IFCS	1:	RP/IPKG	0:	INFLOW	:	MASS FLOW (KG)
ICOMP	6:	NUM	6:	ITYPE	1:	NUMD	1:	ILRN	0:	MSKIP	1:	IPOS	1:	RP/IPKG	0:	BXA	:	AIR MASS FLOW-RATE(KG/S)
ICOMP	6:	NUM	6:	ITYPE	1:	NUMD	1:	ILRN	0:	NSAIP	1:	IPOS	1:	RP/IPKG	0:	BXA	:	AIR MASS FLOW (KG)

END OF COMPLETE LIST OF THE GRAPHICS CATALOG

```

*****
# 1.000E-05 1.000E-05 1.000E-05 1.000E-05 1.000E-05 1.000E-05 1.000E-05 1.000E-05
#
#
# -STEP STEP END INTERVAL INTERVAL INTERVAL INTERVAL
# TIME TIME DOMAIN EDIT EDIT EDIT EDIT
# MINIMUM MAXIMUM TIME LONG SHORT GRAPHICS CURP
#
# NEW TIME DOMAIN REACHED
*****

```

```

MAJOR EDIT AT 1= 0.00000E+00 SEC
SMALL EDIT AT 1= 0.00000E+00 SEC
RUP TIME AT 1= 0.00000E+00 SEC
GRAF TIME AT 1= 0.00000E+00 SEC

```

RESTANT RUP TAKEN AT TIME = 0.00000E+00 SEC, AFTER 0 TESTERS.

RESTANT FROM HERE WILL RESUME COUNTING FOR.....

AUTOR: AM/ <i>for</i> LSC/ <i>for</i> MRSG/ <i>for</i> GT ONGAO GAC		DOCUMENTO: Nº 02/88		CENEN DR	
PARTE: APENDICE C		NOTA TÉCNICA		PAGINA: C14/31	
REVISÃO: 0		DATA: NOVENBRO/88			

CNEN  
DR

AUTOR: AAM/ *Lu*  
LSG/ *Lu*  
MRSG/ *Regina*  
GTT  
ORGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C15/31

PARTE:  
APÊNDICE C

REVISÃO:  
Ø

DATA:  
NOVEMBRO/88

TRAC MAJOR EDIT

TIME = 0.000E+00 SECONDS DELT = 1.000E-05 SECONDS TIME STEPS = 0 OITMO = 0 ETIME = 0.00000E+00 SEC

TIME STEP STABILITY LIMITED BY COMPONENT 0, CELL 0, TO 1.02E+04 SECONDS  
AVERAGE OUTER ITERATION COUNT OVER TIME LAST 0 TIME STEPS WAS 0.00E+00  
TOTAL NUMBER OF TIMES THAT EACH COMPONENT WAS THE LAST TO CONVERGE SINCE THE LAST EDIT IS

THE LAST MINIMUM NUMBER OF OUTER ITERATIONS WAS 0 AT STEP 0, LIMITED BY COMPONENT 0 WITH VARY = 0.00E+00  
THE LAST MAXIMUM NUMBER OF OUTER ITERATIONS WAS 0 AT STEP 0, LIMITED BY COMPONENT 0 WITH VARY = 0.00E+00  
LAST MINIMUM NUMBER OF VESSEL ITERATIONS WAS 0 AT STEP 0  
LAST MAXIMUM NUMBER OF VESSEL ITERATIONS WAS 0 AT STEP 0

CURRENT CONVERGENCE LIMITS AND LIMITATION COUNTS

DELTA	DELTA	DELTA	DELTA	DELTA	DELTA
0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
0	0	0	0	0	0

CPTIME = -5.532E+00

\*\*\*\*\* TIME = 0.0000 DELT = 1.000E-05 \*\*\*\*\*

COMPONENT TYPE = PIPE COMPONENT NUMBER = 2 JN1 = 1 JN2 = 2

CELL	PRESSURE	AIR P	WVGR	FRAC	T SAT	T LIQ	T VAP	DEN LIQ	DEN VAP	LIQ VEL	VAP VEL	FF
1	9.7800E+06	0.000E+00	0.000E+00	5.825E+02	5.790E+02	5.825E+02	7.001E+02	5.380E+01	0.610E+00	0.000E+00	0.000E+00	9.276E-03
2	9.7822E+06	0.000E+00	0.000E+00	5.826E+02	5.790E+02	5.826E+02	7.001E+02	5.381E+01	-1.240E+00	-1.300E+00	0.000E+00	9.276E-03
3	9.7844E+06	0.000E+00	0.000E+00	5.826E+02	5.790E+02	5.826E+02	7.002E+02	5.383E+01	-1.240E+00	-1.300E+00	0.000E+00	9.276E-03
4	9.7867E+06	0.000E+00	0.000E+00	5.826E+02	5.790E+02	5.826E+02	7.002E+02	5.384E+01	-1.240E+00	-1.300E+00	0.000E+00	9.276E-03
5	9.7889E+06	0.000E+00	0.000E+00	5.826E+02	5.790E+02	5.826E+02	7.002E+02	5.386E+01	-1.240E+00	-1.300E+00	0.000E+00	9.276E-03
6	9.7911E+06	0.000E+00	0.000E+00	5.826E+02	5.790E+02	5.826E+02	7.002E+02	5.387E+01	-1.240E+00	-1.300E+00	0.000E+00	9.276E-03
7	9.7933E+06	0.000E+00	0.000E+00	5.827E+02	5.790E+02	5.827E+02	7.002E+02	5.389E+01	-1.240E+00	-1.300E+00	0.000E+00	9.276E-03
8	9.7955E+06	0.000E+00	0.000E+00	5.827E+02	5.790E+02	5.827E+02	7.002E+02	5.391E+01	-1.240E+00	-1.300E+00	0.000E+00	9.276E-03
9	9.7978E+06	0.000E+00	0.000E+00	5.827E+02	5.790E+02	5.827E+02	7.002E+02	5.392E+01	-1.240E+00	-1.300E+00	0.000E+00	9.276E-03
10	9.8000E+06	0.000E+00	0.000E+00	5.827E+02	5.790E+02	5.827E+02	7.002E+02	5.394E+01	-1.240E+00	-1.300E+00	0.000E+00	9.276E-03
11									-1.240E+00	-1.300E+00	0.000E+00	9.276E-03

CELL	IDR	HL	HW	HLV	OPPL	OPPV	TCWF	WALL TEMPERATURES BY SIDE	
1	7	2.635E+03	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	579.00	579.00
2	7	4.580E+03	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	579.00	579.00
3	7	4.580E+03	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	579.00	579.00
4	7	4.580E+03	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	579.00	579.00
5	7	4.580E+03	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	579.00	579.00
6	7	4.580E+03	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	579.00	579.00
7	7	4.580E+03	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	579.00	579.00
8	7	4.580E+03	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	579.00	579.00
9	7	4.580E+03	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	579.00	579.00
10	7	5.652E+03	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	579.00	579.00

TOTAL COMPONENT WATER MASS= 3.756490E+00 TOTAL COMPONENT WATER ENERGY= 5.118497E+06 MASS= 3.756490E+00

\*\*\*\*\* TIME = 0.0000 DELT = 1.000E-05 \*\*\*\*\*

CNEN  
DR

AUTOR: AAM/ *Am Rio Regina*  
LSG/  
MRSR/ *Regina*  
GTT  
GAC  
ÓRGÃO

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C16/31

PARTE:  
APÊNDICE C

REVISÃO:  
0

DATA:  
NOVEMBRO/88

COMPONENT TYPE = PIPE COMPONENT NUMBER = 3 JUN1 = 2 JUN2 = 3

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T LIG	T WVP	DEN LIG	DEN WVP	LIG VEL	WVP VEL	FF
1	9.8000E+06	0.0000E+00	0.000E+00	5.827E+02	5.790E+02	5.827E+02	7.442E+02	5.394E+01	-1.993E+00	-1.993E+00	9.356E-03
2	9.80670E+06	0.0000E+00	0.000E+00	5.827E+02	5.750E+02	5.827E+02	7.104E+02	5.398E+01	-1.993E+00	-1.993E+00	9.356E-03
3	9.81330E+06	0.0000E+00	0.000E+00	5.828E+02	5.710E+02	5.828E+02	7.202E+02	5.403E+01	-1.993E+00	-1.993E+00	9.353E-03
4	9.82000E+06	0.0000E+00	0.000E+00	5.828E+02	5.670E+02	5.828E+02	7.298E+02	5.407E+01	-1.993E+00	-1.993E+00	9.356E-03
5	9.82670E+06	0.0000E+00	0.000E+00	5.829E+02	5.630E+02	5.829E+02	7.391E+02	5.412E+01	-1.993E+00	-1.993E+00	9.357E-03
6	9.83330E+06	0.0000E+00	0.000E+00	5.829E+02	5.590E+02	5.829E+02	7.480E+02	5.417E+01	-1.993E+00	-1.993E+00	9.359E-03
7	9.84000E+06	0.0000E+00	0.000E+00	5.830E+02	5.550E+02	5.830E+02	7.564E+02	5.421E+01	-1.993E+00	-1.993E+00	9.362E-03
8	9.84670E+06	0.0000E+00	0.000E+00	5.830E+02	5.510E+02	5.830E+02	7.645E+02	5.426E+01	-1.993E+00	-1.993E+00	9.366E-03
9	9.85330E+06	0.0000E+00	0.000E+00	5.831E+02	5.470E+02	5.831E+02	7.720E+02	5.430E+01	-1.993E+00	-1.993E+00	9.370E-03
10	9.86000E+06	0.0000E+00	0.000E+00	5.831E+02	5.430E+02	5.831E+02	7.791E+02	5.435E+01	-1.993E+00	-1.993E+00	9.375E-03
11									-3.041E+00	-3.041E+00	9.518E-03

CELL	IDR	HL	HV	HLV	OPPL	OPPV	TCWF	WALL TEMPERATURES BY NODE				
1	2	1.412E+04	0.000E+00	0.000E+00	2.400E+05	0.000E+00	6.298E+02	596.00	601.00	606.00	611.00	616.00
2	2	1.214E+04	0.000E+00	0.000E+00	2.429E+05	0.000E+00	6.298E+02	595.00	600.00	605.00	610.00	615.00
3	2	1.131E+04	0.000E+00	0.000E+00	2.714E+05	0.000E+00	6.193E+02	595.00	600.00	605.00	610.00	615.00
4	2	1.072E+04	0.000E+00	0.000E+00	3.032E+05	0.000E+00	6.186E+02	595.00	600.00	605.00	610.00	615.00
5	2	1.029E+04	0.000E+00	0.000E+00	3.293E+05	0.000E+00	6.179E+02	595.00	600.00	605.00	610.00	615.00
6	2	8.800E+03	0.000E+00	0.000E+00	2.944E+05	0.000E+00	6.153E+02	592.00	597.00	602.00	607.00	612.00
7	2	7.384E+03	0.000E+00	0.000E+00	2.364E+05	0.000E+00	6.058E+02	587.00	592.00	597.00	602.00	607.00
8	1	7.848E+03	0.000E+00	0.000E+00	2.114E+05	0.000E+00	6.044E+02	581.00	586.00	591.00	596.00	601.00
9	1	7.071E+03	0.000E+00	0.000E+00	2.192E+05	0.000E+00	6.040E+02	578.00	583.00	588.00	593.00	598.00
10	1	6.717E+03	0.000E+00	0.000E+00	2.787E+05	0.000E+00	6.040E+02	575.00	580.00	585.00	590.00	595.00

TOTAL COMPONENT WATER MASS= 1.027923E+00 TOTAL COMPONENT WATER ENERGY= 1.297301E+06 QMASS= 1.027923E+00

\*\*\*\*\* TIME = 0.0000 DELT = 1.000E-05 \*\*\*\*\*

COMPONENT TYPE = PIPE COMPONENT NUMBER = 4 JUN1 = 3 JUN2 = 4

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T LIG	T WVP	DEN LIG	DEN WVP	LIG VEL	WVP VEL	FF
1	9.86000E+06	0.0000E+00	0.000E+00	5.831E+02	5.430E+02	5.831E+02	7.791E+02	5.435E+01	-3.041E+00	-3.041E+00	9.518E-03
2	9.86670E+06	0.0000E+00	0.000E+00	5.832E+02	5.433E+02	5.832E+02	7.785E+02	5.440E+01	-3.041E+00	-3.041E+00	9.518E-03
3	9.87330E+06	0.0000E+00	0.000E+00	5.832E+02	5.437E+02	5.832E+02	7.779E+02	5.444E+01	-3.041E+00	-3.041E+00	9.517E-03
4	9.88000E+06	0.0000E+00	0.000E+00	5.833E+02	5.440E+02	5.833E+02	7.774E+02	5.449E+01	-3.041E+00	-3.041E+00	9.517E-03
5	9.88670E+06	0.0000E+00	0.000E+00	5.833E+02	5.443E+02	5.833E+02	7.768E+02	5.453E+01	-3.041E+00	-3.041E+00	9.516E-03
6	9.89330E+06	0.0000E+00	0.000E+00	5.834E+02	5.447E+02	5.834E+02	7.762E+02	5.457E+01	-3.041E+00	-3.041E+00	9.515E-03
7	9.90000E+06	0.0000E+00	0.000E+00	5.834E+02	5.450E+02	5.834E+02	7.757E+02	5.462E+01	-3.041E+00	-3.041E+00	9.516E-03
8	9.90670E+06	0.0000E+00	0.000E+00	5.835E+02	5.453E+02	5.835E+02	7.751E+02	5.467E+01	-3.041E+00	-3.041E+00	9.515E-03
9	9.91330E+06	0.0000E+00	0.000E+00	5.835E+02	5.457E+02	5.835E+02	7.745E+02	5.472E+01	-3.041E+00	-3.041E+00	9.515E-03
10	9.92000E+06	0.0000E+00	0.000E+00	5.836E+02	5.460E+02	5.836E+02	7.739E+02	5.476E+01	-3.041E+00	-3.041E+00	9.515E-03
11									-3.041E+00	-3.041E+00	9.515E-03

CELL	IDR	HL	HV	HLV	OPPL	OPPV	TCWF	WALL TEMPERATURES BY NODE	
1	7	1.037E+04	0.000E+00	0.000E+00	1.037E+04	0.000E+00	0.000E+00	544.00	544.00
2	7	1.037E+04	0.000E+00	0.000E+00	6.946E+03	0.000E+00	0.000E+00	544.00	544.00
3	7	1.037E+04	0.000E+00	0.000E+00	3.421E+03	0.000E+00	0.000E+00	544.00	544.00
4	7	1.036E+04	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	544.00	544.00
5	7	1.036E+04	0.000E+00	0.000E+00	-3.419E+03	0.000E+00	0.000E+00	544.00	544.00

CNEN  
DR

AUTOR: AAM/  
LSG/ *lis*  
MRSGL/ *Regina*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88  
NOTA TÉCNICA

PAGINA:  
C17/31

PARTE:  
APÊNDICE C

REVISÃO:  
0

DATA:  
NOVEMBRO/88

6	7	1.036E+04	0.000E+00	0.000E+00	-6.941E+03	0.000E+00	0.000E+00	544.00	544.00
7	7	1.036E+04	0.000E+00	0.000E+00	-1.036E+04	0.000E+00	0.000E+00	544.00	544.00
8	7	1.036E+04	0.000E+00	0.000E+00	-1.377E+04	0.000E+00	0.000E+00	544.00	544.00
9	7	1.036E+04	0.000E+00	0.000E+00	-1.727E+04	0.000E+00	0.000E+00	544.00	544.00
10	7	1.036E+04	0.000E+00	0.000E+00	-2.070E+04	0.000E+00	0.000E+00	544.00	544.00

TOTAL COMPONENT WATER MASS= 1.684272E+00 TOTAL COMPONENT WATER ENERGY= 1.983479E+06 QMASS= 1.684272E+00

TIME = 0.0000 DELT = 1.000E-05

COMPONENT TYPE = PIPE COMPONENT NUMBER = 5 JUN1 = 4 JUN2 = 5

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T L10	T VAP	DEN L10	DEN VAP	L10 VEL	VAP VEL	FF
1	9.92000E+06	0.00000E+00	0.000E+00	5.836E+02	5.446E+02	5.836E+02	7.764E+02	5.476E+01	-3.041E+00	-3.041E+00	9.515E-03
2	9.92000E+06	0.00000E+00	0.000E+00	5.836E+02	5.420E+02	5.836E+02	7.809E+02	5.476E+01	0.000E+00	0.000E+00	3.000E-02
3	9.92000E+06	0.00000E+00	0.000E+00	5.836E+02	5.397E+02	5.836E+02	7.845E+02	5.476E+01	0.000E+00	0.000E+00	3.000E-02
4	9.92000E+06	0.00000E+00	0.000E+00	5.836E+02	5.352E+02	5.836E+02	7.872E+02	5.476E+01	0.000E+00	0.000E+00	3.000E-02
5	9.92000E+06	0.00000E+00	0.000E+00	5.836E+02	5.345E+02	5.836E+02	7.922E+02	5.476E+01	0.000E+00	0.000E+00	3.000E-02
6	9.92000E+06	0.00000E+00	0.000E+00	5.836E+02	5.290E+02	5.836E+02	7.992E+02	5.476E+01	0.000E+00	0.000E+00	3.000E-02
7	9.92000E+06	0.00000E+00	0.000E+00	5.836E+02	5.235E+02	5.836E+02	8.057E+02	5.476E+01	0.000E+00	0.000E+00	3.000E-02
8	9.92000E+06	0.00000E+00	0.000E+00	5.836E+02	5.185E+02	5.836E+02	8.129E+02	5.476E+01	0.000E+00	0.000E+00	3.000E-02
9									0.000E+00	0.000E+00	2.311E-02

IDR HL WZ HLW OPPL OPV TCHF WALL TEMPERATURES BY MODE

CELL	IDR	HL	WZ	HLW	OPPL	OPV	TCHF	WALL TEMPERATURES BY MODE
1	7	5.951E+03	0.000E+00	0.000E+00	-3.576E+03	0.000E+00	0.000E+00	544.00 544.00
2	7	6.415E+01	0.000E+00	0.000E+00	1.293E+02	0.000E+00	0.000E+00	544.00 544.00
3	7	6.458E+01	0.000E+00	0.000E+00	2.773E+02	0.000E+00	0.000E+00	544.00 544.00
4	7	6.474E+01	0.000E+00	0.000E+00	3.825E+02	0.000E+00	0.000E+00	544.00 544.00
5	7	6.524E+01	0.000E+00	0.000E+00	6.195E+02	0.000E+00	0.000E+00	544.00 544.00
6	7	6.595E+01	0.000E+00	0.000E+00	9.897E+02	0.000E+00	0.000E+00	544.00 544.00
7	7	6.670E+01	0.000E+00	0.000E+00	1.367E+03	0.000E+00	0.000E+00	544.00 544.00
8	7	6.732E+01	0.000E+00	0.000E+00	1.717E+03	0.000E+00	0.000E+00	544.00 544.00

TOTAL COMPONENT WATER MASS= 7.130594E-02 TOTAL COMPONENT WATER ENERGY= 8.192644E+04 QMASS= 7.130594E-02

TIME = 0.0000 DELT = 1.000E-05

COMPONENT TYPE = FILL COMPONENT NUMBER = 1 JUN1 = 1

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T L10	T VAP	DEN L10	DEN VAP	L10 VEL	VAP VEL	FF
1	9.82000E+06	0.00000E+00	0.000E+00	5.828E+02	5.835E+02	5.828E+02	6.885E+02	5.407E+01	0.000E+00	0.000E+00	0.000E+00
2									0.000E+00	0.000E+00	0.000E+00

MASS FLOW RATE = 0.0000E+00 TOTAL MASS IN = 0.0000E+00

TIME = 0.0000 DELT = 1.000E-05

COMPONENT TYPE = BREAK COMPONENT NUMBER = 6 JUN1 = 5

CNEN  
DR

AUTOR: AAM/  
LSG/ *Leo*  
MRSGL/ *Regina*  
GIT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

C18/31

NOTA TÉCNICA

PARTE:

REVISÃO:

DATA:

APÊNDICE C

0

NOVEMBRO/88

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T LIO	T VAP	DEN LIO	DEN VAP	LIO VEL	VAP VEL	FF
1	1.0000E+05	0.0000E+00	1.000E+00	3.730E+02	3.730E+02	3.730E+02	9.547E+02	5.900E-01	0.000E+00	0.000E+00	0.000E+00
2									0.000E+00	0.000E+00	0.000E+00

MASS FLOW RATE = 0.0000E+00      TOTAL MASS OUT = 0.0000E+00

AIR MASS FLOW RATE = 0.0000E+00      TOTAL AIR MASS OUT = 0.0000E+00

TOTAL SYSTEM WATER MASS = 6.539191E+00      TOTAL SYSTEM WATER ENERGY = 0.400795E+06

TOTAL MASS DISCHARGED AT BREAKS = 0.000000E+00

TOTAL MASS INJECTED AT FILLS = 0.000000E+00

COMPUTED SYSTEM INITIAL MASS = 6.539191E+00

CNEN  
DR

AUTOR: AAM/ *Leo*  
LSG/ *Leo*  
MRSR/ *Regina*  
GTT  
ORGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C19/31

PARTE:

REVISÃO:

DATA:

APÊNDICE C

0

NOVEMBRO/88

TRAC MARK EDIT

TIME = 1.000E-05 SECONDS DELT = 1.000E-05 SECONDS TIME STEPS = 1 0170 = 2 ETIME = 1.00000E-05 SEC

TIME STEP STABILITY LIMITED BY COMPONENT 5, CELL 9, TO 1.22E+02SECONDS  
AVERAGE OUTER ITERATION COUNT OVER THE LAST .1 TIME STEPS WAS 2.00E+00  
TOTAL NUMBER OF TIMES THAT EACH COMPONENT WAS THE LAST TO CONVERGE SINCE THE LAST EDIT IS  
0 0 0 1 0 0

THE LAST MINIMUM NUMBER OF OUTER ITERATIONS WAS 2 AT STEP 0, LIMITED BY COMPONENT 5 WITH VARIER = 3.57E-04  
THE LAST MAXIMUM NUMBER OF OUTER ITERATIONS WAS 2 AT STEP 0, LIMITED BY COMPONENT 5 WITH VARIER = 3.57E-04  
LAST MINIMUM NUMBER OF VESSEL ITERATIONS WAS 0 AT STEP 0  
LAST MAXIMUM NUMBER OF VESSEL ITERATIONS WAS 0 AT STEP 0  
CURRENT CONVERGENCE LIMITS AND LIMITATION COUNTS

DELNOX	DELNOX	DELNOX	DELNOX	DELNOX	DELNOX
0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
0	0	0	0	0	0

OPTIME = -5.70E+00

\*\*\*\*\* TIME = 0.0000 DELT = 1.000E-05 \*\*\*\*\*

COMPONENT TYPE = PIPE COMPONENT NUMBER = 2 JUN1 = 1 JUN2 = 2

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T LIO	T VAP	DEN LIO	DEN VAP	LIO VEL	VAP VEL	FF
1	9.7880E+06	0.0000E+00	0.000E+00	5.826E+02	5.790E+02	5.826E+02	7.002E+02	5.385E+01	0.000E+00	0.000E+00	3.000E-02
2	9.7822E+06	0.0000E+00	0.000E+00	5.826E+02	5.790E+02	5.826E+02	7.001E+02	5.381E+01	-1.300E+00	-1.299E+00	9.276E-03
3	9.7844E+06	0.0000E+00	0.000E+00	5.826E+02	5.790E+02	5.826E+02	7.002E+02	5.383E+01	-1.300E+00	-1.300E+00	9.276E-03
4	9.7867E+06	0.0000E+00	0.000E+00	5.826E+02	5.790E+02	5.826E+02	7.002E+02	5.384E+01	-1.300E+00	-1.300E+00	9.276E-03
5	9.7889E+06	0.0000E+00	0.000E+00	5.826E+02	5.790E+02	5.826E+02	7.002E+02	5.384E+01	-1.300E+00	-1.300E+00	9.276E-03
6	9.7911E+06	0.0000E+00	0.000E+00	5.826E+02	5.790E+02	5.826E+02	7.002E+02	5.387E+01	-1.300E+00	-1.300E+00	9.276E-03
7	9.7933E+06	0.0000E+00	0.000E+00	5.826E+02	5.790E+02	5.826E+02	7.002E+02	5.389E+01	-1.300E+00	-1.300E+00	9.276E-03
8	9.7955E+06	0.0000E+00	0.000E+00	5.827E+02	5.790E+02	5.827E+02	7.002E+02	5.391E+01	-1.300E+00	-1.300E+00	9.276E-03
9	9.7978E+06	0.0000E+00	0.000E+00	5.827E+02	5.790E+02	5.827E+02	7.002E+02	5.392E+01	-1.300E+00	-1.300E+00	9.276E-03
10	9.8000E+06	0.0000E+00	0.000E+00	5.827E+02	5.790E+02	5.827E+02	7.002E+02	5.394E+01	-1.300E+00	-1.300E+00	9.276E-03
11									-1.993E+00	-1.992E+00	9.256E-03

CELL IDR IC MW MLV GPPV OPPV TCHF WALL TEMPERATURES BY NODE

1	7	2.435E+03	0.000E+00	0.000E+00	-1.022E+01	0.000E+00	0.000E+00	579.00	579.00
2	7	4.588E+03	0.000E+00	0.000E+00	-1.564E-03	0.000E+00	0.000E+00	579.00	579.00
3	7	4.588E+03	0.000E+00	0.000E+00	-1.948E-05	0.000E+00	0.000E+00	579.00	579.00
4	7	4.588E+03	0.000E+00	0.000E+00	1.932E-05	0.000E+00	0.000E+00	579.00	579.00
5	7	4.588E+03	0.000E+00	0.000E+00	5.607E-09	0.000E+00	0.000E+00	579.00	579.00
6	7	4.588E+03	0.000E+00	0.000E+00	2.673E-09	0.000E+00	0.000E+00	579.00	579.00
7	7	4.588E+03	0.000E+00	0.000E+00	-1.934E-05	0.000E+00	0.000E+00	579.00	579.00
8	7	4.588E+03	0.000E+00	0.000E+00	1.934E-05	0.000E+00	0.000E+00	579.00	579.00
9	7	4.588E+03	0.000E+00	0.000E+00	-1.723E-04	0.000E+00	0.000E+00	579.00	579.00
10	7	5.454E+03	0.000E+00	0.000E+00	-2.880E-03	0.000E+00	0.000E+00	579.00	579.00

TOTAL COMPONENT WATER MASS= 3.755490E+00 TOTAL COMPONENT WATER ENERGY= 5.118097E+06 QMASS= 3.755490E+00

TOTAL COMPONENT HEAT LOSS: INSIDE= 0.437E-01 WATTS OUTSIDE= 0.000E+00 WATTS

\*\*\*\*\* TIME = 0.0000 DELT = 1.000E-05 \*\*\*\*\*

COMPONENT TYPE = PIPE COMPONENT NUMBER = 3 JUN1 = 2 JUN2 = 3

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T L10	T VAP	DEN L10	DEN VAP	L10 VEL	VAP VEL	FF
1	9.88025E+06	0.00000E+00	0.000E+00	5.827E+02	5.790E+02	5.827E+02	7.002E+02	5.394E+01	-1.993E+00	-1.993E+00	9.354E-03
2	9.88697E+06	0.00000E+00	0.000E+00	5.827E+02	5.750E+02	5.827E+02	7.104E+02	5.398E+01	-1.993E+00	-1.996E+00	9.354E-03
3	9.91333E+06	0.00000E+00	0.000E+00	5.828E+02	5.710E+02	5.828E+02	7.202E+02	5.403E+01	-1.993E+00	-1.996E+00	9.355E-03
4	9.92026E+06	0.00000E+00	0.000E+00	5.828E+02	5.670E+02	5.828E+02	7.298E+02	5.408E+01	-1.993E+00	-1.996E+00	9.354E-03
5	9.92697E+06	0.00000E+00	0.000E+00	5.829E+02	5.630E+02	5.829E+02	7.391E+02	5.412E+01	-1.993E+00	-1.996E+00	9.357E-03
6	9.93353E+06	0.00000E+00	0.000E+00	5.829E+02	5.590E+02	5.829E+02	7.480E+02	5.417E+01	-1.993E+00	-1.996E+00	9.357E-03
7	9.94017E+06	0.00000E+00	0.000E+00	5.830E+02	5.550E+02	5.830E+02	7.564E+02	5.421E+01	-1.993E+00	-1.996E+00	9.362E-03
8	9.94685E+06	0.00000E+00	0.000E+00	5.830E+02	5.510E+02	5.830E+02	7.645E+02	5.426E+01	-1.993E+00	-1.996E+00	9.366E-03
9	9.95345E+06	0.00000E+00	0.000E+00	5.831E+02	5.470E+02	5.831E+02	7.720E+02	5.430E+01	-1.993E+00	-1.996E+00	9.370E-03
10	9.95010E+06	0.00000E+00	0.000E+00	5.831E+02	5.430E+02	5.831E+02	7.791E+02	5.435E+01	-1.993E+00	-1.996E+00	9.373E-03
11									-3.041E+00	-3.041E+00	9.518E-03

CELL	IDR	HL	HW	HLV	OPPL	OPPV	TCHF	WALL TEMPERATURES BY NODE				
1	2	1.412E+04	0.000E+00	0.000E+00	2.400E+05	0.000E+00	6.200E+02	596.00	661.00	606.00	611.00	616.00
2	2	1.214E+04	0.000E+00	0.000E+00	2.420E+05	0.000E+00	6.200E+02	595.00	600.00	635.00	610.00	615.00
3	2	1.131E+04	0.000E+00	0.000E+00	2.714E+05	0.000E+00	6.190E+02	595.00	600.00	605.00	610.00	615.00
4	2	1.072E+04	0.000E+00	0.000E+00	3.003E+05	0.000E+00	6.185E+02	595.00	600.00	605.00	610.00	615.00
5	2	1.029E+04	0.000E+00	0.000E+00	3.293E+05	0.000E+00	6.179E+02	595.00	600.00	605.00	610.00	615.00
6	2	8.800E+03	0.000E+00	0.000E+00	2.904E+05	0.000E+00	6.153E+02	592.00	597.00	602.00	607.00	612.00
7	2	7.386E+03	0.000E+00	0.000E+00	2.334E+05	0.000E+00	6.058E+02	587.00	592.00	597.00	602.00	607.00
8	1	7.000E+03	0.000E+00	0.000E+00	2.114E+05	0.000E+00	6.040E+02	581.00	586.00	591.00	596.00	601.00
9	1	7.071E+03	0.000E+00	0.000E+00	2.192E+05	0.000E+00	6.040E+02	579.00	585.00	588.00	593.00	598.00
10	1	8.717E+03	0.000E+00	0.000E+00	2.789E+05	0.000E+00	6.000E+02	575.00	580.00	585.00	590.00	595.00

TOTAL COMPONENT WATER MASS= 1.027923E+00 TOTAL COMPONENT WATER ENRPG= 1.297301E+06 WMASS= 1.027923E+00

TOTAL COMPONENT HEAT LOSS: INSIDE= -6.915E+04 WATTS OUTSIDE= 0.060E+00 WATTS

\*\*\*\*\* TIME = 0.000 DELT = 1.00E-05 \*\*\*\*\*

COMPONENT TYPE = PIPE COMPONENT NUMBER = 4 JUN1 = 3 JUN2 = 4

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T L10	T VAP	DEN L10	DEN VAP	L10 VEL	VAP VEL	FF
1	9.86601E+06	0.00000E+00	0.000E+00	5.831E+02	5.430E+02	5.831E+02	7.791E+02	5.435E+01	-3.041E+00	-3.041E+00	9.518E-03
2	9.86671E+06	0.00000E+00	0.000E+00	5.832E+02	5.433E+02	5.832E+02	7.785E+02	5.440E+01	-3.041E+00	-3.042E+00	9.518E-03
3	9.87330E+06	0.00000E+00	0.000E+00	5.832E+02	5.437E+02	5.832E+02	7.779E+02	5.444E+01	-3.041E+00	-3.042E+00	9.517E-03
4	9.88000E+06	0.00000E+00	0.000E+00	5.833E+02	5.440E+02	5.833E+02	7.774E+02	5.449E+01	-3.041E+00	-3.042E+00	9.517E-03
5	9.88670E+06	0.00000E+00	0.000E+00	5.833E+02	5.443E+02	5.833E+02	7.768E+02	5.453E+01	-3.041E+00	-3.042E+00	9.516E-03
6	9.89329E+06	0.00000E+00	0.000E+00	5.834E+02	5.447E+02	5.834E+02	7.762E+02	5.458E+01	-3.041E+00	-3.042E+00	9.516E-03
7	9.89999E+06	0.00000E+00	0.000E+00	5.834E+02	5.450E+02	5.834E+02	7.757E+02	5.463E+01	-3.041E+00	-3.042E+00	9.516E-03
8	9.90669E+06	0.00000E+00	0.000E+00	5.835E+02	5.453E+02	5.835E+02	7.751E+02	5.467E+01	-3.041E+00	-3.042E+00	9.515E-03
9	9.91329E+06	0.00000E+00	0.000E+00	5.835E+02	5.457E+02	5.835E+02	7.745E+02	5.472E+01	-3.041E+00	-3.042E+00	9.515E-03
10	9.91995E+06	0.00000E+00	0.000E+00	5.836E+02	5.460E+02	5.836E+02	7.739E+02	5.476E+01	-3.041E+00	-3.042E+00	9.515E-03
11									-3.041E+00	-3.042E+00	9.515E-03

CELL	IDR	HL	HW	HLV	OPPL	OPPV	TCHF	WALL TEMPERATURES BY NODE	
1	7	1.037E+04	0.000E+00	0.000E+00	1.037E+04	0.000E+00	0.000E+00	544.00	544.00

CNEN  
DR

AUTOR: AAM/  
LSG/ *Lu*  
MRSR/ *Teiji na*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C21/31

PARTE:

REVISÃO:

DATA:

APÊNDICE C

0

NOVEMBRO/88

2	7	1.837E+04	0.000E+00	0.000E+00	6.946E+03	0.000E+00	0.000E+00	544.00	544.00
3	7	1.837E+04	0.000E+00	0.000E+00	3.420E+03	0.000E+00	0.000E+00	544.00	544.00
4	7	1.836E+04	0.000E+00	0.000E+00	-1.006E-01	0.000E+00	0.000E+00	544.00	544.00
5	7	1.836E+04	0.000E+00	0.000E+00	-3.419E+03	0.000E+00	0.000E+00	544.00	544.00
6	7	1.836E+04	0.000E+00	0.000E+00	-6.946E+03	0.000E+00	0.000E+00	544.00	544.00
7	7	1.836E+04	0.000E+00	0.000E+00	-1.035E+04	0.000E+00	0.000E+00	544.00	544.00
8	7	1.836E+04	0.000E+00	0.000E+00	-1.377E+04	0.000E+00	0.000E+00	544.00	544.00
9	7	1.835E+04	0.000E+00	0.000E+00	-1.727E+04	0.000E+00	0.000E+00	544.00	544.00
10	7	1.835E+04	0.000E+00	0.000E+00	-2.070E+04	0.000E+00	0.000E+00	544.00	544.00

TOTAL COMPONENT WATER MASS= 1.684272E+00 TOTAL COMPONENT WATER ENERGY= 1.983470E+06 MASS= 1.684272E+00

TOTAL COMPONENT HEAT LOSS: INSIDE= 2.641E+03 WATTS OUTSIDE= 0.000E+00 WATTS

\*\*\*\*\* TIME = 0.0000 DELT = 1.000E-05 \*\*\*\*\*

COMPONENT TYPE = PIPE COMPONENT NUMBER = 5 JUN1 = 4 JUN2 = 5

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T L10	T VAP	DEN L10	DEN VAP	L10 VEL	VAP VEL	FF
1	9.73120E+06	0.00000E+00	0.000E+00	5.822E+02	5.445E+02	5.822E+02	7.762E+02	5.346E+01	-3.036E+00	-2.976E+00	9.515E-03
2	9.91047E+06	0.00000E+00	0.000E+00	5.836E+02	5.420E+02	5.836E+02	7.608E+02	5.475E+01	-2.405E-02	-3.419E-01	3.000E-02
3	9.91977E+06	0.00000E+00	0.000E+00	5.836E+02	5.397E+02	5.836E+02	7.845E+02	5.476E+01	-1.914E-04	-2.735E-03	3.000E-02
4	9.91850E+06	0.00000E+00	0.000E+00	5.836E+02	5.380E+02	5.836E+02	7.872E+02	5.475E+01	3.119E-04	4.475E-03	3.000E-02
5	9.91897E+06	0.00000E+00	0.000E+00	5.836E+02	5.345E+02	5.836E+02	7.922E+02	5.470E+01	4.833E-03	6.967E-02	3.000E-02
6	9.86116E+06	0.00000E+00	0.000E+00	5.831E+02	5.298E+02	5.831E+02	7.992E+02	5.436E+01	3.127E-02	4.544E-01	3.000E-02
7	9.56625E+06	0.00000E+00	0.000E+00	5.809E+02	5.234E+02	5.809E+02	8.654E+02	5.227E+01	1.899E-01	2.783E+00	3.000E-02
8	8.08115E+06	0.00000E+00	0.000E+00	5.689E+02	5.181E+02	5.689E+02	8.115E+02	4.280E+01	9.113E-01	1.347E+01	3.000E-02
9									4.566E+00	1.292E+02	2.311E-02

IPR HL HU HLU OPPL OPPV TCF WALL TEMPERATURES BY NODE

CELL	IPR	HL	HU	HLU	OPPL	OPPV	TCF	WALL TEMPERATURES BY NODE
1	7	5.895E+03	0.000E+00	0.000E+00	-3.210E+03	0.000E+00	0.000E+00	544.00 544.00
2	7	6.415E+01	0.000E+00	0.000E+00	1.283E+02	0.000E+00	0.000E+00	544.00 544.00
3	7	6.450E+01	0.000E+00	0.000E+00	2.773E+02	0.000E+00	0.000E+00	544.00 544.00
4	7	6.474E+01	0.000E+00	0.000E+00	3.885E+02	0.000E+00	0.000E+00	544.00 544.00
5	7	6.524E+01	0.000E+00	0.000E+00	6.200E+02	0.000E+00	0.000E+00	544.00 544.00
6	7	6.599E+01	0.000E+00	0.000E+00	9.909E+02	0.000E+00	0.000E+00	544.00 544.00
7	7	6.670E+01	0.000E+00	0.000E+00	1.374E+03	0.000E+00	0.000E+00	544.00 544.00
8	7	6.732E+01	0.000E+00	0.000E+00	1.747E+03	0.000E+00	0.000E+00	544.00 544.00

TOTAL COMPONENT WATER MASS= 7.130594E-02 TOTAL COMPONENT WATER ENERGY= 8.192644E+04 MASS= 7.130594E-02

TOTAL COMPONENT HEAT LOSS: INSIDE= 9.553E+00 WATTS OUTSIDE= 0.000E+00 WATTS

\*\*\*\*\* TIME = 0.0000 DELT = 1.000E-05 \*\*\*\*\*

COMPONENT TYPE = FILL COMPONENT NUMBER = 1 JUN1 = 1

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T L10	T VAP	DEN L10	DEN VAP	L10 VEL	VAP VEL	FF
1	9.82000E+06	0.00000E+00	0.000E+00	5.820E+02	5.835E+02	5.820E+02	6.885E+02	5.407E+01	0.000E+00	0.000E+00	0.000E+00
2									0.000E+00	0.000E+00	0.000E+00

CNEN  
DR

AUTOR: AAM/ *Am*  
LSG/ *Lio*  
MRSR/ *Rajina*  
GTT  
GAC  
órção

DOCUMENTO: Nº 02/88

PAGINA:  
C22/31

NOTA TÉCNICA

PARTE:  
APÊNDICE C

REVISÃO:  
0

DATA:  
NOVEMBRO/88

MASS FLOW RATE = 0.000E+00 TOTAL MASS IN = 0.000E+00

\*\*\*\*\* TIME = 0.0000 DELT = 1.000E-05 \*\*\*\*\*

COMPONENT TYPE = BREAK COMPONENT NUMBER = 6 JUM = 5

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T L10	T WAP	DEB L10	DEB WAP	L10 VEL	WAP VEL	FF
1	1.0000E+05	0.0000E+00	1.000E+00	3.730E+02	3.730E+02	3.730E+02	9.547E+02	5.900E-01	4.500E+00	1.292E+02	0.000E+00
2									0.000E+00	0.000E+00	0.000E+00

MASS FLOW RATE = 0.0000E+00 TOTAL MASS OUT = 0.0000E+00

AIR MASS FLOW RATE = 0.0000E+00 TOTAL AIR MASS OUT = 0.0000E+00

TOTAL SYSTEM WATER MASS = 6.53191E+00 TOTAL SYSTEM WATER ENERGY = 0.400792E+06

TOTAL HEAT LOSSES BY 1-0 COMPONENTS: INSIDE = -6.649E+04 WATTS OUTSIDE = 9.704E+02 WATTS

TOTAL MASS DISCHARGED AT BREAKS = 0.00000E+00

TOTAL MASS INJECTED AT FILLS = 0.00000E+00

COMPUTED SYSTEM INITIAL MASS = 6.53191E+00

RESTART DUMP TAKEN AT TIME = 1.00000E-05 SEC. AFTER 1 Timesteps.

RESTART FROM HERE WILL RESUME COUNTING FOR.....

MAJOR EDIT AT T = 1.00000E-05 SEC

SMALL EDIT AT T = 0.00000E+00 SEC

DUMP TIME AT T = 1.00000E-05 SEC

GRAF TIME AT T = 1.00000E-05 SEC

\*\*\*\*\*  
\* NEW TIME DOMAIN REACHED \*  
\* MINIMUM MAXIMUM TIME LONG SHORT GRAPHICS DUMP \*  
\* TIME TIME DOMAIN EDIT EDIT EDIT EDIT \*  
\* STEP STEP END INTERVAL INTERVAL INTERVAL INTERVAL \*  
\* \*  
\* 1.000E-05 2.000E-04 2.000E-02 1.000E-02 1.000E-02 1.000E-05 1.000E-02 \*  
\*\*\*\*\*

CNEN  
DR

AUTOR: AAM/ LSG/ MRSR/ *Regina*  
GTT  
ORGÃO GAC

DOCUMENTO: N2 04/00  
NOTA TÉCNICA

PAGINA:  
C23/31

PARTE:  
APÊNDICE C

REVISÃO:  
0

DATA:  
NOVEMBRO/88

TRAC MAJOR EDIT

TIME = 1.012E-02 SECONDS DELT = 2.000E-04 SECONDS TIME STEPS = 93 OITMO = 2 ETIME = 1.01100E-02 SEC

TIME STEP STABILITY LIMITED BY COMPONENT 5, CELL 9, TO 1.02E+02SECONDS  
AVERAGE OUTER ITERATION COUNT OVER THE LAST 92 TIME STEPS WAS 1.97E+00  
TOTAL NUMBER OF TIMES THAT EACH COMPONENT WAS THE LAST TO CONVERGE SINCE THE LAST EDIT IS  
0 0 11 81 0 0

THE LAST MINIMUM NUMBER OF OUTER ITERATIONS WAS 1 AT STEP 27, LIMITED BY COMPONENT 4 WITH WAGER = 9.48E-03  
THE LAST MAXIMUM NUMBER OF OUTER ITERATIONS WAS 2 AT STEP 92, LIMITED BY COMPONENT 5 WITH WAGER = 4.17E-04  
LAST MINIMUM NUMBER OF VESSEL ITERATIONS WAS 0 AT STEP 92  
LAST MAXIMUM NUMBER OF VESSEL ITERATIONS WAS 0 AT STEP 92

CURRENT CONVERGENCE LIMITS AND LIMITATION COUNTS

DELRX	DELEFX	DELRX	DELVX	DELCX	DELDX
1.000E+00	1.000E+00	1.000E+00	7.570E+01	1.000E+00	1.000E+00
0	0	0	0	0	0

CPTIME = -1.504E+01

TIME = 0.0101 DELT = 2.000E-04

COMPONENT TYPE = PIPE COMPONENT NUMBER = 2 JUN1 = 1 JUN2 = 2

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T LIG	T VAP	DEM LIG	DEM VAP	LIG VEL	VAP VEL	FF
1	1.06505E+07	0.00000E+00	0.000E+00	5.891E+02	5.794E+02	5.891E+02	7.012E+02	6.020E+01	6.000E+00	0.000E+00	3.000E-02
2	1.07013E+07	0.00000E+00	0.000E+00	5.892E+02	5.794E+02	5.892E+02	7.012E+02	6.035E+01	-2.774E-02	-1.473E-01	2.031E-02
3	1.07195E+07	0.00000E+00	0.000E+00	5.893E+02	5.795E+02	5.893E+02	7.012E+02	6.047E+01	-0.961E-02	-4.046E-01	1.535E-02
4	1.07506E+07	0.00000E+00	0.000E+00	5.895E+02	5.795E+02	5.895E+02	7.012E+02	6.072E+01	-1.029E-01	-4.817E-01	1.392E-02
5	1.07521E+07	0.00000E+00	0.000E+00	5.895E+02	5.795E+02	5.895E+02	7.012E+02	6.074E+01	-1.479E-01	-3.917E-01	1.267E-02
6	1.07735E+07	0.00000E+00	0.000E+00	5.897E+02	5.795E+02	5.897E+02	7.013E+02	6.089E+01	-1.924E-01	-5.543E-01	1.203E-02
7	1.08185E+07	0.00000E+00	0.000E+00	5.900E+02	5.795E+02	5.900E+02	7.013E+02	6.123E+01	-1.506E-01	-2.270E-01	1.204E-02
8	1.07571E+07	0.00000E+00	0.000E+00	5.894E+02	5.795E+02	5.894E+02	7.012E+02	6.077E+01	-1.562E-01	2.919E-01	1.226E-02
9	1.05547E+07	0.00000E+00	0.000E+00	5.881E+02	5.794E+02	5.881E+02	7.010E+02	5.920E+01	-3.912E-01	2.147E-01	1.047E-02
10	1.03243E+07	0.00000E+00	0.000E+00	5.865E+02	5.793E+02	5.865E+02	7.005E+02	5.762E+01	-7.973E-01	-1.583E-01	9.661E-03
11									-1.853E+00	-1.179E+00	9.390E-03

CELL	IDR	HL	HV	HLV	OPPL	OPPV	TCHF	WALL TEMPERATURES BY NODE	
1	7	2.220E+02	0.000E+00	1.394E+04	-9.742E+01	0.000E+00	0.000E+00	579.00	579.00
2	7	6.199E+02	0.000E+00	1.396E+04	-2.745E+02	0.000E+00	0.000E+00	579.00	579.00
3	7	9.950E+02	0.000E+00	1.400E+04	-4.400E+02	0.000E+00	0.000E+00	579.00	579.00
4	7	1.462E+03	0.000E+00	1.405E+04	-6.800E+02	0.000E+00	0.000E+00	579.00	579.00
5	7	1.894E+03	0.000E+00	1.406E+04	-5.779E+02	0.000E+00	0.000E+00	579.00	579.00
6	7	1.820E+03	0.000E+00	1.415E+04	-8.639E+02	0.000E+00	0.000E+00	579.00	579.00
7	7	2.033E+03	0.000E+00	1.421E+04	-1.003E+03	0.000E+00	0.000E+00	579.00	579.00
8	7	3.746E+03	0.000E+00	1.296E+04	-1.732E+03	0.000E+00	0.000E+00	579.00	579.00
9	7	6.449E+03	0.000E+00	1.340E+04	-2.341E+03	0.000E+00	0.000E+00	579.00	579.00
10	7	1.126E+04	0.000E+00	1.266E+04	-2.843E+03	0.000E+00	0.000E+00	579.00	579.00

TOTAL COMPONENT WATER MASS= 2.760920E+00 TOTAL COMPONENT WATER ENERGY= 5.125294E+06 MASS= 3.755090E+00

TOTAL COMPONENT HEAT LOSS: INSIDE= 9.210E+02 WATTS OUTSIDE= 0.000E+00 WATTS

TIME = 0.0101 DELT = 2.000E-04

CNEN  
DR

LSG/ *Lio*  
MRSR/ *Regina*  
GTT  
ORGÃO GAC

NOTA TÉCNICA  
PARTE: APÊNDICE C  
REVISÃO: 0  
DATA: NOVEMBRO/88  
C24/31

COMPONENT TYPE = PIPE COMPONENT NUMBER = 3 JUN1 = 2 JUN2 = 3

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T LIO	T VAP	DEN LIO	DEN VAP	LIO VEL	VAP VEL	FF
1	1.01587E+07	0.00000E+00	0.000E+00	5.833E+02	5.792E+02	5.853E+02	7.006E+02	5.644E+01	-1.833E+00	-1.179E+00	9.379E-03
2	1.00780E+07	0.00000E+00	0.000E+00	5.847E+02	5.751E+02	5.847E+02	7.107E+02	5.587E+01	-1.920E+00	-1.288E+00	9.362E-03
3	1.00080E+07	0.00000E+00	0.000E+00	5.842E+02	5.711E+02	5.842E+02	7.204E+02	5.538E+01	-1.970E+00	-1.371E+00	9.344E-03
4	9.94745E+06	0.00000E+00	0.000E+00	5.838E+02	5.671E+02	5.838E+02	7.298E+02	5.496E+01	-2.043E+00	-1.416E+00	9.338E-03
5	9.88818E+06	0.00000E+00	0.000E+00	5.833E+02	5.631E+02	5.833E+02	7.390E+02	5.454E+01	-1.993E+00	-1.412E+00	9.343E-03
6	9.82329E+06	0.00000E+00	0.000E+00	5.829E+02	5.591E+02	5.829E+02	7.478E+02	5.410E+01	-1.945E+00	-1.352E+00	9.361E-03
7	9.74380E+06	0.00000E+00	0.000E+00	5.823E+02	5.550E+02	5.823E+02	7.562E+02	5.355E+01	-1.860E+00	-1.238E+00	9.393E-03
8	9.64832E+06	0.00000E+00	0.000E+00	5.815E+02	5.510E+02	5.815E+02	7.642E+02	5.284E+01	-1.734E+00	-1.071E+00	9.441E-03
9	9.54394E+06	0.00000E+00	0.000E+00	5.805E+02	5.469E+02	5.805E+02	7.715E+02	5.192E+01	-1.559E+00	-0.507E+00	9.515E-03
10	9.32478E+06	0.00000E+00	0.000E+00	5.791E+02	5.431E+02	5.791E+02	7.779E+02	5.074E+01	-1.328E+00	-5.722E-01	9.630E-03
11									-1.579E+00	-6.814E-01	9.865E-03

CELL	IDR	HL	HW	FLV	OPPL	OPPV	TCWF	WALL TEMPERATURES BY NODE				
1	2	2.453E+04	0.000E+00	3.309E+03	3.710E+05	0.000E+00	6.213E+02	594.29	601.31	606.48	611.36	614.78
2	2	2.222E+04	0.000E+00	3.328E+03	4.007E+05	0.000E+00	6.198E+02	593.16	600.30	605.48	610.36	613.78
3	2	2.127E+04	0.000E+00	3.350E+03	4.592E+05	0.000E+00	6.185E+02	592.71	600.26	605.47	610.36	613.78
4	2	2.048E+04	0.000E+00	3.374E+03	5.151E+05	0.000E+00	6.171E+02	592.27	600.23	605.47	610.36	613.78
5	2	1.975E+04	0.000E+00	3.398E+03	5.675E+05	0.000E+00	6.160E+02	591.84	600.19	605.47	610.36	613.78
6	2	1.758E+04	0.000E+00	3.415E+03	5.310E+05	0.000E+00	6.124E+02	589.27	597.23	602.47	607.37	610.78
7	2	1.534E+04	0.000E+00	3.431E+03	4.585E+05	0.000E+00	6.085E+02	584.92	592.29	597.48	602.37	605.99
8	1	1.437E+04	0.000E+00	3.433E+03	4.055E+05	0.000E+00	6.040E+00	579.25	586.32	591.43	596.37	599.99
9	1	1.339E+04	0.000E+00	3.419E+03	3.915E+05	0.000E+00	6.000E+00	576.16	583.31	588.48	593.37	597.10
10	1	1.460E+04	0.000E+00	3.394E+03	4.263E+05	0.000E+00	6.000E+00	572.32	580.24	585.47	590.37	594.04

TOTAL COMPONENT WATER MASS= 1.027735E+00 TOTAL COMPONENT WATER ENERGY= 1.297439E+06 MASS= 1.627923E+00  
TOTAL COMPONENT HEAT LOSS: INSIDE= -1.195E+05 WATTS OUTSIDE= 0.000E+00 WATTS

\*\*\*\*\* TIME = 0.0101 DELT = 2.000E-04 \*\*\*\*\*

COMPONENT TYPE = PIPE COMPONENT NUMBER = 4 JUN1 = 3 JUN2 = 4

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T LIO	T VAP	DEN LIO	DEN VAP	LIO VEL	VAP VEL	FF
1	0.74219E+06	0.00000E+00	0.000E+00	5.746E+02	5.427E+02	5.746E+02	7.776E+02	4.706E+01	-1.579E+00	-6.814E-01	9.885E-03
2	7.69323E+06	0.00000E+00	0.000E+00	5.655E+02	5.427E+02	5.655E+02	7.757E+02	4.046E+01	-4.770E-01	5.175E-01	1.075E-02
3	6.54809E+06	0.00000E+00	0.000E+00	5.545E+02	5.427E+02	5.545E+02	7.736E+02	3.391E+01	1.119E+00	2.173E+00	1.015E-02
4	5.75228E+06	0.00000E+00	0.000E+00	5.460E+02	5.427E+02	5.460E+02	7.720E+02	2.941E+01	2.653E+00	3.592E+00	9.617E-03
5	5.35138E+06	0.00000E+00	0.000E+00	5.457E+02	5.430E+02	5.457E+02	7.711E+02	2.832E+01	3.430E+00	4.877E+00	9.445E-03
6	5.61244E+06	0.00000E+00	0.000E+00	5.444E+02	5.434E+02	5.444E+02	7.706E+02	2.855E+01	3.431E+00	2.677E+00	9.454E-03
7	5.59362E+06	0.00000E+00	0.000E+00	5.442E+02	5.437E+02	5.442E+02	7.700E+02	2.855E+01	3.366E+00	3.335E+00	9.464E-03
8	5.57930E+06	0.00000E+00	0.000E+00	5.439E+02	5.440E+02	5.439E+02	7.694E+02	2.842E+01	3.355E+00	3.701E+00	9.460E-03
9	5.53932E+06	0.00000E+00	0.000E+00	5.436E+02	5.442E+02	5.436E+02	7.689E+02	2.826E+01	3.483E+00	3.927E+00	9.481E-03
10	5.35401E+06	0.00000E+00	0.000E+00	5.413E+02	5.439E+02	5.413E+02	7.691E+02	2.724E+01	5.105E+00	5.880E+00	9.529E-03
11									1.371E+01	1.444E+01	9.514E-03

CELL	IDR	HL	HW	FLV	OPPL	OPPV	TCWF	WALL TEMPERATURES BY NODE				
1	7	1.327E+04	0.000E+00	4.982E+03	1.658E+04	0.000E+00	0.000E+00	543.94	544.60			





CNEN  
DR

LSG/ <sup>200</sup>Regina  
MRS/ <sup>200</sup>Regina  
GTT  
GAC

DOCUMENTO Nº 02/88  
NOTA TÉCNICA  
PARTE: APÊNDICE C  
REVISÃO: 0

PÁGINA: C27/31  
DATA: NOVEMBRO/88

TRAC MAJOR EDIT

TIME = 2.012E-02 SECONDS DELT = 2.000E-04 SECONDS TIME STEPS = 143 OITM = 1 ETIME = 2.01189E-02 SEC

TIME STEP STABILITY LIMITED BY COMPONENT 5, CELL 8, TO 8.75E+01SECONDS  
AVERAGE OUTER ITERATION COUNT OVER THEIR LAST 50 TIME STEPS WAS 1.56E+00  
TOTAL NUMBER OF TIMES THAT EACH COMPONENT WAS THE LAST TO CONVERGE SINCE THE LAST EDIT IS

0 10 13 27 0 0

THE LAST MINIMUM NUMBER OF OUTER ITERATIONS WAS 1 AT STEP 142, LIMITED BY COMPONENT 3 WITH VARER = 8.50E-03  
THE LAST MAXIMUM NUMBER OF OUTER ITERATIONS WAS 2 AT STEP 124, LIMITED BY COMPONENT 3 WITH VARER = 1.74E-05  
LAST MINIMUM NUMBER OF VESSEL ITERATIONS WAS 0 AT STEP 142  
LAST MAXIMUM NUMBER OF VESSEL ITERATIONS WAS 0 AT STEP 142

CURRENT CONVERGENCE LIMITS AND LIMITATION COUNTS

DELRX	DELRX	DELRX	DELRX	DELRX	DELRX
1.000E+00	1.000E+00	1.000E+00	0.029E+01	1.000E+00	1.000E+00
0	0	0	0	0	0

CPTIME = -2.289E+01

\*\*\*\*\* TIME = 0.0201 DELT = 2.000E-04 \*\*\*\*\*

COMPONENT TYPE = PIPE COMPONENT NUMBER = 2 JUN1 = 1 JUN2 = 2

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T L10	T VAP	DEN L10	DEN VAP	L10 VEL	VAP VEL	FF
1	1.89960E+07	0.00000E+00	0.000E+00	5.912E+02	5.796E+02	5.912E+02	7.015E+02	6.256E+01	0.000E+00	0.000E+00	3.000E-02
2	1.89832E+07	0.00000E+00	0.000E+00	5.911E+02	5.795E+02	5.911E+02	7.015E+02	6.247E+01	-4.273E-02	5.840E-02	1.478E-02
3	1.89734E+07	0.00000E+00	0.000E+00	5.908E+02	5.794E+02	5.908E+02	7.014E+02	6.240E+01	-4.475E-02	3.690E-01	1.573E-02
4	1.89666E+07	0.00000E+00	0.000E+00	5.899E+02	5.795E+02	5.899E+02	7.013E+02	6.114E+01	4.511E-02	5.900E-01	2.836E-02
5	1.85607E+07	0.00000E+00	0.000E+00	5.882E+02	5.794E+02	5.882E+02	7.010E+02	5.933E+01	2.819E-01	9.250E-01	1.100E-02
6	1.81907E+07	0.00000E+00	0.000E+00	5.856E+02	5.792E+02	5.856E+02	7.006E+02	5.646E+01	6.984E-01	1.413E+00	1.007E-02
7	9.75430E+06	0.00000E+00	0.000E+00	5.824E+02	5.790E+02	5.824E+02	7.001E+02	5.364E+01	1.258E+00	2.000E+00	9.353E-03
8	9.37511E+06	0.00000E+00	0.000E+00	5.796E+02	5.788E+02	5.796E+02	6.997E+02	5.119E+01	1.824E+00	2.544E+00	9.055E-03
9	9.26974E+06	0.00000E+00	0.000E+00	5.786E+02	5.787E+02	5.786E+02	6.996E+02	5.036E+01	2.155E+00	2.707E+00	8.917E-03
10	9.18929E+06	0.00000E+00	1.624E-05	5.774E+02	5.787E+02	5.774E+02	6.994E+02	4.930E+01	2.433E+00	3.039E+00	8.837E-03
11									3.766E+00	4.336E+00	9.002E-03

CELL	IGR	N	NV	HLV	OPFL	OPPV	TCIF	WALL TEMPERATURES BY NODE	
1	7	4.121E+02	0.000E+00	1.457E+04	-2.419E+02	0.000E+00	0.000E+00	579.00	579.00
2	7	8.392E+02	0.000E+00	1.456E+04	-4.857E+02	0.000E+00	0.000E+00	579.00	579.00
3	7	6.734E+02	0.000E+00	1.458E+04	-3.724E+02	0.000E+00	0.000E+00	579.00	579.00
4	7	1.635E+03	0.000E+00	1.431E+04	-5.061E+02	0.000E+00	0.000E+00	579.00	579.00
5	7	3.256E+03	0.000E+00	1.398E+04	-1.198E+03	0.000E+00	0.000E+00	579.00	579.00
6	7	6.456E+03	0.000E+00	1.325E+04	-1.203E+03	0.000E+00	0.000E+00	579.00	579.00
7	7	1.007E+04	0.000E+00	1.247E+04	2.297E+02	0.000E+00	0.000E+00	579.00	579.00
8	7	1.328E+04	0.000E+00	1.178E+04	2.660E+03	0.000E+00	0.000E+00	579.00	579.00
9	7	1.545E+04	0.000E+00	1.143E+04	4.002E+03	0.000E+00	0.000E+00	579.00	579.00
10	7	2.037E+04	0.000E+00	1.119E+04	6.737E+03	0.000E+00	0.000E+00	579.00	579.00

TOTAL COMPONENT WATER MASS= 3.758225E+06 TOTAL COMPONENT WATER ENERGY= 5.121578E+06 GRASS= 2.755691E+06

TOTAL COMPONENT HEAT LOSS: INSIDE= -7.897E+02 WATTS OUTSIDE= 0.000E+00 WATTS

\*\*\*\*\* TIME = 0.0201 DELT = 2.000E-04 \*\*\*\*\*

CNEN  
DR

LSG/ *Lis*  
MRSG/ *Regina*  
GTT  
GAC

DOCUMENTO: 027/00  
NOTA TÉCNICA  
PARTE: APÊNDICE C

C28/31  
REVISÃO: Ø  
DATA: NOVEMBRO/88

COMPONENT TYPE = PIPE COMPONENT NUMBER = 3 JUN1 = 2 JUN2 = 3

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T LIG	T VAP	DEN LIG	DEN VAP	LIG VEL	VAP VEL	FF
1	9.02451E+06	0.00000E+00	1.447E-02	5.767E+02	5.786E+02	5.767E+02	6.993E+02	4.875E+01	3.746E+00	4.336E+00	9.062E-03
2	8.98043E+06	0.00000E+00	3.363E-04	5.766E+02	5.756E+02	5.764E+02	7.083E+02	4.851E+01	5.824E+00	6.340E+00	8.833E-03
3	8.95276E+06	0.00000E+00	4.363E-06	5.761E+02	5.711E+02	5.761E+02	7.179E+02	4.829E+01	5.827E+00	6.338E+00	8.756E-03
4	8.90245E+06	0.00000E+00	0.000E+00	5.757E+02	5.672E+02	5.757E+02	7.272E+02	4.796E+01	5.769E+00	6.326E+00	8.704E-03
5	8.82587E+06	0.00000E+00	0.000E+00	5.751E+02	5.633E+02	5.751E+02	7.362E+02	4.747E+01	5.661E+00	6.288E+00	8.794E-03
6	8.71579E+06	0.00000E+00	0.000E+00	5.742E+02	5.593E+02	5.742E+02	7.458E+02	4.676E+01	5.594E+00	6.184E+00	8.907E-03
7	8.58825E+06	0.00000E+00	0.000E+00	5.731E+02	5.552E+02	5.731E+02	7.554E+02	4.594E+01	5.395E+00	6.028E+00	8.822E-03
8	8.44147E+06	0.00000E+00	0.000E+00	5.720E+02	5.511E+02	5.720E+02	7.655E+02	4.543E+01	5.093E+00	5.827E+00	8.845E-03
9	8.32099E+06	0.00000E+00	0.000E+00	5.710E+02	5.471E+02	5.710E+02	7.697E+02	4.428E+01	4.902E+00	5.615E+00	8.867E-03
10	8.22910E+06	0.00000E+00	0.000E+00	5.702E+02	5.434E+02	5.702E+02	7.755E+02	4.371E+01	4.753E+00	5.420E+00	8.882E-03
11									7.090E+00	7.704E+00	9.118E-03

IDR	HL	HV	HLV	OPPL	OPPV	TCIF	WALL TEMPERATURES BY NODE					
1	2	4.292E+04	5.698E+00	2.900E+01	6.371E+05	9.326E+01	6.156E+02	593.89	601.45	606.89	611.56	614.33
2	2	4.781E+04	0.000E+00	2.866E+03	7.795E+05	0.000E+00	6.101E+02	591.36	600.40	605.87	610.56	613.33
3	2	4.536E+04	0.000E+00	2.877E+02	8.643E+05	0.000E+00	6.076E+02	590.20	600.25	605.86	610.56	613.33
4	2	4.324E+04	0.000E+00	2.883E+03	9.410E+05	0.000E+00	6.054E+02	589.00	600.12	605.85	610.56	613.33
5	2	4.131E+04	0.000E+00	2.878E+03	1.010E+06	0.000E+00	6.034E+02	587.77	599.07	605.83	610.56	613.33
6	2	3.856E+04	0.000E+00	2.863E+03	9.948E+05	0.000E+00	6.004E+02	585.10	597.05	602.85	607.56	610.34
7	2	3.552E+04	0.000E+00	2.844E+03	9.245E+05	0.000E+00	5.962E+02	581.24	592.23	597.87	602.57	605.35
8	2	3.227E+04	0.000E+00	2.829E+03	8.252E+05	0.000E+00	5.851E+02	576.41	586.56	591.89	596.57	599.56
9	2	3.152E+04	0.000E+00	2.822E+03	8.270E+05	0.000E+00	5.809E+02	573.37	583.35	588.89	593.57	596.56
10	1	3.771E+04	0.000E+00	2.819E+03	9.645E+05	0.000E+00	0.000E+00	568.78	580.15	585.50	592.57	592.57

TOTAL COMPONENT WATER MASS= 1.023028E+00 TOTAL COMPONENT WATER ENERGY= 1.294153E+06 GRASS= 1.027922E+06

TOTAL COMPONENT HEAT LOSS: INSIDE= -2.316E+05 WATTS OUTSIDE= 0.000E+00 WATTS

\*\*\*\*\* TIME = 0.0201 DELT = 2.000E-04 \*\*\*\*\*

COMPONENT TYPE = PIPE COMPONENT NUMBER = 4 JUN1 = 3 JUN2 = 4

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T LIG	T VAP	DEN LIG	DEN VAP	LIG VEL	VAP VEL	FF
1	8.04552E+06	0.00000E+00	0.000E+00	5.685E+02	5.425E+02	5.686E+02	7.765E+02	4.259E+01	7.090E+00	7.704E+00	9.115E-03
2	7.86514E+06	0.00000E+00	0.000E+00	5.670E+02	5.427E+02	5.670E+02	7.759E+02	4.158E+01	6.871E+00	7.499E+00	9.175E-03
3	7.62799E+06	0.00000E+00	0.000E+00	5.649E+02	5.429E+02	5.649E+02	7.750E+02	4.047E+01	6.624E+00	7.297E+00	9.145E-03
4	7.38395E+06	0.00000E+00	0.000E+00	5.615E+02	5.432E+02	5.615E+02	7.741E+02	3.815E+01	6.261E+00	6.908E+00	9.140E-03
5	6.90663E+06	0.00000E+00	0.000E+00	5.581E+02	5.424E+02	5.581E+02	7.730E+02	3.535E+01	5.791E+00	6.579E+00	9.204E-03
6	6.47332E+06	0.00000E+00	0.000E+00	5.535E+02	5.424E+02	5.535E+02	7.718E+02	3.379E+01	5.316E+00	6.131E+00	9.247E-03
7	6.03456E+06	0.00000E+00	2.654E-05	5.491E+02	5.436E+02	5.491E+02	7.706E+02	3.095E+01	4.913E+00	5.750E+00	9.280E-03
8	5.64180E+06	0.00000E+00	2.784E-03	5.440E+02	5.440E+02	5.440E+02	7.696E+02	2.893E+01	4.454E+00	5.474E+00	9.318E-03
9	5.47379E+06	0.00000E+00	3.420E-02	5.428E+02	5.428E+02	5.428E+02	7.694E+02	2.790E+01	4.282E+00	4.982E+00	9.567E-03
10	5.29179E+06	0.00000E+00	1.637E-01	5.406E+02	5.424E+02	5.406E+02	7.717E+02	2.693E+01	7.342E+00	8.833E+00	1.007E-02
11									2.221E+01	2.321E+01	1.069E-02

IDR	HL	HV	HLV	OPPL	OPPV	TCIF	WALL TEMPERATURES BY NODE	
1	7	4.410E+04	0.000E+00	4.321E+03	5.642E+04	0.000E+00	0.000E+00	543.80 543.99

CNEN  
DR

LSG/ <sup>100</sup>  
MRSRG/ Regina

NOTA TÉCNICA

PAGINA: C29/31

ORGÃO

GTT  
GAC

PARTE:  
APÊNDICE C

REVISÃO:  
Ø

DATA:  
NOVEMBRO/88

2	7	4.281E+04	0.000E+00	4.221E+03	4.661E+04	0.000E+00	0.000E+00	543.83	544.00
3	7	4.074E+04	0.000E+00	4.073E+03	3.538E+04	0.000E+00	0.000E+00	543.67	544.00
4	7	3.853E+04	0.000E+00	3.888E+03	2.616E+04	0.000E+00	0.000E+00	543.90	544.00
5	7	3.579E+04	0.000E+00	3.670E+03	1.834E+04	0.000E+00	0.000E+00	543.93	544.00
6	7	3.333E+04	0.000E+00	3.495E+03	1.164E+04	0.000E+00	0.000E+00	543.76	544.00
7	7	3.155E+04	0.000E+00	3.314E+03	6.207E+03	0.000E+00	0.000E+00	543.99	544.00
8	7	3.017E+04	0.000E+00	3.155E+03	1.809E+03	0.000E+00	0.000E+00	544.02	544.00
9	7	3.789E+04	0.000E+00	3.433E+03	6.473E+03	0.000E+00	0.000E+00	544.03	544.00
10	7	7.166E+04	0.000E+00	9.637E+03	1.039E+05	0.000E+00	0.000E+00	543.89	544.00

TOTAL COMPONENT WATER MASS= 1.644144E+00 TOTAL COMPONENT WATER ENERGY= 1.935721E+06 MASS= 1.684270E+00

TOTAL COMPONENT HEAT LOSS: INSIDE= -1.614E+04 WATTS OUTSIDE= 0.000E+00 WATTS

TIME = 0.0201 DELT = 2.000E-04

COMPONENT TYPE = PIPE COMPONENT NUMBER = 5 JUN1 = 4 JUN2 = 5

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T L10	T VAP	DEN L10	DEN VAP	L10 VEL	VAP VEL	FF
1	4.04958E+05	0.00000E+00	3.917E-01	5.358E+02	5.279E+02	5.349E+02	7.707E+02	2.435E+01	2.221E+01	2.321E+01	1.069E-02
2	4.64865E+06	0.00000E+00	5.327E-01	5.324E+02	5.353E+02	5.323E+02	7.858E+02	2.349E+01	3.162E+01	3.298E+01	1.576E-02
3	4.36262E+06	0.00000E+00	6.071E-01	5.286E+02	5.207E+02	5.283E+02	7.921E+02	2.204E+01	4.293E+01	4.473E+01	1.939E-02
4	4.14153E+06	0.00000E+00	6.564E-01	5.255E+02	5.255E+02	5.245E+02	7.767E+02	2.094E+01	5.166E+01	5.958E+01	2.149E-02
5	3.95642E+06	0.00000E+00	6.895E-01	5.233E+02	5.233E+02	5.228E+02	7.975E+02	2.017E+01	5.855E+01	6.983E+01	2.504E-02
6	3.85205E+06	0.00000E+00	7.168E-01	5.213E+02	5.213E+02	5.208E+02	8.026E+02	1.948E+01	6.445E+01	7.532E+01	2.743E-02
7	3.72735E+06	0.00000E+00	7.579E-01	5.197E+02	5.197E+02	5.181E+02	8.051E+02	1.885E+01	7.015E+01	8.179E+01	3.667E-02
8	2.85445E+06	0.00000E+00	9.122E-01	5.035E+02	5.035E+02	5.031E+02	8.234E+02	1.437E+01	8.126E+01	8.654E+01	4.737E-02
9									2.118E+02	1.418E+02	7.956E-02

IDR HL HW HLW OPPL OPPV TCHF WALL TEMPERATURES BY NODE

CELL	IDR	HL	HW	HLW	OPPL	OPPV	TCHF	WALL TEMPERATURES BY NODE
1	7	9.588E+04	0.000E+00	2.963E+03	4.734E+05	0.000E+00	0.000E+00	542.81 543.97
2	7	1.074E+05	0.000E+00	6.757E+03	8.552E+05	0.000E+00	0.000E+00	541.74 543.93
3	7	1.191E+05	0.000E+00	5.918E+03	1.238E+06	0.000E+00	0.000E+00	537.14 543.86
4	7	1.269E+05	0.000E+00	2.551E+03	1.517E+06	0.000E+00	0.000E+00	537.44 543.81
5	7	1.316E+05	0.000E+00	3.673E+03	1.683E+06	0.000E+00	0.000E+00	536.11 543.77
6	7	1.348E+05	0.000E+00	3.711E+03	1.623E+06	0.000E+00	0.000E+00	534.82 543.72
7	7	1.257E+05	0.000E+00	1.104E+03	1.948E+06	0.000E+00	0.000E+00	529.52 543.66
8	7	1.266E+05	0.000E+00	1.520E+04	3.275E+06	0.000E+00	0.000E+00	529.77 543.53

TOTAL COMPONENT WATER MASS= 3.201311E-02 TOTAL COMPONENT WATER ENERGY= 3.762461E+04 MASS= 7.130207E-02

TOTAL COMPONENT HEAT LOSS: INSIDE= -2.464E+04 WATTS OUTSIDE= 0.020E+00 WATTS

TIME = 0.0201 DELT = 2.000E-04

COMPONENT TYPE = FILL COMPONENT NUMBER = 1 JUN1 = 1

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T L10	T VAP	DEN L10	DEN VAP	L10 VEL	VAP VEL	FF
1	9.82000E+06	0.00000E+00	0.000E+00	5.828E+02	5.835E+02	5.828E+02	6.805E+02	5.407E+01	0.000E+00	0.000E+00	0.000E+00
2									0.000E+00	0.000E+00	0.000E+00

CNEN  
DR

ÓRGÃO

AUTOR: LSG/  
MRSR/ Regina  
GTT  
GAC

DOCUMENTO: Nº 02/88

PAGINA:

NOTA TÉCNICA

C30/31

PARTE:  
APÊNDICE C

REVISÃO:  
0

DATA:  
NOVEMBRO/88

MASS FLOW RATE = 0.0000E+00      TOTAL MASS IN = 0.0000E+00

\*\*\*\*\* TIME = 0.0201 DELT = 2.000E-04 \*\*\*\*\*

COMPONENT TYPE = BREAK      COMPONENT NUMBER = 6      JUNK = 5

CELL	PRESSURE	AIR P	VAPOR FRAC	T SAT	T LIO	T VAP	DEN LIO	DEN VAP	LIO VEL	VAP VEL	FF
1	1.0000E+05	0.0000E+00	1.000E+00	3.730E+02	3.730E+02	3.730E+02	9.547E+02	5.908E-01	2.118E+02	1.410E+02	0.000E+00
2									0.000E+00	0.000E+00	0.000E+00

MASS FLOW RATE = 3.8761E+00      TOTAL MASS OUT = 8.1781E-02

AIR MASS FLOW RATE = 0.0000E+00      TOTAL AIR MASS OUT = 0.0000E+00

TOTAL SYSTEM WATER MASS = 6.457404E+00      TOTAL SYSTEM WATER ENERGY= 8.389859E+04

TOTAL HEAT LOSSES BY 1-D COMPONENTS:      INSIDE= -2.731E+05 WATTS      OUTSIDE= 9.652E+02 WATTS

TOTAL MASS DISCHARGED AT BREAKS = 8.178067E-02

TOTAL MASS INJECTED AT FILLS = 0.000000E+00

COMPUTED SYSTEM INITIAL MASS = 6.539184E+00

RESTART DUMP TAKEN AT TIME = 2.01189E-02 SEC, AFTER 143 TIMESTEPS.

RESTART FROM HERE WILL RESUME COUNTING FOR.....

MAJOR EDIT AT T= 2.00200E-02 SEC

SMALL EDIT AT T= 2.00000E-05 SEC

PUMP TIME AT T= 2.01189E-02 SEC

GRAF TIME AT T= 2.01189E-02 SEC

PROBLEM TIMING STATISTICS

CPU = -2.3674E+01

CNEN  
DR

AUTOR: AAM/ *Ac*  
LSG/ *lv*  
MRSR/ *Rizina*  
GTT  
ÓRGÃO GAC

DOCUMENTO: Nº 02/86

PAGINA:

NOTA TÉCNICA

C31/31

PARTE:

REVISÃO:

DATA:

APENDICE C

Ø

NOVEMBRO/88

++++ MAIN +++++ FINAL STOP +++++

FORTRAN STOP

REGINA job terminated at 17-NOV-1988 11:14:59.32

Accounting information:

Buffered I/O count:	731	Peak working set size:	1000
Direct I/O count:	5689	Peak page file size:	4855
Page faults:	32192	Mounted volumes:	6
Charged CPU time:	Ø 00:15:49.40	Elapsed time:	Ø 00:40:08.69